

Bobcaygeon Drinking Water System

Waterworks # 210000318
System Category – Large Municipal Residential

Annual Water Report

Prepared For: The City of Kawartha Lakes
Reporting Period of January 1st 2018 – December 31st 2018

Issued: February 19, 2019

Revision: 0

Operating Authorities:



This report has been prepared to satisfy the annual reporting requirements in O. Reg. 170/03 Section 11 and Schedule 22

Table of Contents

Annual Water Report	1
Report Availability	1
Compliance Report Card	1
System Process Description	1
Raw Source	1
Treatment	2
Treatment Chemicals used during the reporting year:	2
Summary of Non-Compliance.....	2
Adverse Water Quality Incidents.....	2
Non-Compliance	2
Non-Compliance Identified in a Ministry Inspection:	3
Flows	3
Raw Water Flows.....	3
Total Monthly Flows (m ³ /d)	4
Monthly Rate Flows (L/s)	4
Treated Water Flows	5
Monthly Rated Flows	5
Annual Total Flow Comparison.....	5
Regulatory Sample Results Summary	6
Microbiological Testing	6
Operational Testing	6
Inorganic Parameters	6
Schedule 15 Sampling:.....	7
Organic Parameters.....	8
Additional Legislated Samples.....	9
Major Maintenance Summary	9
WTRS Data and Submission Confirmation	A

Report Availability

This system does not serve more than 10,000 residences. The annual reports will be available to residents at the City of Kawartha Lakes Municipal Office and on the City of Kawartha Lakes website at: www.kawarthalakes.ca Notification that reports are available free of charge will be made on the City's website. The City of Kawartha Lakes Public Works Administration Office is located at 12 Peel Street in Lindsay, Ontario.

Compliance Report Card

Drinking Water System Number: 210000318

Drinking Water System Name: Bobcaygeon DWS

Drinking Water System Owner: City of Kawartha Lakes

Drinking Water System Category: Large Municipal Residential

Period Being Reported: January 1, 2018 - December 31, 2018

	# of Events	Date	Details
Health & Safety			
Number of Incidents	0		
Drinking Water			
MECP Inspections	1	September 25, 2018	Announced-Focused Drinking Water Inspection - Final Inspection Rating of 100%
AWQI's	0	N/A	N/A
Number of Non-Compliances	1	November 5, 2018	Combined chlorine was not recorded for a treated water bacteriological sample. Total chlorine was recorded but the free chlorine residual was collected prior to the addition of the Ammonium Sulphate.
Number of Boil Water Advisories	0		

System Process Description

Raw Source

The Bobcaygeon DWS sources its water from the Big Bob River.

Treatment

The treatment system consists of the following:

- Three lowlifts
- SternPAC feed system with metering pumps
- Two solids re-circulating reactivator type flocculator/clarifier units in parallel which includes flash mixing, flocculation and sedimentation chambers
- Two dual media (anthracite/sand) high rate gravity filters in parallel
- Continuous online turbidity analyzers
- Sodium hypochlorite feed system with metering pumps
- Continuous online chlorine analyzers
- Four clear wells
- Ammonium sulfate feed system with metering pumps
- Continuous online flow meters
- Three highlifts
- Water storage standpipe with a capacity of 4400 m³
- One surge equalization tank for the sludge from the settling tanks and the backwash wastewater from the filters
- Standby power generator

Treatment Chemicals used during the reporting year:

Chemical Name	Use	Supplier
Sodium Hypochlorite	Disinfection	Brenntag
SternPAC	Coagulant	Kemira
Ammonium Sulphate	Chloramination	FloChem

Summary of Non-Compliance

Adverse Water Quality Incidents

There were no AWQI's for this system during the reporting period.

Non-Compliance

Legislation	Requirement(s) system failed to meet	Duration of the failure (i.e. date(s))	Corrective Action	Status
O. Reg. 170/03	Combined chlorine was not recorded for a treated water bacteriological sample. Total chlorine was	November 5, 2018	Training was provided to staff on the location of the free chlorine residual in order to calculate the	Complete

Legislation	Requirement(s) system failed to meet	Duration of the failure (i.e. date(s))	Corrective Action	Status
	recorded but the free chlorine residual was collected prior to the addition of the Ammonium Sulphate.		combined chlorine.	

Non-Compliance Identified in a Ministry Inspection:

Legislation Requirement(s) system failed to meet	Duration of the failure	(i.e. date(s))	Corrective Action	Status
There were no non-compliances identified in a Ministry Inspection during this period.				

Flows


The Bobcaygeon Drinking Water System is operating near half the rated capacity.

Raw Water Flows

The Raw Water flows are regulated under the Permit to Take Water. 2018 Raw Flow Data was submitted to the Ministry electronically under permit #7640-AQJHCV. The confirmation and a copy of the data that was submitted are attached in Appendix A.


Total Monthly Flows (m³/d)

Max Allowable PTTW- Raw



Monthly Rated Flows (L/s)

Max allowable rate – PTTW- Raw




Note: The above table shows there were exceedances in instantaneous peak flow rate (L/s) which were caused during maintenance of the clarifiers. The scheduled Flow Meter calibration was in July.

Treated Water Flows

The Treated Water flows are regulated under the Municipal Licence.


Monthly Rated Flows

Rated Capacity - MDWL



Annual Total Flow Comparison

Total Annual m³



Regulatory Sample Results Summary

Microbiological Testing

Water	No. of Samples Collected	Range of E.Coli Results		Range of Total Coliform Results		Range of HPC Results	
		Min / Max		Min / Max		Min / Max	
Raw	52	0	39	5	1280		
Treated	52	0	0	0	0	0	2
Distribution	157	0	0	0	0	0	66

Operational Testing

	No. of Samples Collected	Range of Results	
		Minimum	Maximum
Turbidity Raw	64	0.45	1.65
Turbidity Filter 1	8760	0	2
Turbidity Filter 2	8760	0	2
Chlorine	8760	0	7.21
Fluoride (If the DWS provides fluoridation)	N/A	N/A	N/A

Note: Record the unit of measure if it is **not** milligrams per litre.

Note: For continuous monitors 8760 is used as the number of samples. Spikes recorded by on-line instrumentation were a result of air bubbles and various maintenance/calibration activities. All spikes are reviewed for compliance with O. Reg. 170/03

Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium and Fluoride are required to be tested every five years. Nitrate and Nitrite are tested quarterly and the metals are tested annually as required under O. Reg. 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- MDL = Method Detection Limit

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances	
				MAC	1/2 MAC
Treated Water					
Antimony: Sb (ug/L) - TW	2018/01/08	<MDL 0.02	6.0	No	No
Arsenic: As (ug/L) - TW	2018/01/08	<MDL 0.2	10.0	No	No
Barium: Ba (ug/L) - TW	2018/01/08	21.5	1000.0	No	No
Boron: B (ug/L) - TW	2018/01/08	6.0	5000.0	No	No

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances	
				MAC	1/2 MAC
Cadmium: Cd (ug/L) - TW	2018/01/08	<MDL 0.003	5.0	No	No
Chromium: Cr (ug/L) - TW	2018/01/08	0.09	50.0	No	No
Mercury: Hg (ug/L) - TW	2018/01/08	<MDL 0.01	1.0	No	No
Selenium: Se (ug/L) - TW	2018/01/08	0.05	50.0	No	No
Uranium: U (ug/L) - TW	2018/01/08	0.01	20.0	No	No
Additional Inorganics					
Fluoride (mg/L) - TW	2018/01/08	<MDL 0.06	1.5	No	No
Nitrite (mg/L) - TW	2018/01/08	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2018/04/03	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2018/07/09	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2018/10/09	<MDL 0.003	1.0	No	No
Nitrate (mg/L) - TW	2018/01/08	0.091	10.0	No	No
Nitrate (mg/L) - TW	2018/04/03	0.308	10.0	No	No
Nitrate (mg/L) - TW	2018/07/09	0.042	10.0	No	No
Nitrate (mg/L) - TW	2018/10/09	0.075	10.0	No	No
Sodium: Na (mg/L) - TW	2018/01/08	8.54	20*	No	No

*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

Schedule 15 Sampling:

The Schedule 15 Sampling is required under O.Reg 170/03. This system is under reduced sampling. No plumbing samples were collected.

Distribution System	Number of Sampling Points	Number of Samples	Range of Results		MAC (ug/L)	Exceedances
			Minimum	Maximum		
Alkalinity (mg/L)	6	6	51	70	N/A	N/A
pH	6	6	7.15	7.83	N/A	N/A
Lead (ug/l)	N/A	N/A				

Organic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances	
				MAC	1/2 MAC
Treated Water					
Alachlor (ug/L) - TW	2018/01/08	<MDL 0.02	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW	2018/01/08	<MDL 0.01	5.00	No	No
Azinphos-methyl (ug/L) - TW	2018/01/08	<MDL 0.05	20.00	No	No
Benzene (ug/L) - TW	2018/01/08	<MDL 0.32	1.00	No	No
Benzo(a)pyrene (ug/L) - TW	2018/01/08	<MDL 0.004	0.01	No	No
Bromoxynil (ug/L) - TW	2018/01/08	<MDL 0.33	5.00	No	No
Carbaryl (ug/L) - TW	2018/01/08	<MDL 0.05	90.00	No	No
Carbofuran (ug/L) - TW	2018/01/08	<MDL 0.01	90.00	No	No
Carbon Tetrachloride (ug/L) - TW	2018/01/08	<MDL 0.16	2.00	No	No
Chlorpyrifos (ug/L) - TW	2018/01/08	<MDL 0.02	90.00	No	No
Diazinon (ug/L) - TW	2018/01/08	<MDL 0.02	20.00	No	No
Dicamba (ug/L) - TW	2018/01/08	<MDL 0.2	120.00	No	No
1,2-Dichlorobenzene (ug/L) - TW	2018/01/08	<MDL 0.41	200.00	No	No
1,4-Dichlorobenzene (ug/L) - TW	2018/01/08	<MDL 0.36	5.00	No	No
1,2-Dichloroethane (ug/L) - TW	2018/01/08	<MDL 0.35	5.00	No	No
1,1-Dichloroethylene (ug/L) - TW	2018/01/08	<MDL 0.33	14.00	No	No
Dichloromethane (Methylene Chloride) (ug/L) - TW	2018/01/08	<MDL 0.35	50.00	No	No
2,4-Dichlorophenol (ug/L) - TW	2018/01/08	<MDL 0.15	900.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW	2018/01/08	<MDL 0.19	100.00	No	No
Diclofop-methyl (ug/L) - TW	2018/01/08	<MDL 0.4	9.00	No	No
Dimethoate (ug/L) - TW	2018/01/08	<MDL 0.03	20.00	No	No
Diquat (ug/L) - TW	2018/01/08	<MDL 1.0	70.00	No	No
Diuron (ug/L) - TW	2018/01/08	<MDL 0.03	150.00	No	No
Glyphosate (ug/L) - TW	2018/01/08	<MDL 1.0	280.00	No	No
Malathion (ug/L) - TW	2018/01/08	<MDL 0.02	190.00	No	No
Metolachlor (ug/L) - TW	2018/01/08	<MDL 0.01	50.00	No	No
Metribuzin (ug/L) - TW	2018/01/08	<MDL 0.02	80.00	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) - TW	2018/01/08	<MDL 0.3	80.00	No	No
Paraquat (ug/L) - TW	2018/01/08	<MDL 1.0	10.00	No	No

	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances	
				MAC	1/2 MAC
PCB (ug/L) - TW	2018/01/08	<MDL 0.04	3.00	No	No
Pentachlorophenol (ug/L) - TW	2018/01/08	<MDL 0.15	60.00	No	No
Phorate (ug/L) - TW	2018/01/08	<MDL 0.01	2.00	No	No
Picloram (ug/L) - TW	2018/01/08	<MDL 1.0	190.00	No	No
Prometryne (ug/L) - TW	2018/01/08	<MDL 0.03	1.00	No	No
Simazine (ug/L) - TW	2018/01/08	<MDL 0.01	10.00	No	No
Terbufos (ug/L) - TW	2018/01/08	<MDL 0.01	1.00	No	No
Tetrachloroethylene (ug/L) - TW	2018/01/08	<MDL 0.35	10.00	No	No
2,3,4,6-Tetrachlorophenol (ug/L) - TW	2018/01/08	<MDL 0.2	100.00	No	No
Triallate (ug/L) - TW	2018/01/08	<MDL 0.01	230.00	No	No
Trichloroethylene (ug/L) - TW	2018/01/08	<MDL 0.44	5.00	No	No
2,4,6-Trichlorophenol (ug/L) - TW	2018/01/08	<MDL 0.25	5.00	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L) - TW	2018/01/08	<MDL 0.12	100.00	No	No
Trifluralin (ug/L) - TW	2018/01/08	<MDL 0.02	45.00	No	No
Vinyl Chloride (ug/L) - TW	2018/01/08	<MDL 0.17	1.00	No	No
Distribution Water					
Trihalomethane: Total (ug/L) Annual Average - DW	2018	40.5	100.00	No	No
HAA Total (ug/L) Annual Average - DW	2018	37.443	N/A	N/A	N/A

MAC = Maximum Allowable Concentration as per O. Reg. 169/03

MDL = Method Detection Limit

Additional Legislated Samples

There was no additional sampling required.

Major Maintenance Summary incurred to install, repair or replace required equipment

WO #	Description
125120	Replace main breaker and transfer switch

Appendix A

WTRS Data and Submission Confirmation

Confirmation:

Thank you for submitting your water taking data online.

Permit Number: 7640-AQJHCV
Permit Holder: THE CORPORATION OF THE CITY OF KAWARTHA LAKES.
Received on: Jan 29, 2019 1:19 PM

This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.