

Lindsay Ops Leachate		Exceeds Bylaw Value Exceeds PWQO Value									
Parameters	CKL Sewer Bylaw Limits (mg/L)	Provincial Water Quality Objectives (mg/L)	Jan. Results (mg/L)	Feb. Results (mg/L)	Mar. Results (mg/L)	April. Results (mg/L)	April. Results (mg/L) new cell	May Results (mg/L)	June Results (mg/L)	July Results (mg/L)	August Results (mg/L)
Hardness (CaCO3)	N/A	N/A	593	596	544	653	925	557	475	628	649
Alkalinity (CaCO3)	N/A	N/A	609	599	601	482	1270	528	531	693	773
Biochemical Oxygen Demand (BOD)	300	N/A	<3	19	8	7	262	4	3	5	4
TDS	N/A	N/A	991	1005	972	928	1550	796	743	1045	1144
Dissolved Organic Carbon	N/A	N/A	13.1	13.4	13.5	12.9	207	14.8	12.1	16.1	18.5
COD	N/A	N/A	73	62	63	56	644	40	38	76	78
Chloride	N/A	N/A	176	199	198	127	27.5	107	106	138	202
Ammonia (N) - Total	N/A	1.11	17.6	17.6	16.9	14.1	10	9.71	10.5	20.9	26.6
Fluoride	10	N/A	0.2	0.1	< 0.1	< 0.1	0.8	< 0.1	< 0.1	< 0.1	< 0.1
Phenolic, 4AAP	1	0.001	0.012	<0.002	< 0.002	< 0.002	0.14	< 0.002	< 0.002	< 0.002	< 0.002
Sulphate	N/A	N/A	45	48	48	139	10	38	34	33	22
Nitrite	N/A	N/A	<0.05	<0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
Nitrate	N/A	N/A	0.08	0.15	0.18	0.16	< 0.05	0.42	0.32	< 0.05	< 0.05
Kjeldahl Nitrogen - Total	50	N/A	19.7	20.5	20.8	17.6	104	10.9	10.5	25.2	30.7
Aluminum - Total	50	0.075*	0.27	0.12	0.12	0.68	0.13	0.1	0.08	0.15	0.1
Antimony - Total	5	0.02	<0.0005	<0.0001	< 0.0005	0.0006	0.0022	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Arsenic - Total	1	0.1	0.0024	0.0013	0.0008	0.0013	0.0107	0.0013	0.0009	0.0026	0.0012
Barium	N/A	N/A	0.331	0.297	0.253	0.245	0.362	0.211	0.159	0.394	0.382
Beryllium	N/A	1.1**	<0.002	<0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002
Boron	N/A	0.2	0.382	0.426	0.37	0.299	2.95	0.281	0.278	0.509	0.54
Cadmium - Total	0.7	0.0002	<0.00007	<0.000015	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070
Calcium	N/A	N/A	179	175	160	211	273	184	154	184	186
Chromium - Total	2.8	0.0099	0.017	0.011	0.012	0.161	0.013	0.004	0.001	0.013	< 0.001
Cobalt - Total	5	0.0009	0.0013	0.007	0.0013	0.0025	0.0052	0.0009	0.0011	0.0015	0.001
Copper - Total	2	0.005	0.0042	0.0011	0.0011	0.0062	0.011	0.001	0.0015	0.0021	< 0.0005
Iron	N/A	0.3	27.7	11	5.64	21	7.96	20.9	10.8	45.5	14.4
Lead - Total	1	0.005	0.0025	0.00012	0.0002	0.0016	0.0016	0.0004	0.0001	0.0005	< 0.0001
Magnesium	N/A	N/A	35.3	38.6	35.1	30.6	59.1	23.6	21.9	40.9	44.8
Manganese - Total	5	N/A	0.45	0.363	0.355	0.618	0.63	0.439	0.35	0.447	0.379
Mercury - Total	0.01	0.0002	<0.00002	<0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002
Molybdenum - Total	5	0.04	<0.0005	0.0002	< 0.0005	0.0022	0.0009	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Nickel - Total	2	0.025	0.01	0.01	0.01	0.07	0.03	< 0.01	< 0.01	0.01	< 0.01
Potassium	N/A	N/A	18.1	21.3	19.1	14.5	139	11.7	10.8	24	27.4
Phosphorus	N/A	N/A	<0.1	<0.1	< 0.1	0.1	0.3	< 0.1	< 0.1	< 0.1	< 0.1
Phosphorus - Total	10	0.01	0.05	0.03	0.03	0.1	0.29	0.05	0.02	0.05	0.03
Selenium - Total	1	0.1	<0.005	<0.0001	< 0.0005	< 0.0005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005
Silver - Total	0.4	0.0001	<0.0001	<0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Sodium	N/A	N/A	121	136	123	97.6	257	81.6	73	136	149
Strontium	N/A	10 bq/L	0.64 mg/L	0.715 mg/L	0.622	0.678	1.35	0.572	0.515	0.774	0.732
Thallium	N/A	0.0003	<0.0003	<0.00005	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Vanadium	N/A	0.006	0.0018	0.0009	0.0008	0.0025	0.0074	0.0009	0.0005	0.0018	0.0007
Zinc - Total	2	0.03	0.023	0.009	0.03	0.035	0.034	0.009	< 0.005	0.006	< 0.005
Benzene	0.01	0.1	0.0023	0.0007	0.0006	< 0.5	0.0007	< 0.0005	<0.0016	0.0006	< 0.0005
Toluene	0.02	0.0008	<0.0005	<0.0005	<0.0005	< 0.0005	0.0126	< 0.0005	< 0.0005	< 0.0005	< 0.0005
Ethylbenzene	0.06	0.008	0.0027	<0.0005	<0.0005	< 0.0005	0.0006	< 0.0005	<0.0011	< 0.0005	< 0.0005
Xylene, m, p -	N/A	N/A	0.0042	<0.001	<0.001	< 0.001	0.0012	<0.001	<0.0011	<0.001	<0.001
Xylene, o -	N/A	0.04	0.0005	<0.0005	<0.0005	<0.0005	0.0006	<0.0005	<0.0005	<0.0005	<0.0005
Xylene, m, p, o -	N/A	N/A	0.0042	<0.0011	<0.0011	<0.0011	0.0018	<0.0011	<0.0011	<0.0011	<0.0011

Parameters	Limits	Provincial Water Quality Objectives	Jan. Results	Feb. Results	Mar. Results	April. Results	Apr. Results New Cell	May. Results	June. Results	July. Results	Aug. Results
pH (at 25 °C)	6.0 - 9.5	6.5 - 8.5	7.34	7.68	7.6	7.34	7.74	7.13	7.35	6.95	7.4
Conductivity (at 25 °C)	N/A	N/A	1750 µm ho/cm	1780 µm ho/cm	1790 µmho/cm	1590 µmho/cm	3490 µmho/cm	1370 µmho/cm	1350 µmho/cm	1860 µmho/cm	2000 µmho/cm
Conductivity (calculated)	N/A	N/A	1650 µm ho/cm	1720 µm ho/cm	1664 µmho/cm	1563 µmho/cm	2403 µmho/cm	1344 µmho/cm	1267 µmho/cm	1692 µmho/cm	1928 µmho/cm
Anion Sum	N/A	N/A	18.1 meq/L	18.5 meq/L	18.6 meq/L	16.1 meq/L	26.4 meq/L	14.4 meq/L	14.3 meq/L	18.4 meq/L	21.6 meq/L
Cation Sum	N/A	N/A	20.3 meq/L	20.2 meq/L	18.2 meq/L	18.7 meq/L	34.4 meq/L	16.8 meq/L	14.3 meq/L	23 meq/L	22.8 meq/L
% Difference	N/A	N/A	5.77%	4.51%	1.09%	7.29%	13.10%	7.78%	0.18%	11.00%	2.68%
Ion Ratio (AS/CS)	N/A	N/A	0.891	0.914	1.02	0.864	0.769	0.856	1	0.801	0.948
Sodium Adsorption Ratio	N/A	N/A	2.16	2.42	2.29	1.66	3.68	1.5	1.46	2.36	2.54
TDS (calc.) / EC (actual)	N/A	N/A	0.567	0.565	0.542	0.585	0.444	0.58	0.551	0.561	0.572
Langelier Index (at 25°C)	N/A	N/A	0.875	1.19	1.08	0.845	1.77	0.635	0.78	0.543	1.05