

Lindsay Ops Leachate		Exceeds Bylaw Value Exceeds PWQO Value											
Parameters	CKL Sewer Bylaw Limits (mg/L)	Provincial Water Quality Objectives (mg/L)	Jan. Results (mg/L)	Feb. Results (mg/L)	Mar. Results (mg/L)	April. Results (mg/L)	April. Results (mg/L) new cell	May Results (mg/L)	June Results (mg/L)	July Results (mg/L)	August Results (mg/L)	September Results (mg/L)	October. Results (mg/L) new cell
Hardness (CaCO3)	N/A	N/A	593	596	544	653	925	557	475	628	649	664	1090
Alkalinity (CaCO3)	N/A	N/A	609	599	601	482	1270	528	531	693	773	759	2380
Biochemical Oxygen Demand (BOD)	300	N/A	<3	19	8	7	262	4	3	5	4	n/a	62
TDS	N/A	N/A	991	1005	972	928	1550	796	743	1045	1144	1258	4318
Dissolved Organic Carbon	N/A	N/A	13.1	13.4	13.5	12.9	207	14.8	12.1	16.1	18.5	1.3	130
COD	N/A	N/A	73	62	63	56	644	40	38	76	78	112	692
Chloride	N/A	N/A	176	199	198	127	27.5	107	106	138	202	307	887
Ammonia (N) - Total	N/A	1.11	17.6	17.6	16.9	14.1	10	9.71	10.5	20.9	26.6	28.4	350
Fluoride	10	N/A	0.2	0.1	< 0.1	< 0.1	0.8	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 3
Phenolic, 4AAP	1	0.001	0.012	<0.002	< 0.002	< 0.002	0.14	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002
Sulphate	N/A	N/A	45	42	48	139	10	38	34	33	22	15	121
Nitrite	N/A	N/A	<0.05	<0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 1
Nitrate	N/A	N/A	0.08	0.15	0.18	0.16	< 0.05	0.42	0.32	< 0.05	< 0.05	< 0.05	< 1
Kjeldahl Nitrogen - Total	50	N/A	19.7	20.5	20.8	17.6	104	10.9	10.5	25.2	30.7	35.8	364
Aluminum - Total	50	0.075*	0.27	0.12	0.12	0.68	0.13	0.1	0.08	0.15	0.1	0.07	0.62
Antimony - Total	5	0.02	<0.0005	<0.0001	< 0.0005	0.0006	0.0022	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	0.002
Arsenic - Total	1	0.1	0.0024	0.0013	0.0008	0.0013	0.0107	0.0013	0.0009	0.0026	0.0012	0.0014	0.0189
Barium	N/A	N/A	0.331	0.297	0.253	0.245	0.362	0.211	0.159	0.394	0.382	0.471	0.82
Beryllium	N/A	1.1**	<0.002	<0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002	< 0.002
Boron	N/A	0.2	0.382	0.426	0.37	0.299	2.95	0.281	0.278	0.509	0.54	0.632	9.68
Cadmium - Total	0.7	0.0002	<0.00007	<0.000015	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070	< 0.000070
Calcium	N/A	N/A	179	175	160	211	273	184	154	184	186	180	267
Chromium - Total	2.8	0.0099	0.017	0.011	0.012	0.161	0.013	0.004	0.001	0.013	< 0.001	0.004	0.037
Cobalt - Total	5	0.0009	0.0013	0.007	0.0013	0.0025	0.0052	0.0009	0.0011	0.0015	0.0015	0.0011	0.0159
Copper - Total	2	0.005	0.0042	0.0011	0.0011	0.0062	0.011	0.001	0.0015	0.0021	< 0.0005	< 0.0005	0.008
Iron	N/A	0.3	27.7	11	5.64	21	7.96	20.9	10.8	45.5	14.4	15.1	59.6
Lead - Total	1	0.005	0.0025	0.00012	0.0002	0.0016	0.0016	0.0004	0.0001	0.0005	< 0.0001	< 0.0001	0.0013
Magnesium	N/A	N/A	35.3	38.6	35.1	30.6	59.1	23.6	21.9	40.9	44.8	52	104
Manganese - Total	5	N/A	0.45	0.363	0.355	0.618	0.63	0.439	0.35	0.447	0.379	0.299	0.837
Mercury - Total	0.01	0.0002	<0.00002	<0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002	< 0.00002
Molybdenum - Total	5	0.04	<0.0005	0.0002	< 0.0005	0.0022	0.0009	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	0.0021
Nickel - Total	2	0.025	0.01	0.01	0.01	0.07	0.03	< 0.01	< 0.01	0.01	< 0.01	0.01	0.09
Potassium	N/A	N/A	18.1	21.3	19.1	14.5	139	11.7	10.8	24	27.4	28.9	260
Phosphorus	N/A	N/A	<0.1	<0.1	< 0.1	0.1	0.3	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	3.3
Phosphorus - Total	10	0.01	0.05	0.03	0.03	0.1	0.29	0.05	0.02	0.05	0.03	0.03	3.21
Selenium - Total	1	0.1	<0.005	<0.0001	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	< 0.005	0.012
Silver - Total	0.4	0.0001	<0.0001	<0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001	< 0.0001
Sodium	N/A	N/A	121	136	123	97.6	257	81.6	73	136	149	168	740
Strontium	N/A	10 bq/L	0.64 mg/L	0.715 mg/L	0.622	0.678	1.35	0.572	0.515	0.774	0.732	0.794	2.73
Thallium	N/A	0.0003	<0.0003	<0.00005	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003	< 0.0003
Vanadium	N/A	0.006	0.0018	0.0009	0.0008	0.0025	0.0074	0.0009	0.0005	0.0018	0.0007	0.001	0.0239
Zinc - Total	2	0.03	0.023	0.009	0.03	0.035	0.034	0.009	< 0.005	0.006	< 0.005	0.005	0.185
Benzene	0.01	0.1	0.0023	0.0007	0.0006	< 0.5	0.0007	< 0.0005	<0.0016	0.0006	< 0.0005	0.0018	
Toluene	0.02	0.0008	<0.0005	<0.0005	<0.0005	< 0.0005	0.0126	< 0.0005	< 0.0005	< 0.0005	< 0.0005	< 0.0005	
Ethylbenzene	0.06	0.008	0.0027	<0.0005	<0.0005	< 0.0005	0.0006	< 0.0005	<0.0011	< 0.0005	< 0.0005	< 0.0005	
Xylene, m, p -	N/A	N/A	0.0042	<0.001	<0.001	< 0.001	0.0012	<0.001	<0.0011	<0.001	<0.001	<0.001	
Xylene, o -	N/A	0.04	0.0005	<0.0005	<0.0005	<0.0005	0.0006	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	
Xylene, m, p, o -	N/A	N/A	0.0042	<0.0011	<0.0011	<0.0011	0.0018	<0.0011	<0.0011	<0.0011	<0.0011	<0.0011	

Parameters	Limits	Provincial Water Quality Objectives	Jan. Results	Feb. Results	Mar. Results	April. Results	Apr. Results New Cell	May. Results	June. Results	July. Results	Aug. Results	Sept. Results	Oct. Results New Cell
pH (at 25 °C)	6.0 - 9.5	6.5 - 8.5	7.34	7.68	7.6	7.34	7.74	7.13	7.35	6.95	7.4	7.28	7.87
Conductivity (at 25 °C)	N/A	N/A	1750 µm ho/cm	1780 µm ho/cm	1790 µmho/cm	1590 µmho/cm	3490 µmho/cm	1370 µmho/cm	1350 µmho/cm	1860 µmho/cm	2000 µmho/cm	2160 µmho/cm	7050 µmho/cm
Conductivity (calculated)	N/A	N/A	1650 µm ho/cm	1720 µm ho/cm	1664 µmho/cm	1563 µmho/cm	2403 µmho/cm	1344 µmho/cm	1267 µmho/cm	1692 µmho/cm	1928 µmho/cm	2141 µmho/cm	6453 µmho/cm
Anion Sum	N/A	N/A	18.1 meq/L	18.5 meq/L	18.6 meq/L	16.1 meq/L	26.4 meq/L	14.4 meq/L	14.3 meq/L	18.4 meq/L	21.6 meq/L	24.1 meq/L	75.1 meq/L
Cation Sum	N/A	N/A	20.3 meq/L	20.2 meq/L	18.2 meq/L	18.7 meq/L	34.4 meq/L	16.8 meq/L	14.3 meq/L	23 meq/L	22.8 meq/L	24.1 meq/L	88.5 meq/L
% Difference	N/A	N/A	5.77%	4.51%	1.09%	7.29%	13.10%	7.78%	0.18%	11.00%	2.68%	0.02%	8.17%
Ion Ratio (AS/CS)	N/A	N/A	0.891	0.914	1.02	0.864	0.769	0.856	1	0.801	0.948	1	0.849
Sodium Adsorption Ratio	N/A	N/A	2.16	2.42	2.29	1.66	3.68	1.5	1.46	2.36	2.54	2.84	9.73
TDS (calc.) / EC (actual)	N/A	N/A	0.567	0.565	0.542	0.585	0.444	0.58	0.551	0.561	0.572	0.582	0.612
Langelier Index (at 25°C)	N/A	N/A	0.875	1.19	1.08	0.845	1.77	0.635	0.78	0.543	1.05	0.903	2.12