



Appendix # B
to
Report # WW2017-007

MEMORANDUM

Date: June 23, 2016
To: Shelley Durham. City of Kawartha Lakes
From: Mazahir Alidina, Maika Pellegrino. WSP
Project No.: 161-15613
Location: Lindsay Water Treatment Plant
Subject: Coagulant Testing for the Lindsay Water Treatment Plant

1. Introduction

The Lindsay Water Treatment Plant is a conventional (full) treatment plant with an ACTIFLO® System that consists of two (2) ballasted flocculation/clarification units, two (2) sedimentation tanks and five (5) multi-media filters to handle the plant rated flow of 22,730 m³/d.

The source water for the plant is the Scugog River where water temperatures range between 0 and 30°C. Currently polyaluminum chloride (PAC) is used when raw water is below 12°C and Alum is used above 12°C. Operational and raw water parameters provided by the Plant staff are summarized in Table 1 Plant Operational and Raw Water Parameters.

Table 1 Plant Operational and Raw Water Parameters

Parameter	Value		Comments
Flow Rate	80-185	L/s	
Surface Area Clarifier	21	m ²	From Drawing S-103 (4595 x 4595) mm ²
Surface loading rate (rise rate)	31.7	m/hr	(185 L/s)/21 m ²
Hydraulic Contact Time			
Coagulation tank	In-line		Flash Mixers are used
Injection Tank	2	min	
Maturation Tank	8	min	
Settling Tank	15	min	
Operational Parameters			
Polymer in Use	LT22S		Cationic in nature
Polymer Dose	0.03	mg/L	
SternPAC (Coagulant) Dose	85	mg/L	
CO ₂ (pH suppression) Dose			
Microsand Dose	20	mL/1000 mL	
Alum (Coagulant) Dose	120 - 180	Mg/L	
Actiflo® Influent pH range	6.8 - 7.0		
Raw Water Characteristics			
Raw water pH range	7.5 - 8.0		
Raw water Turbidity	1.5 - 2.0	NTU	
Raw water Alkalinity	160 - 190	mg/L	
Raw water Hardness	170 - 300	mg/L	
Raw water Colour	20 - 30	TCU	
Raw water UVT	50-Hi 60s		

2. Objectives

WSP was retained by The City of Kawartha Lakes to explore optimum coagulants for the Lindsay Water Treatment Plant during Raw Water cold temperature conditions.

The aim of the jar test was to simulate a full scale ACTIVFLO® process in order to determine alternative coagulants for cold water use. The jar test simulates similar contact times in each basin of the ACTIVFLO® process and by adding the chemicals and micro-sand along the same sequence used in the full-scale unit.

The coagulants to be tested were to be compatible with the following:

- Source water characteristics.
- Other treatment chemicals used at the Plant
- Water characteristics in clearwells
- Water characteristics in the distribution system

Suppliers who were contacted to provide coagulant samples were informed that the coagulants to be provided should meet the above criteria.

3. Methodology

3.1 Coagulants to be tested

WSP contacted several suppliers for samples of coagulants to use in the jar testing. A total of ten (10) coagulant samples were received from four (4) suppliers as outlined in Appendix 1. Suppliers were asked to provide data for optimum pH range, basicity, typical dose, concentration of Al_2O_3 and confirmation that the product met ANSI/NSF standard 60 and all Ontario regulations. Input was obtained from the City during the kick-off meeting regarding any previous experience with any of the procured coagulants as well as any operational issues perceived with use of any of the coagulants. The following is a summary of factors considered in shortlisting the coagulants selected for testing:

- The City currently uses SternPAC and this was to be one of the coagulants to be tested.
- The RFQ indicated that DelPAC 2020 would be one of the tested coagulants
- PAX-18 was used previously by the plant and had led to red water issues, and was hence excluded from further consideration.
- WC 620 Polydadmac, WC 530 Polyamine & WC 585 Polyamine were polymeric coagulants that required much lower dosage. Current plant equipment did not allow dosing at such low rates and these coagulants were hence excluded from further consideration.
- Insufficient information was provided by the supplier of Magnasol 4000G to qualify it.
- PAX-XL50 & PAX-XL-54 were similar in composition and hence only one of these was selected (PAX-XL50)
- DeltaFloc 1118 & DeltaFloc 1123 were similar in composition and hence only one of these was selected (DeltaFloc 1118)

The coagulant dose tested was calculated based on the actual average dose of SternPAC currently used at the plant. The specific doses of the coagulants varied in order to have the Al_2O_3 content proportional and allow a direct comparison based on Al_2O_3 dose.

3.2 Jar Testing Procedure

The jar testing was carried out in accordance with the industry standard "Actiflo® Jar Testing Procedure" (Appendix 2). Since insufficient washed microsand was available for use, the jar testing was carried out over the course of two days: April 28, 2016 and April 29, 2016. The test was performed using a Phipps & Bird PB-700™ Jar Test Apparatus (supplied by WSP, Figure 1) at the Lindsay Water Treatment Plant. The PB-700™ is a six-paddle model with regulated variable paddle speed control between a range of 1 – 300 rpm with a digital readout of the exact speed. The unit comes with six, square acrylic 2L jar testing jars and has a fluorescent lamp floc illuminator built into its base.

Figure 1 Jar Testing Apparatus used for testing the coagulants



The microsand to be used for the testing was washed thoroughly (by plant staff) until the supernatant was clear, in order to eliminate turbidity caused by micro-grains or any suspended particles that could be introduced into the water tested in the jar test. The micro-sand was laid out to dry overnight and stored in a plastic jar.

Raw water was collected from the raw water sampling tap located after the screens to the plant (Figure 2). Four (4) 18L pails were filled with water on the morning of April 28, 2016. The raw water temperature, pH and turbidity as read from the on-line meters during collection were as follows:

- Temperature: 12.1°C
- pH: 8.03
- Turbidity: 0.83

Polymer solution utilized in the jar tests was obtained (by plant staff) from the bulk solutions prepared for the full-scale unit in the plant. The concentration of the bulk polymer was calculated to be approximately: 0.003 kg/L (3000 mg/L). The polymer dose in the Actiflo® was calculated for April 27, 2016 to be 0.54 mg/L.

Figure 2 Raw Water Sampling Location



3.3 pH Control

It was initially anticipated that the pH of the raw water would need to be adjusted to an optimum theoretical pH (as provided by the manufacturer). It was envisioned that the minimum and maximum doses would be adjusted for pH by recording the volume of acid or caustic required to bring the pH of solution into the optimum pH range by conducting a small scale titration. Amounts to be added to intermediate coagulant doses would then be interpolated.

Upon review of the technical product information for each of the products, it was noted that the optimum pH ranges for all the products lied between the range of 6 – 8. Since the raw water pH range supplied by the Plant was 7.5 – 8, it was noted that all the tested coagulants operate optimally at the raw water pH and pH adjustment was hence not required.

3.4 Temperature Control

Ambient temperature in the lab was around 20°C. In order to maintain the tested water at a temperature below 12°C, water was stored in the refrigerator/freezer before testing (Figure 3). Ice packs were placed within the jars during the course of the test to prevent temperature rise above 12°C while the test was ongoing.

Due to space constraints only one pail could be stored in the refrigerator in the laboratory. The remaining three (3) pails of raw water were stored outside the water treatment plant. Ambient temperatures for Lindsay on the two days of the jar test are as follows:

- April 28, 2016: High: 10°C, Low: -4°C
- April 29, 2016: High: 13°C, Low: -2°C

Since the target was to carry out the jar test at temperatures below 12°C, storing the pails outside the water was deemed acceptable.

Figure 3 Raw Water Storage During Jar Testing



3.5 Jar Testing

Readings for the raw water pH, temperature, turbidity and UV absorbance were recorded. 2L of raw water was transferred into each of the square jars using a 1L measuring cylinder. The paddles were set a few centimetres from the bottom of the jars.

The respective coagulant to be tested was diluted in a ratio of 1:100 using a volumetric flask and transferred to a plastic bottle. The neat polymer was also diluted in a ratio of 1:100 using a volumetric flask and transferred to a plastic bottle. Each of these dilutions were prepared right before beginning the jar test. The required amount of coagulant to be added to jars 1 – 6 was measured using a micropipette and transferred to a glass vial. The amount of polymer to be added to each jar was divided equally into two glass vials. The amount of microsand to be transferred into each jar was placed into a plastic weigh boat in preparation for the beginning of the test.

The jar test apparatus was switched on and set to 150 ± 5 rpm. The coagulant was added to each of the jars and the timing started. At 2:40 mins the microsand followed by 50% of the polymer was added to each of the jars. At 5:20 mins, the remaining 50% of polymer was added to each of the jars. After 6 mins of maturation time, the stirring was stopped at 13:20 mins and the water was allowed to settle for 4 mins. At 17:20 mins, the supernatant from each of the jars were extracted using the tap for laboratory analysis and bottling for external analysis. Samples were kept cold before delivery to the lab. Images taken during jar testing of one of the coagulants are presented in Figure 4 below.

Figure 4 Time Lapse of Jar Test for one coagulant



The water quality parameters tested are summarized in Table 2 below:

Table 2 Water Quality Parameters Tested

WSP (In Lab)	Commercial Lab
pH	Alkalinity
Temperature	Apparent Colour
Turbidity	True Colour
UVA	Residual Aluminum
	Total Hardness
	Calcium Hardness
	DOC
	TOC

4. Results

4.1 Raw Water

The raw water quality results are summarized in Table 3 below.

Table 3 Raw Water Quality Parameters


Parameter	Value	Unit
pH	8.09	
Temperature	10.28	(°C)
Turbidity	1.38	(NTU)
UVA	0.22	
DOC	7.4	mg/L
TOC	7.8	mg/L
Alkalinity	177	(mg CaCO ₃ /L)
True colour	20	
Apparent Colour	38	
Calcium Hardness	73.6	mg/L
Total Hardness	220	mg/L
Residual Aluminum	7.4	ug/L

4.2 Jar Test Results

Lab results from SGS Canada Inc. and data sheets summarizing the jar test results for each of the coagulants are included in Appendix 3. Graphs illustrating performance of each of the coagulants with regards to the different water quality parameters are included in Appendix 4.

The water temperature was measured in samples from each of the jars following completion of a test. It was noted that the final water temperature was always below 12.5°C as noted in Figure 5. This indicates that the objective of conducting the test at cold temperature was achieved. However since the jar test was carried out at the upper end of the cold water range, the results may not be the same at extreme cold water temperatures (2 - 4°C).

Figure 5 Water Temperatures following jar tests



With increasing dose of SternPAC, DelPAC-2020 and PAX-XL50, the pH of the water was noted to decrease slightly (Appendix 4). The pH did not appear to change significantly with an increase in dosage of DeltaFloc-1118. It was unclear why the pH increased with increasing dose of PAX-XL8.


There were no identifiable trends in change of alkalinity, calcium hardness and total hardness between the coagulants tested (Appendix 4).

Apparent colour and true colour were both noted to decrease with increasing dose for all coagulants tested (Appendix 4). SternPAC and PAX-XL50 appeared to perform slightly better with regards to True colour removal, while DeltaFloc-1118 and SternPAC seemed to perform better with regards to Apparent colour removal.

UV absorbance, dissolved organic carbon and total organic carbon all decreased with increased coagulant dose (Appendix 4). Overall, all the coagulants performed very similar in regards to removal of these parameters. There appeared to be slightly better performance of SternPAC and PAX-XL50 regarding removal of total and dissolved organic carbon, and SternPAC and DeltaFloc-1118 regarding UVA. The differences noted between the coagulants however do not seem to be significant.

Turbidity was also noted to decrease with increasing coagulant dose as illustrated in Figure 6. PAX-XL50 exhibited significantly less turbidity removal than the other coagulants. PAX-XL8 and DeltaFloc-1118 exhibited slightly better turbidity removal than DelPAC-2020 and SternPAC.

Figure 6 Jar Test results for Turbidity



The aluminum residual was noted to be lowest with use of DeltaFloc-1118 as a coagulant (Appendix 4). The remaining coagulants resulted in similar residual aluminum generation.

5. Chemical Costs

The City of Kawartha Lakes issued a Request for Information (2016-46-RFI) seeking input from the suppliers of the five chemicals on estimated costs based on the 2015 consumption quantity of polyaluminum chloride of 630,000 kg. A summary of the responses received from the suppliers is presented in Table 4 below.

Table 4 Summary of Chemical Costs

Chemical	Supplier	Proposed Consumption (kg)	Cost
SternPAC	Kemira	630,000	\$277,000
PAX-XL8	Kemira	620,000	\$297,000
PAX-XL50	Kemira	510,000	\$250,000
DeIPAC 2020	Control Chem	-	\$300,000
DeltaFloc-1118	Control Chem	-	\$300,000

6. Conclusion

Based on the results, the following conclusions are drawn:

- PAX-XL50 exhibited significantly lower turbidity removal compared to the other coagulants. Since turbidity is a critical parameter for water quality, PAX-XL50 is not recommended for further testing.
- PAX-XL8 resulted in an increase in pH with increasing dose. An increase in pH could result in increased scaling and PAX-XL8 is hence not recommended for further testing.
- Whereas the performance of DeltaFloc-1118 and DeIPAC 2020 were noted to be similar for several parameters, DeltaFloc-1118 yielded better results compared to DeIPAC 2020 for turbidity, apparent colour and aluminum. DeIPAC 2020 is hence not recommended for further consideration.

Other than SternPAC which is currently used at the plant, the only other coagulant tested which may be considered further is DeltaFloc-1118. Under the conditions investigated in the current jar test, the results suggest that there is no obvious benefit in switching from SternPAC to DeltaFloc-1118.

It should be noted however that the jar test was carried out at a temperature between 11 and 12.5°C, so the results obtained are valid at this temperature. Since the same results may not hold true at extremely low temperatures, it is recommended that SternPAC and DeltaFloc-1118 be tested further at a temperature of 2 - 4°C, to investigate if DeltaFloc-1118 exhibits superior performance compared to SternPAC.

In the absence of any additional jar tests, since the plant is currently using SternPAC (and the staff are knowledgeable with its handling and use), our recommendation is that the Lindsay Water Treatment plant continue using SternPAC as the cold water coagulant.

Based on the cost estimates received from the chemical suppliers, DeltaFloc-1118 is more expensive than SternPAC. A switch in coagulant to DeltaFloc-1118 would hence imply a higher cost to the City. On the other hand, DeltaFloc-1118 consumed less alkalinity and resulted in a more stable pH, which could result in a lower consumption of carbon dioxide. The current results cannot hence determine the overall cost implication of switching coagulants. If the results for DeltaFloc-1118 are significantly better than SternPAC when re-tested at the extreme cold temperatures however, an increase in cost associated with a switch to DeltaFloc-1118 may be justified.

It is recommended that when SternPAC and DeltaFloc-1118 are re-tested at cold temperatures, the following additional parameters are included in the analysis to assess for corrosivity: chloride, sulphate and total dissolved solids (TDS). This will allow the calculation of the following corrosion indexes: Larsons-Skold Index, Langelier Index, Chloride to Sulphate Mass Ratio (CSMR) and their comparison with the full scale results. Additionally, before any change in coagulant is implemented, we recommend that an evaluation be carried out to highlight the effect of the change in coagulant on downstream processes.

Considering the current average dose of 80-85 mg/L SternPAC used at the plant (corresponding to an equivalent dose of 10 – 10.7 mg/L Al_2O_3), the dosage appears to be optimal. However, whether SternPAC continues to be used as the cold water coagulant or DeltaFloc-1118 is recommended to be adopted as an alternate coagulant, we recommend that an optimization jar test study be conducted to review the microsand dose, determine the optimum polymer dose and optimum pH since the current dosing ranges for these inputs do not seem to be optimized.

Appendix 1

Coagulant Options

Lindsay Water Treatment Plant Jar Testing for Alternative Coagulants



To be Tested	Name of Chemical	Constituent	Conc. Of Chemical	Supplier	Optimum pH Range	Basicity	Typical Dose	Conc. Of Al ₂ O ₃	ANSI/NSE Standard 60 certified and meets all Ontario Regulations (Y/N)	Comments
Y	DelPAC 2020	Aluminum Chloride Hydroxide Sulfate Solution	-	ControlChem Canada Ltd.	6 - 8	70%	90% SternPAC - depending on raw water	10.50%	Y	RFQ Indicated DelPAC 2020 to be tested
Y	Delta-Floc 1118	Aluminum Chloride Hydroxide, Aluminum chlorohydrate	-	ControlChem Canada Ltd.	6 - 8	83%	40% SternPAC - depending on raw water	22%	Y	Selected for Testing
N	Delta-Floc 1123	Aluminum Chloride Hydroxide Sulfate Solution, Blend	-	ControlChem Canada Ltd.	6 - 8	78%	40% SternPAC - depending on raw water	16.70%	Y	Similar to Delta-Floc 1118 which was selected
Y	PAX-XL8	Aluminum Chloride Hydroxide Sulfate	30-35%	Kemira	5.5 - 8	65 - 70	-	10.5	Y	Selected for Testing
Y	PAX-XL50	Aluminum Chloride Hydroxide Sulfate	33-40%	Kemira	5.5 - 8	60	-	13	Y	Selected for Testing
N	PAX-XL54	Aluminum Chloride Hydroxide Sulfate	40-43%	Kemira	5.5 - 8	75	-	19	Y	Similar to PAX-XL50 which was selected
N	PAX-18	Polyaluminum Chloride	30-40%	Kemira	5.5 - 8	42	-	17	Y	Previous Red water issues when used at plant
Y	SternPAC	Polyaluminum Chloride	-	Kemira (From Plant Supply)	5.5 - 8	50	-	10.4	Y	SternPAC currently used & to be tested
N	WC 620 Polyadmac	Diallyldimethylammonium chloride homopolymer	-	Wescor	6 - 9	-	0.7 - 5 ppm	-	Y	Plant does not have correct sized pumps to dose small qtys
N	WC 530 - Polyamine	Epichlorohydrin amine condensates polymer solution	-	Wescor	6 - 9	-	0.5 - 3 ppm	-	Y	Plant does not have correct sized pumps to dose small qtys
N	WC 585 - polyamine	Epichlorohydrin amine condensates polymer solution	-	Wescor	6 - 9	-	0.5 - 3 ppm	-	Y	Plant does not have correct sized pumps to dose small qtys
N	Magnasol 4000 G	Aluminum Salt	-	Canada Colors & Chemicals	-	-	-	-	-	Insufficient Information provided to make a decision

Appendix 2

Actiflo® Laboratory Jar Test Procedure

N° method		Revision date
Reference	ACTIFLO LABORATORY JAR TEST PROCEDURE	2015-07-02

In order to simulate the ACTIFLO® process, a modified Jar test procedure was developed. The procedure can be used to find the adequate coagulant and polymer dosages to obtain a clarified water with a low turbidity. Furthermore, the modified jar test procedure has the capability of evaluating or predicting process performances of an existing ACTIFLO® unit and bring accurate diagnosis on operation troubleshooting.

The simulation method reproduces results that are very close to full-scale unit results. Such reproduction is achieved by simulating the same contact times in each basin and adding the chemicals and micro-sand along the same sequence used in the full-scale unit.

At the designed flow rate, the surface loading rate in a typical ACTIFLO® unit is 40 m/hr. This loading rate corresponds to hydraulic contact times of respectively 2, 2, 6 and 3 minutes in the coagulation, injection, maturation and settling tanks.

A. Material

- Jar test apparatus
- Raw water
- Circulating open bath for temperature control (optional).
- Square glass beakers or round beakers (1 Liter)
- Washed micro-sand
- Polymer
- Coagulant
- Acid or alkali, to adjust the pH (optional)
- Measurement apparatus (turbidimeter, spectrophotometer, etc.)
- Stopwatch

B. Chemicals Preparation

- Prepare the microsand dedicated to Jar-Test.

This microsand has to be already washed with distilled or tap water to remove sand dust causing turbidity. To prepare the microsand, follow the procedure below:

Rinse the new or used micro-sand thoroughly 10 times or until the supernatant is clear, in order to eliminate turbidity caused by micro-grains or any suspended particles that could be introduced into the water tested in the jar test. Dry in a 104°C oven overnight. Place in a identified microsand plastic jar.

- Prepare a polymer solution in the laboratory or use the polymer solution prepared for the full-scale unit in the WTP.

From dry polymer powder:

Prepare a 0.1% solution. Weight 0.1 g of dry polymer and slowly add in a 0.25L beaker filled with 0.1 L of distilled water. The beaker has to be mixed to avoid eye fish in the solution. Add the dry polymer weight into the vortex formed by mixing. Mix the solution for approximately 1 hour until complete dissolution of the polymer. 0.1 mL of this



ACTIFLO® JARTEST PROCEDURE

solution corresponds to 1 mg/L. 1mL of this prepared solution added in a 1000 L beaker corresponds to 1 mg/L of polymer dosage.

For better accuracy, it is recommended to dilute this solution prior injecting in the jar test beakers if the dosages to apply are less than 1 mg/L. Measure 10 mL of prepared polymer solution and complete at 100 mL with distilled water. 1mL of this diluted solution corresponds to 0.1 mg/L of polymer dosage.

Caution: the 0.1% solution is efficient for 1 day. The diluted polymer solution is efficient for approximately 1 hour. Prepare new diluted solution after 1hour use.

From polymer preparation tank:

For polymer at 1 g/L (0.1%), sample polymer from polymer metering pump or polymer preparation tank at the WTP.

Dilution to obtain a 0.1 g/L solution:

Concentration in the tank (g/L)	Dilution factor	Volume to add in the 100 ml cylinder (mL)
1.5	15	6.7
2.0	20	5
2.5	25	4
3.0	30	3.3

Fill the cylinder to 100 mL mark with distilled water and stir.

Caution: The polymer solution as prepared is efficient for approximately 1 hour. Prepare new dilution after 1 hour use.

Caution: Polymer solution is viscous and very slippery if dropped on the floor.

Polymer volume to inject for 1L water during the jar test is as follow:

Plant polymer diluted at 1.0 g/L (0.01%), for 1 L jar test.			
Dosage required (mg/L)	Total Volume (mL)	Polymer volume to add (mL)	
		1st injection	2nd injection
0.5	0.5	0.25	0.25
0.75	0.75	0.375	0.375
1.25	1.25	0.625	0.625
1.5	1.5	0.75	0.75
2.0	2.0	1.0	1.0
3.0	3.0	1.5	1.5

- Coagulant

Use coagulant from manufacturer bottle or sample coagulant metering pump skid in the WTP.

Caution: Dilution is not necessary if a micropipette is available (0-200 µL).

Caution: Change your tip or pipette between each jar tests series (risk of coagulant precipitation in the tip)

Caution: Never dilute PAC or PASS coagulants (risk of precipitation)

If no micropipette available, the following dilution

For organic coagulant, a dilution factor of 10 is recommended. Dilute 10 mL of neat coagulant into a 100 mL graduated cylinder using distilled water for dilution.

For inorganic coagulant, a dilution factor of 10 or 50 can be used.

The coagulant dosage may be expressed in different ways:

Volumetric dosage (µL /L)

mg/L of commercial product as sold = volume (µL /L) x specific gravity

mg/L of active ingredient = volume (µL /L) x specific gravity x concentration (%)

mg Fe or Al/L (recommended but not common)= volume (µL /L) x specific gravity x % Fe or Al

mg/L solid product (not recommended but very common in WTP) = volume (µL /L) x specific gravity x dry solids content (%)

To validate the calculation, please refer to the chemical technical specifications sheet.

C. Test Method

The optimal results will be achieved using the following jar test steps:

Step 1: Perform a series of jar test at fix coagulant dosage, fix polymer dosage and different pH (pH curve).

Step 2: Perform a series of jar tests at fix pH and using different coagulant dosages and fix polymer dosage (coagulant curve). You may review the pH curve at the optimal coagulant dosage found (optional).

Step 3: Perform a series of jar tests at different polymer dosage, with the optimal pH and coagulant found in the previous steps (polymer curve).

The Actiflo jar test method may be executed as follow:

Times given in the test method below are specific to a rise rate of 40 m/h.

Set the circulating bath to desired temperature (optional).

Measure the raw water parameters (pH, alkalinity, true and apparent colour, turbidity, UV absorbance, temperature). Measure parameters according to protocol and test objectives.

Fill up the 1-Liter beakers with raw water.

Set the beakers on the bench.

Make sure raw water temperature corresponds with the desired temperature (optional).

Set the paddle between 0.5 and 1.0 cm from the bottom of the beaker.

Start mixing and adjust speed at 150 RPM.

Add the acid or the alkali to adjust the pH (optional).

Add the coagulant (see timeline below).

Start the stopwatch or the sequential run in the Jar tester.

Two minutes after adding coagulant, add micro-sand (8-10 g/L of water) and 50% of the polymer dosage.

Two minutes (cationic polymer) or 5 minutes (anionic polymer) after adding the micro-sand and first polymer dosage, inject the remaining 50 % polymer dosage.

After a supplementary maturation contact time of 6 minutes (cationic polymer) or 3 minutes (anionic polymer), stop stirring and allow the water to settle for the next 3 minutes.

Use a 25-100 mL syringe, pipet or a pipe under vacuum to collect the supernatant (NOT collect the surface, due to microsand and microflocs that may float). Sample the clarified water.


Measure the clarified water parameters important for the test objectives.

Note all the results and parameters on the ACTIFLO® jar test log sheet.

TIMELINE FOR SELECTED RISE RATES

20 m/h: twice the time for 40 m/h


40 m/h






ACTIFLO® JARTEST PROCEDURE

50 m/h



60 m/h



80 m/h: half the time for 40 m/h

C. Waste

Do not throw the sand in the wash bin. Collect sand and discard as stated by site regulation.

Date de révision : 2015-07-02

Révisé par : CDM

Approuvé par : SV

Appendix 3

Result Data Sheets



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

City of Kawartha Lakes (Lindsay DWS)
Attn : Rob Gamache

12 Peel Street
Lindsay, ON
K9V 3L8, Canada

Phone: 705-324-9411 Ext 1141
Fax: 705-328-3054

Works #: 220000175

10-May-2016

Date Rec. : 29 April 2016
LR Report: CA14580-APR16

Copy: #1

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Alkalinity mg/L as CaCO ₃	Colour TCU	Apparent Colour CU	Hardness mg/L as CaCO ₃	Aluminum ug/L	Calcium mg/L	Dissolved Organic Carbon mg/L	Total Organic Carbon mg/L
1: Analysis Start Date		---	29-Apr-16	02-May-16	02-May-16	03-May-16	03-May-16	03-May-16	29-Apr-16	29-Apr-16
2: Analysis Start Time		---	21:44	15:12	13:53	09:11	09:11	07:48	22:19	22:19
3: Analysis Approval Date		---	06-May-16	03-May-16	02-May-16	04-May-16	04-May-16	04-May-16	10-May-16	10-May-16
4: Analysis Approval Time		---	12:32	11:29	15:25	10:18	10:18	10:19	13:05	13:05
7: AO/OG		---	30-500	5		80-100	100	---	5	---
8: MDL		---	2	3		0.05	0.3	0.01	0.2	0.2
9: NR DP-2020-T1	29-Apr-16	11.0	181	10	20	211	289	70.2	6.2	6.0
10: NR DP-2020-T2	29-Apr-16	11.0	180	9	18	215	257	71.3	5.0	5.6
11: NR DP-2020-T3	29-Apr-16	11.0	178	8	16	209	368	68.8	4.8	5.4
12: NR DP-2020-T4	29-Apr-16	11.0	178	8	16	213	267	70.6	5.4	5.8
13: NR DP-2020-T5	29-Apr-16	11.0	172	10	13	206	304	67.7	5.1	5.0
14: NR DP-2020-T6	29-Apr-16	11.0	172	7	12	218	231	72.6	5.1	5.1
15: NR PAX-XL50-T1	28-Apr-16	11.0	177	11	20	211	313	69.3	6.3	6.0
16: NR PAX-XL50-T2	28-Apr-16	11.0	185	9	18	213	296	70.9	5.1	6.0
17: NR PAX-XL50-T3	28-Apr-16	11.0	175	8	17	209	394	68.7	5.0	5.7
18: NR PAX-XL50-T4	28-Apr-16	11.0	172	7	17	217	286	72.2	4.9	5.5
19: NR PAX-XL50-T5	28-Apr-16	11.0	177	7	13	217	307	71.2	4.8	4.8
20: NR PAX-XL50-T6	28-Apr-16	11.0	180	6	12	213	250	70.5	4.1	4.4
21: NR SPAC-T1	29-Apr-16	11.0	177	11	21	214	301	71.3	5.7	5.9



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 220000175

LR Report : CA14580-APR16

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Alkalinity mg/L as CaCO ₃	Colour TCU	Apparent Colour CU	Hardness mg/L as CaCO ₃	Aluminum ug/L	Calcium mg/L	Dissolved Organic Carbon mg/L	Total Organic Carbon mg/L
22: NR SPAC-T2	29-Apr-16	11.0	190	9	18	215	266	71.5	5.4	5.9
23: NR SPAC-T3	29-Apr-16	11.0	177	10	17	216	393	71.7	5.6	5.6
24: NR SPAC-T4	29-Apr-16	11.0	188	8	14	213	196	70.0	5.0	5.0
25: NR SPAC-T5	29-Apr-16	11.0	167	8	15	213	247	70.3	4.7	5.2
26: NR SPAC-T6	29-Apr-16	11.0	173	7	12	211	224	69.6	5.2	4.8
27: NR DF1118-T1	29-Apr-16	11.0	182	14	23	213	211	70.1	5.7	6.0
28: NR DF1118-T2	29-Apr-16	11.0	181	8	14	209	83.1	69.2	5.4	6.0
29: NR DF1118-T3	29-Apr-16	11.0	187	9	10	210	65.8	69.4	5.0	5.0
30: NR DF1118-T4	29-Apr-16	11.0	182	8	9	212	77.2	70.2	4.6	4.6
31: NR DF1118-T5	29-Apr-16	11.0	190	6	7	214	50.8	71.4	3.8	4.2
32: NR DF1118-T6	29-Apr-16	11.0	193	4	6	210	57.3	69.8	4.1	4.0
33: NR PAX-XL8-T1	28-Apr-16	11.0	185	12	22	215	316	71.7	5.1	6.0
34: NR PAX-XL8-T2	28-Apr-16	11.0	174	10	17	215	250	71.1	5.5	5.4
35: NR PAX-XL8-T3	28-Apr-16	11.0	203	10	17	210	264	69.3	5.8	6.0
36: NR PAX-XL8-T4	28-Apr-16	11.0	173	10	15	213	210	70.9	5.1	5.5
37: NR PAX-XL8-T5	28-Apr-16	11.0	179	9	15	214	235	70.6	5.7	5.7
38: NR PAX-XL8-T6	28-Apr-16	11.0	175	7	14	210	197	69.7	4.8	5.2
39: NR Raw Water	29-Apr-16	11.0	177	20	38	220	7.4	73.6	7.4	7.8

AO/OG - Aesthetic Objective / Operational Guideline

MDL - SGS Method Detection Limit

NR - Not reportable under applicable Provincial drinking water regulations as per client.

Patti Stark

Project Specialist Environmental Services, Analytical

Coagulant	Sample	Al ₂ O ₃ Dose	pH	Temp. (°C)	Turbidity (NTU)	UVA	Alkalinity mg/L as CaCO ₃	True Colour TCU	Apparent Colour CU	Hardness mg/L as CaCO ₃	Aluminum ug/L	Calcium Hardness mg/L	Dissolved Organic Carbon mg/L	Total Organic Carbon mg/L
PAX-XL8	NR PAX-XL8-T1	7.15	7.41	12	0.74	0.161	185	12	22	215	315	71.7	5.1	6
	NR PAX-XL8-T2	8.48	7.55	12	0.53	0.137	174	10	17	215	250	71.1	5.5	5.4
	NR PAX-XL8-T3	9.77	7.62	11.9	0.55	0.138	203	10	17	210	264	69.3	5.8	6
	NR PAX-XL8-T4	11.07	7.63	12.1	0.46	0.126	173	10	15	213	210	70.9	5.1	5.5
	NR PAX-XL8-T5	12.37	7.69	12.3	0.47	0.127	179	9	15	214	235	70.6	5.7	5.7
	NR PAX-XL8-T6	13.67	7.68	12.4	0.45	0.116	175	7	14	210	197	69.7	4.8	5.2
PAX-XL50	NR PAX-XL50-T1	7.25	8.08	12.2	1.1	0.162	177	11	20	211	313	69.3	6.3	6
	NR PAX-XL50-T2	8.57	8.01	11.6	0.89	0.147	185	9	18	213	296	70.9	5.1	6
	NR PAX-XL50-T3	10.48	7.94	11.7	0.95	0.138	175	8	17	209	394	68.7	5	5.7
	NR PAX-XL50-T4	12.09	7.92	11.7	0.73	0.127	172	7	17	217	286	72.2	4.9	5.5
	NR PAX-XL50-T5	13.70	7.88	11.9	1.04	0.122	177	7	13	217	307	71.2	4.8	4.8
	NR PAX-XL50-T6	15.31	7.8	12.3	0.71	0.109	180	6	12	213	250	70.9	4.1	4.4
DeltaFloc 1118	NR DF1118-T1	7.15	7.67	10.9	0.83	0.181	182	14	23	213	211	70.1	5.7	6
	NR DF1118-T2	10.01	7.95	11	0.53	0.134	181	8	14	209	83.1	69.2	5.4	6
	NR DF1118-T3	12.87	7.95	11.2	0.42	0.11	187	9	10	210	65.8	69.4	5	5
	NR DF1118-T4	15.73	7.89	11.96	0.38	0.1	182	8	9	212	77.2	70.2	4.8	4.8
	NR DF1118-T5	18.59	7.91	11.5	0.32	0.087	190	6	7	214	50.8	71.4	3.8	4.2
	NR DF1118-T6	21.45	7.88	11.7	0.21	0.075	193	4	6	210	57.3	69.6	4.1	4
DelPAC-2020	NR DP-2020-T1	6.86	8.09	11.5	0.77	0.156	181	10	20	211	289	70.2	6.2	6
	NR DP-2020-T2	8.11	7.95	11.3	0.59	0.144	180	9	18	215	257	71.3	5	5.6
	NR DP-2020-T3	9.36	7.92	11.2	0.83	0.138	178	8	16	209	368	68.8	4.8	5.4
	NR DP-2020-T4	10.61	7.89	11.4	0.61	0.128	178	8	16	213	267	70.6	5.4	5.8
	NR DP-2020-T5	11.86	7.85	11.5	0.71	0.125	172	10	13	206	304	67.7	5.1	5
	NR DP-2020-T6	13.10	7.79	11.8	0.63	0.113	172	7	12	218	231	72.6	5.1	5.1
SternPAC	NR SPAC-T1	6.89	8.07	11.5	0.78	0.157	177	11	21	214	301	71.3	5.7	5.9
	NR SPAC-T2	8.15	7.93	10.9	0.71	0.147	190	9	18	215	266	71.5	5.4	5.9
	NR SPAC-T3	9.40	7.85	11.1	0.6	0.143	177	10	17	216	353	71.7	5.6	5.8
	NR SPAC-T4	10.65	7.75	11.2	0.55	0.126	188	8	14	213	196	70	5	5
	NR SPAC-T5	11.91	7.75	11.4	0.65	0.123	187	8	15	213	247	70.3	4.7	5.2
	NR SPAC-T6	13.16	7.69	11.6	0.45	0.112	173	7	12	211	224	69.6	5.2	4.8
	NR Raw Water		8.59	10.28	1.36	0.24	171	20	38	220	73	13.6	7.9	7.8

161-05613-00 Coagulant Testing for Lindsay Water Treatment Plant



Jar Test Data Sheet		Source Water:				
Date:	4/28/2016	pH			7.61	
Time:	12:15 PM	Temperature		(°C)	9.8	
Performed By:	Mazahir Alidina	Turbidity		(NTU)	1.41	
Coagulant Type:	PAX-XL8	UVA			0.227	
		DOC		mg/L	7.4	
		TOC		mg/L	7.8	
		Alkalinity		(mg CaCO3/L)	177	
Coagulant Dosage:	55 to 105 mg/L	True colour			20	
Coagulant Aid Type:	Cationic Polmer	Apparent Colour			38	
Coagulant Aid Dosage:	0.54 mg/L	Calcium Hardness		mg/L	73.6	
Microsand Dose:	20 g	Total Hardness		mg/L as CaCO3	220	
Specific Gravity	1.24	Residual Aluminum		ug/L	7.4	
Conc. Of Alum (Al ₂ O ₃) (%)	10.50					
JAR NUMBER	T1	T2	T3	T4	T5	T6
DOSAGES						
Raw Water Volume (mL)	2000	2000	2000	2000	2000	2000
Coagulant Dose (mg/L)	55	65	75	85	95	105
Al ₂ O ₃ Conc. (mg/L)	7.16	8.46	9.77	11.07	12.37	13.67
Volume of 1:10 diluted Coagulant added (mL)	0.887	1.048	1.210	1.371	1.532	1.694
Microsand added (g)	20	20	20	20	20	20
Initial Volume of 1:10 diluted Polymer added with microsand (mL)	1.667	1.667	1.667	1.667	1.667	1.667
Remaining Volume of 1:10 diluted Polymer added (mL)	1.667	1.667	1.667	1.667	1.667	1.667
FLOCCULATION (0 - 2:40 mins)						
Duration (min)	2:40	2:40	2:40	2:40	2:40	2:40
Speed (rpm)	150	150	150	150	150	150
MATURATION (2:40 - 13:20 mins)						
Duration (min)	10:40	10:40	10:40	10:40	10:40	10:40
Speed (rpm)	150	150	150	150	150	150
SETTLING (13:20 - 17:20 mins)						
Duration (min)	4:00	4:00	4:00	4:00	4:00	4:00
Speed (rpm)	0	0	0	0	0	0
FINAL RESULTS						
pH	7.41	7.55	7.62	7.65	7.69	7.68
Temperature (°C)	12	12	11.9	12.1	12.3	12.4
Turbidity (NTU)	0.74	0.53	0.55	0.48	0.47	0.45
UVA	0.161	0.137	0.139	0.126	0.127	0.116
Alkalinity as CaCO3 (mg/L)	185	174	203	173	179	175
Colour (TCU)	12	10	10	10	9	7
Apparent Colour (CU)	22	17	17	15	15	14
Hardness as CaCO3 (mg/L)	215	215	210	213	214	210
Aluminum (ug/L)	316	250	264	210	235	197
Calcium (mg/L)	71.7	71.1	69.3	70.9	70.6	69.7
Dissolved Organic Carbon (mg/L)	5.1	5.5	5.8	5.1	5.7	4.8
Total Organic Carbon (mg/L)	6	5.4	6	5.5	5.7	5.2

161-05613-00 Coagulant Testing for Lindsay Water Treatment Plant



Jar Test Data Sheet		Source Water:				
Date:	4/28/2016	pH		7.81		
Time:	2:45 PM	Temperature	(°C)	11.4		
Performed By:	Mazahir Alidina	Turbidity	(NTU)	1.41		
Coagulant Type:	PAX-XL50	UVA		0.227		
		DOC	mg/L	7.4		
		TOC	mg/L	7.8		
Coagulant Dosage:	45 to 95 mg/L	Alkalinity	(mg CaCO ₃ /L)	177		
Coagulant Aid Type:	Cationic Polymer	True colour		20		
Coagulant Aid Dosage:	0.54 mg/L	Apparent Colour		38		
Microsand Dose:	20 g	Calcium Hardness	mg/L	73.6		
Specific Gravity	1.24	Total Hardness	mg/L as CaCO ₃	220		
Conc. Of Alum (Al ₂ O ₃) (%)	13.00	Residual Aluminum	ug/L	7.4		
JAR NUMBER	T1	T2	T3	T4	T5	T6
DOSAGES						
Raw Water Volume (mL)	2000	2000	2000	2000	2000	2000
Coagulant Dose (mg/L)	45	55	65	75	85	95
Al ₂ O ₃ Conc. (mg/L)	7.25	8.87	10.48	12.09	13.70	15.31
Volume of 1:10 diluted Coagulant added (mL)	0.726	0.887	1.048	1.210	1.371	1.532
Microsand added (g)	20	20	20	20	20	20
Initial Volume of 1:10 diluted Polymer added with microsand (mL)	1.667	1.667	1.667	1.667	1.667	1.667
Remaining Volume of 1:10 diluted Polymer added (mL)	1.667	1.667	1.667	1.667	1.667	1.667
FLOCCULATION (0 - 2:40 mins)						
Duration (min)	2:40	2:40	2:40	2:40	2:40	2:40
Speed (rpm)	150	150	150	150	150	150
MATURATION (2:40 - 13:20 mins)						
Duration (min)	10:40	10:40	10:40	10:40	10:40	10:40
Speed (rpm)	150	150	150	150	150	150
SETTLING (13:20 - 17:20 mins)						
Duration (min)	4:00	4:00	4:00	4:00	4:00	4:00
Speed (rpm)	0	0	0	0	0	0
FINAL RESULTS						
pH	8.08	8.01	7.94	7.92	7.88	7.8
Temperature (°C)	12.2	11.6	11.7	11.7	11.9	12.3
Turbidity (NTU)	1.1	0.89	0.95	0.73	1.04	0.71
UVA	0.162	0.147	0.138	0.127	0.122	0.108
Alkalinity as CaCO ₃ (mg/L)	177	185	175	172	177	180
Colour (TCU)	11	9	8	7	7	6
Apparent Colour (CU)	20	18	17	17	13	12
Hardness as CaCO ₃ (mg/L)	211	213	209	217	217	213
Aluminum (ug/L)	313	296	394	286	307	250
Calcium (mg/L)	69.3	70.9	68.7	72.2	71.2	70.5
Dissolved Organic Carbon (mg/L)	6.3	5.1	5	4.9	4.8	4.1
Total Organic Carbon (mg/L)	6	6	5.7	5.5	4.8	4.4

161-05613-00 Coagulant Testing for Lindsay Water Treatment Plant



Jar Test Data Sheet		Source Water:				
Date:	4/29/2016	pH			8.4	
Time:	9:20 AM	Temperature	(°C)		11.2	
Performed By:	Mazahir Alidina	Turbidity	(NTU)		1.25	
Coagulant Type:	DeltaFloc-1118	UVA			0.223	
		DOC	mg/L		7.4	
		TOC	mg/L		7.8	
		Alkalinity	(mg CaCO3/L)		177	
Coagulant Dosage:	25 to 75 mg/L	True colour			20	
Coagulant Aid Type:	Cationic Polmer	Apparent Colour			38	
Coagulant Aid Dosage:	0.54 mg/L	Calcium Hardness	mg/L		73.6	
Microsand Dose:	20 g	Total Hardness	mg/L as CaCO3		220	
Specific Gravity	1.3	Residual Aluminum	ug/L		7.4	
Conc. Of Alum (Al ₂ O ₃) (%)	22.00					
JAR NUMBER	T1	T2	T3	T4	T5	T6
DOSAGES						
Raw Water Volume (mL)	2000	2000	2000	2000	2000	2000
Coagulant Dose (mg/L)	25	35	45	55	65	75
Al ₂ O ₃ Conc. (mg/L)	7.15	10.01	12.87	15.73	18.59	21.45
Volume of 1:10 diluted Coagulant added (mL)	0.385	0.538	0.692	0.846	1.000	1.154
Microsand added (g)	20	20	20	20	20	20
Initial Volume of 1:10 diluted Polymer added with microsand (mL)	1.667	1.667	1.667	1.667	1.667	1.667
Remaining Volume of 1:10 diluted Polymer added (mL)	1.667	1.667	1.667	1.667	1.667	1.667
FLOCCULATION (0 - 2:40 mins)						
Duration (min)	2:40	2:40	2:40	2:40	2:40	2:40
Speed (rpm)	150	150	150	150	150	150
MATURATION (2:40 - 13:20 mins)						
Duration (min)	10:40	10:40	10:40	10:40	10:40	10:40
Speed (rpm)	150	150	150	150	150	150
SETTLING (13:20 - 17:20 mins)						
Duration (min)	4:00	4:00	4:00	4:00	4:00	4:00
Speed (rpm)	0	0	0	0	0	0
FINAL RESULTS						
pH	7.87	7.95	7.95	7.89	7.91	7.88
Temperature (°C)	10.9	11	11.2	11.96	11.5	11.7
Turbidity (NTU)	0.83	0.53	0.42	0.38	0.32	0.21
UVA	0.181	0.134	0.11	0.1	0.087	0.075
Alkalinity as CaCO3 (mg/L)	182	181	187	182	190	193
Colour (TCU)	14	8	9	8	6	4
Apparent Colour (CU)	23	14	10	9	7	6
Hardness as CaCO3 (mg/L)	213	209	210	212	214	210
Aluminum (ug/L)	211	83.1	65.8	77.2	50.8	57.3
Calcium (mg/L)	70.1	69.2	69.4	70.2	71.4	69.8
Dissolved Organic Carbon (mg/L)	5.7	5.4	5	4.6	3.8	4.1
Total Organic Carbon (mg/L)	6	6	5	4.6	4.2	4

161-05613-00 Coagulant Testing for Lindsay Water Treatment Plant



Jar Test Data Sheet			Source Water:			
Date:	4/29/2016	pH				8.31
Time:	11:20 AM	Temperature	(°C)			9.5
Performed By:	Mazahir Alidina	Turbidity	(NTU)			1.41
Coagulant Type:	DeIPAC 2020	UVA				0.223
		DOC	mg/L			7.4
		TOC	mg/L			7.8
		Alkalinity	(mg CaCO3/L)			177
Coagulant Dosage:	55 to 105 mg/L	True colour				20
Coagulant Aid Type:	Cationic Polmer	Apparent Colour				38
Coagulant Aid Dosage:	0.54 mg/L	Calcium Hardness	mg/L			73.6
Microsand Dose:	20 g	Total Hardness	mg/L as CaCO3			220
Specific Gravity	1.2	Residual Aluminum	ug/L			7.4
Conc. Of Alum (Al ₂ O ₃) (%)	10.40					
JAR NUMBER	T1	T2	T3	T4	T5	T6
DOSAGES						
Raw Water Volume (mL)	2000	2000	2000	2000	2000	2000
Coagulant Dose (mg/L)	55	65	75	85	95	105
Al ₂ O ₃ Conc. (mg/L)	6.86	8.11	9.36	10.61	11.86	13.10
Volume of 1:10 diluted Coagulant added (mL)	0.917	1.083	1.250	1.417	1.583	1.750
Microsand added (g)	20	20	20	20	20	20
Initial Volume of 1:10 diluted Polymer added with microsand (mL)	1.667	1.667	1.667	1.667	1.667	1.667
Remaining Volume of 1:10 diluted Polymer added (mL)	1.667	1.667	1.667	1.667	1.667	1.667
FLOCCULATION (0 - 2:40 mins)						
Duration (min)	2:40	2:40	2:40	2:40	2:40	2:40
Speed (rpm)	150	150	150	150	150	150
MATURATION (2:40 - 13:20 mins)						
Duration (min)	10:40	10:40	10:40	10:40	10:40	10:40
Speed (rpm)	150	150	150	150	150	150
SETTLING (13:20 - 17:20 mins)						
Duration (min)	4:00	4:00	4:00	4:00	4:00	4:00
Speed (rpm)	0	0	0	0	0	0
FINAL RESULTS						
pH	8.09	7.99	7.92	7.89	7.85	7.79
Temperature (°C)	11.5	11.3	11.2	11.4	11.5	11.8
Turbidity (NTU)	0.77	0.69	0.83	0.61	0.71	0.63
UVA	0.156	0.144	0.138	0.128	0.125	0.113
Alkalinity as CaCO3 (mg/L)	181	180	178	178	172	172
Colour (TCU)	10	9	8	8	10	7
Apparent Colour (CU)	20	18	16	16	13	12
Hardness as CaCO3 (mg/L)	211	215	209	213	206	218
Aluminum (ug/L)	289	257	368	267	304	231
Calcium (mg/L)	70.2	71.3	68.8	70.6	67.7	72.6
Dissolved Organic Carbon (mg/L)	6.2	5	4.8	5.4	5.1	5.1
Total Organic Carbon (mg/L)	6	5.6	5.4	5.8	5	5.1

161-05613-00 Coagulant Testing for Lindsay Water Treatment Plant



Jar Test Data Sheet			Source Water:			
Date:	4/29/2016	pH				8.31
Time:	12:50 PM	Temperature	(°C)			9.5
Performed By:	Mazahir Alidina	Turbidity	(NTU)			1.43
Coagulant Type:	SternPAC	UVA				0.224
		DOC	mg/L			7.4
		TOC	mg/L			7.8
		Alkalinity	(mg CaCO3/L)			177
Coagulant Dosage:	55 to 105 mg/L	True colour				20
Coagulant Aid Type:	Cationic Polmer	Apparent Colour				38
Coagulant Aid Dosage:	0.536 mg/L	Calcium Hardness	mg/L			73.6
Microsand Dose:	20 g	Total Hardness	mg/L as CaCO3			220
Specific Gravity	1.205	Residual Aluminum	ug/L			7.4
Conc. Of Alum (Al ₂ O ₃) (%)	10.40					
JAR NUMBER	T1	T2	T3	T4	T5	T6
DOSAGES						
Raw Water Volume (mL)	2000	2000	2000	2000	2000	2000
Coagulant Dose (mg/L)	55	65	75	85	95	105
Al ₂ O ₃ Conc. (mg/L)	6.89	8.15	9.40	10.65	11.91	13.16
Volume of 1:10 diluted Coagulant added (mL)	0.913	1.079	1.245	1.411	1.577	1.743
Microsand added (g)	20	20	20	20	20	20
Initial Volume of 1:10 diluted Polymer added with microsand (mL)	1.667	1.667	1.667	1.667	1.667	1.667
Remaining Volume of 1:10 diluted Polymer added (mL)	1.667	1.667	1.667	1.667	1.667	1.667
FLOCCULATION (0 - 2:40 mins)						
Duration (min)	2:40	2:40	2:40	2:40	2:40	2:40
Speed (rpm)	150	150	150	150	150	150
MATURATION (2:40 - 13:20 mins)						
Duration (min)	10:40	10:40	10:40	10:40	10:40	10:40
Speed (rpm)	150	150	150	150	150	150
SETTLING (13:20 - 17:20 mins)						
Duration (min)	4:00	4:00	4:00	4:00	4:00	4:00
Speed (rpm)	0	0	0	0	0	0
FINAL RESULTS						
pH	8.07	7.93	7.85	7.79	7.75	7.69
Temperature (°C)	11.5	10.9	11.1	11.2	11.4	11.6
Turbidity (NTU)	0.78	0.71	0.8	0.55	0.65	0.45
UVA	0.157	0.147	0.143	0.126	0.123	0.112
Alkalinity as CaCO3 (mg/L)	177	190	177	188	167	173
Colour (TCU)	11	9	10	8	8	7
Apparent Colour (CU)	21	18	17	14	15	12
Hardness as CaCO3 (mg/L)	214	215	216	213	213	211
Aluminum (ug/L)	301	266	393	196	247	224
Calcium (mg/L)	71.3	71.5	71.7	70	70.3	69.6
Dissolved Organic Carbon (mg/L)	5.7	5.4	5.6	5	4.7	5.2
Total Organic Carbon (mg/L)	5.9	5.9	5.6	5	5.2	4.8

Appendix 4

Result Graphs

