



ONTARIO CLEAN WATER AGENCY
AGENCE ONTARIENNE DES EAUX

Report to the City of Kawartha Lakes for the Woodville Water Treatment Plant (WTP) Capacity Assessment

SUBMITTED BY

Ontario Clean Water Agency
2085 Hurontario Street, Suite 500
Mississauga, ON L5A 4G1

Date: May 18, 2022
Project No: **KAWLAN5842-2232**
Rev: 0

Issue and Revision Record					
Rev. No.	Date	Prepared by:	Reviewed by:	Approved by:	Rev. Description
00	May 13, 2022	Jose Casal, P.Eng.	Lisa Babel, P.Eng.		Draft to Client
	May 18, 2022	Jose Casal, P.Eng.	Lisa Babel, P.Eng.		Final

Report prepared by:



Jose Casal, P.Eng., PMP
Senior Specialist/Project Manager

Report reviewed by:



Lisa Babel, P.Eng.
Director

STATEMENT OF CONFIDENTIALITY

OCWA's Report to City of Kawartha Lakes for the Woodville Water Treatment Plant (WTP) Capacity Assessment

This document has been developed by the Ontario Clean Water Agency in response to the City of Kawartha Lakes request. Information has been provided for the express review of the City of Kawartha Lakes and is not to be copied or submitted in any way or form to any person(s) or organization(s) without the written authorization of the President and CEO of the Ontario Clean Water Agency. All copyright and intellectual rights to the material provided remain in the ownership of the Ontario Clean Water Agency.

Table of Contents

Statement of Confidentiality

1 Introduction	1
2 Background	1
2.1 Drinking Water System (DWS) Overview.....	1
2.2 Raw Water Taking	1
2.3 Water Treatment Plant.....	2
3 Flow Testing.....	4
3.1 Potential Risks.....	5
4 Flow Analysis	9
4.1 Historical Raw Water Taking.....	9
4.2 Historical Treated Water Usage/Consumption.....	10
4.3 Water Quality.....	11
5 Growth/Development Forecast.....	11
5.1 Population Projection	11
5.2 Future Water Demand Forecast	12
5.3 Regulatory Requirements	12
6 Capacity Assessment.....	13
6.1 Potential Residential Development (Scenario 1).....	14
6.2 Potential Residential Development (Scenario 2).....	15
7 Conclusions	17
8 Recommendations	18

Appendix A: Flow Testing Schedule

Appendix B: Flow Testing Results

1 Introduction

The City of Kawartha Lakes (City) is growing in population. To meet the potential future growth the City reached out to OCWA to complete a desktop capacity study to provide some insight into how much development can be accommodated within the current available capacity and at what point an upgrade may be needed.

2 Background

Woodville is a community located west of Lindsay, within the Municipality of Kawartha Lakes (City). Based on the 2021 census information, Woodville has a population of approximately 718 people. Water is supplied via a dedicated municipal Drinking Water System (DWS); however there is no municipal sewage collection and treatment system. All houses have independent onsite sewage systems (septic tanks).

2.1 Drinking Water System (DWS) Overview

The Woodville DWS consists of two groundwater under direct influence of surface water (GUDI) production wells (Well 1 and Well 2) and one pond makeup well (Well 3) in addition to, one water treatment plant (WTP), a water distribution network and one elevated storage reservoir (standpipe). The Woodville WTP is currently operated/managed by the Ontario Clean Water Agency (OCWA) and the distribution system is operated/managed by the City of Kawartha Lakes.

The Woodville DWS currently operates under the following approval instruments:

- Permit to Take Water (PTTW): 1207-AHKRXV dated February 15, 2017
- Municipal Drinking Water License (MDWL): 141-115 (Issue 3) dated April 30, 2021
- Drinking Water Works Permit (DWWP): 141-215 (Issue 3) dated November 10, 2021

2.2 Raw Water Taking

Raw water is supplied via three groundwater wells as follows:

- Production Well 1: A production well complete with 225 m of 150 mm diameter discharge pipe from the well to a pump station, including pitless adapter. It is deemed to be a GUDI (groundwater under the direct influence of surface water). Well 1 is equipped with one submersible pump rated at 6.8 L/s at 75.5 m TDH, with a variable frequency drive.
- Production Well 2: Drilled groundwater well complete with 200 m of 100 mm diameter discharge pipe to the pump station. Also deemed to be a GUDI (groundwater under the direct influence of surface water). Well 2 is equipped with a submersible deep well pump rated 6.8 L/s at 75.5 m TDH, with a variable frequency drive.
- Pond Make-up Well 3: Groundwater well complete with 50 mm diameter discharge pipe from the well to an existing private pond located at 326 Glen Road via a pumphouse. It is considered a

Recreational – Isolated non-potable pond make-up system. Well 3 is equipped with one submersible pump rated at 22.8 L/min at a TDH of 8 m.

The operation of these three wells is controlled by the provisions included in the PTTW currently in place, as follows:

Table 2-1: Water Taking per Well as per the PTTW

WELL	MAX. TAKEN PER MINUTE (LITRES):	MAX. NUM. OF HRS TAKEN PER DAY:	MAX. TAKEN PER DAY (LITRES):	MAX. NUM. OF DAYS TAKEN PER YEAR:
Well 1	409	24	589,162	365
Well 2	409	24	589,162	365
Well 3	23	24	32,832	365
Total Taking			589,162	

Notwithstanding the provisions made in Table 2-1, the PTTW currently in place allows for pumping of production wells Well 1 and Well 2, at rates of up to 6.8 L/s (409 L/min) for each of the wells. However, the maximum simultaneous permitted water taking rate for the works is limited to 6.8 L/s (409 L/min) from all sources combined up to a maximum of 589,162 L/day. As such, pumping of Well 1 and Well 2 can either be conducted separately at that rate or both wells can be pumped simultaneously, although with each at a reduced rate to ensure the total does not exceed 6.8 L/s.

2.3 Water Treatment Plant

The existing Water Treatment Plant (WTP) provides filtration (cartridge filters) and chemical disinfection (primary and secondary) using sodium hypochlorite. The facility has the following equipment components:

Table 2-2: Woodville WTP Process Equipment and Components

PROCESS EQUIPMENT/COMPONENT	DESCRIPTION
Filtration	Two treatment trains in parallel, each train consisting of two cartridge filter assemblies: - First assembly consisting of one filter housing and a battery of 12 1-micron nominal cartridges certified to ANSI/NSF 61 and capable of filtering 1-5 micron particles at 6.8 L/s. - Second assembly consisting of one filter housing and a battery of 12 1-micron absolute cartridges confirmed to be ANSI/NSF 53 and capable of filtering 1 micron particles at 6.8 L/s complete with pressure gauges to determine pressure differential for cartridge replacement.

PROCESS EQUIPMENT/COMPONENT	DESCRIPTION
Disinfection	- Two chemical feed pumps (duty and standby) each capable of dosing sodium hypochlorite solution. - One chemical storage tank, complete with chemical spill containment facilities and necessary piping.
Chlorine Contact	Approximately 90 m of 600 mm diameter watermain from the pump station along County Road No. 46, serving as chlorine contact chamber.
Instrumentation & Control	- System control with data acquisition including various on-line analyzers and monitors - Two turbidimeters: one in each filter train. - Two chlorine analyzers: one located before chlorine contact chamber and second located in remote monitoring station at the end of the chlorine contact chamber.
Standby Power	One 60 kW standby power generator system, complete with fuel tank, containment facilities, and necessary controls.
Elevated Storage Reservoir (Standpipe)	One Standpipe for water storage and pressure equalization across the distribution with a total storage capacity of 1160 m ³

According to the MDWL, the facility has a rated capacity of 588 m³/day.

Woodville Drinking Water System




Figure 2-1: Woodville WTP Process Flow Diagram (PFD) as per the DWWP

The Woodville water distribution system (operated by the City) is composed of a network of watermain including fire hydrants, valves and other appurtenances, as well as, an elevated storage reservoir (standpipe) which has a total storage capacity of 1160 m³ (twice as much the rated capacity of the existing water treatment facility). As confirmed by the City, the Woodville DWS does not provide fire protection.

3 Flow Testing

As requested by the municipality, OCWA completed flow testing at the Woodville WTP to confirm/validate that the existing treatment process trains (Train 1 and Train 2) currently in place at the facility are capable of processing flows up to the maximum water taking allowance of 409 L/m (6.8 L/s).

Forty five 1-hour testing runs were performed in total between April 26, 2022 and May 9, 2022; following the testing schedule shown in Appendix A. Both treatment trains (Train 1 and Train 2) were tested independently and combined using each well pump (either Well 1 pump or Well 2 pump) independently or both well pumps at once as illustrated in Figure 3-1. In each testing trial, the following parameters were monitored:

- Water Quantity: Raw water flow from both wells (Well 1 and 2) and Treated water flow (flowmeter treated water).
- Filter Performance: Turbidity, pressure at the filters.

- Disinfection: Chlorine residual before the contact chamber and chlorine residual at monitoring station at the end of the chlorine contact Chamber.




Figure 3-1: Flow Testing Combinations

In general, all test runs were considered satisfactory, as they all confirmed that the existing treatment trains are capable of producing good quality drinking water at the maximum flow rates for which the facility was originally designed. As summary of the overall test result is shown in Table 3-1 and the full data set are included in Appendix B. Despite the above, the following operational challenges which were encountered during these test runs are worth noting:

- During the test conducted on Treatment Train 2, with flow of greater than 6 L/s using only raw water supply from Well 1 (April 27, 2022); the VFD installed on the Well 1 pump reached the maximum amperage threshold and disconnected. It was noted that the filters installed in Treatment Train 2 were near the end of their life. This situation did not occur while running Treatment Train 1 with supply from Well 1 at the same flow setting.
- Testing both treatment trains together at once was only possible from "MANUAL mode" since the current SCADA programming does not allow for this setting. At present the SCADA "AUTOMATIC mode" is restricted to operate only one treatment train at a time. It is recommended that the existing SCADA program be reviewed and/or adjusted (if possible) to enable operation of both treatment trains simultaneously.

3.1 Potential Risks

The filtration trains (cartridge filters) are considered the critical process units of this water treatment system. These cartridge filters are normally replaced based on differential pressure (pressure loss)

indicating that the filters are at the end of life or are replaced when the turbidity criteria are consistently not achieved. There is no ability to backwash these filters and they must be replaced when blinded.

Adding new services connections (new houses) to the existing ones; translates into higher water demand (additional flows). The effective life of the existing filtration units will shorten as the flow through these treatment trains increase and/or the longer the run time (hours of operation) these treatment systems are ON whether independently or combined to meet the new demand. Therefore, any future growth/development could directly impacts the performance and life of these filters.

It should be noted as of December 2020, the manufacturer/supplier (Suez) of the 1-micron absolute ANSI/NFS 53 certified cartridge filters has decided to discontinue production of these type of filters due to the incremental accreditation cost required for this type of filter. As such, this poses an operational risk for this facility.

Since December 2020, OCWA has manage to keep large inventory of these filters. However, the stock is rapidly depleting. OCWA's ongoing efforts to secure the ANSI/NSF 53 filters that currently fit the filter vessels (canisters) have yielded diminishing results, as many other manufacturers in the market have also discontinued fabrication. If a long term solution acceptable by all stakeholders (i.e. OCWA, municipalities, Ministry, etc.) is not devised in the near future, the current circumstances pose a risk to the continued operations of facilities across the province using this type of certified filter. Consequently, OCWA will be submitting an application for regulatory relief to the Ministry (MECP) to get an exemption until a long term solution is found and approved by the Ministry.

In the interim, OCWA continues to work jointly with the Ministry and other municipalities to develop a procedure to test and confirm log removal credits using the non ANSI/NSF certified filters from other manufacturers. If the proposed procedure to test and validate these filtration units is approved by all stakeholders, this could effectively eliminate the needs to have ANSI/NSF certified filters. If successful, this would also set a provincial standard for certifying cartridge filters.

Table 3-1: Summary of monitoring parameters during the Flow Monitoring Program

#	Treatment Train	Well	Date	Time	Duration	Monitoring Parameters							
						Water Quantity			Filter Performance		Disinfection		
						Raw Water Flow (L/s) ¹	Treated Water Flow (L/s) ²	Well Level (m)	Turbidity (NTU) ³	Pressure (kPa) ⁴	Chlorine Dosage (mg/L) ⁵	Chlorine Residual (mg/L) ⁶	Distribution Chlorine Residual (mg/L) ⁷
1	treatment train # 1	well 1	APRIL 28, 2022	09:09 – 10:09	1 h	5	4.99	0.038	5.2/5.3	4.67	4.67	3.3	2.4
2		well 1	APRIL 28, 2022	10:09 – 11:09	1 h	5.48	5.48	0.034	7.2/7.3	4.25	4.25	3.34	2.44
3		well 1	APRIL 28, 2022	11:09 – 12:09	1 h	5.98	5.98	0.035	9.3/9.9	4.71	4.71	3.29	2.48
4		well 1	APRIL 28, 2022	12:09 – 13:09	1 h	6.48	6.48	0.034	12.1/12.4	4.8	4.8	3.28	2.48
5		well 1	APRIL 28, 2022	13:09 – 14:09	1 h	6.79	6.79	0.035	13.9/14.2	4.99	4.99	3.03	2.49
6		well 2	APRIL 28, 2022	14:09 – 15:09	1 h	4.84	5.04	0.038	6.3/6.0	4.79	4.79	3.36	2.48
7		well 2	MAY 3, 2022	11:41 – 12:41	1 h	5.3	5.3	0.052	8.9/8.5	3.66	3.66	2.68	2.37
8		well 2	MAY 3, 2022	08:41 – 09:41	1 h	5.98	5.96	0.034	10.6/10.7	3.9	3.9	2.76	2.4
9		well 2	MAY 3, 2022	09:41 – 10:41	1 h	6.48	6.45	0.033	13.0/13.0	4.2	4.2	2.89	2.46
10		well 2	MAY 3, 2022	10:41 – 11:41	1 h	6.8	6.8	0.034	14.5/14.6	4.08	4.08	2.78	2.48
11		well 1 + well 2	MAY 3, 2022	11:41 – 12:41	1 h	2.42/2.63	5.02	0.033	5.8/6.8	3.85	3.85	2.97	2.49
12		well 1 + well 2	MAY 3, 2022	12:41 – 13:41	1 h	2.73/2.72	5.44	0.033	8.9/9.9	3.55	3.55	2.98	2.49
13		well 1 + well 2	MAY 3, 2022	13:41 – 14:41	1 h	2.98/2.99	5.95	0.032	11.2/11.3	4	4	2.89	2.49
14		well 1 + well 2	MAY 4, 2022	06:56 – 07:56	1 h	3.24/3.23	6.48	0.033	13.8/13.9	3.61	3.61	2.95	2.4
15		well 1 + well 2	MAY 4, 2022	07:56 – 08:56	1 h	3.40/3.40	6.78	0.033	15.7/15.1	4.01	4.01	2.91	2.37
16	treatment train # 2	well 1	APRIL 26, 2022	12:35 – 13:35	1 h	5.01	5.01	0.037	82.7/88	4.6	4.6	3.47	2.35
17		well 1	APRIL 26, 2022	1335-1435	1 h	5.48	5.47	0.035	88/125.1	4.54	4.54	3.5	2.36
18		well 1	APRIL 27, 2022	0730-0830	1 h	5.78	5.78	0.08	133.0/145.9	4.01	4.01	2.84	2.24
19		well 1	APRIL 27, 2022	0830-0930	1 h	4.29	5.2	0.045	145.9/133.3	6.1	6.1	2.87	2.14
20		well 1	APRIL 27, 2022	0930-1030	1 h	6.17	6.12	0.039	133.3/158.3	4.41	4.41	3.16	2.12
21		well 2	APRIL 26, 2022	07:35 – 08:35	1 h	5.02	4.98	0.037	73.3/73.6	1.51	1.51	3.23	2.28
22		well 2	APRIL 26, 2022	0835-0935	1 h	5.48	5.44	0.036	73.6/84.4	4.5	4.5	3.4	2.29
23		well 2	APRIL 26, 2022	0935-1035	1 h	5.98	5.94	0.036	84.4/94.7	4.56	4.56	3.37	2.35

¹ Raw water flow from both wells (combined) during that 1-hour test run.

² Treated water flow (flowmeter treated water) during that 1-hour test run

³ Turbidity at the filters (leaving the filters) during that 1-hour test run

⁴ Pressure at the filters (start/stop readings) during that 1-hour test run

⁵ Chlorine Dosage during that 1-hour test run

⁶ Chlorine residual before the contact chamber during that 1-hour test run

⁷ Chlorine residual at monitoring station at the end of the chlorine contact chamber during that 1-hour test run.

#	Treatment Train	Well	Date	Time	Duration	Monitoring Parameters							
						Water Quantity			Filter Performance		Disinfection		
						Raw Water Flow (L/s) ¹	Treated Water Flow (L/s) ²	Well Level (m)	Turbidity (NTU) ³	Pressure (kPa) ⁴	Chlorine Dosage (mg/L) ⁵	Chlorine Residual (mg/L) ⁶	Distribution Chlorine Residual (mg/L) ⁷
24		well 2	APRIL 26, 2022	1035-1135	1 h	6.49	6.44	0.036	94.7/100.3	4.56	4.56	3.36	2.36
25		well 2	APRIL 26, 2022	1135-1235	1 h	6.58	6.69	0.037	100.3/108.9	4.37	4.37	3.28	2.37
26		well 1 + well 2	APRIL 27, 2022	1037 – 11:37	1 h	2.49/2.41	4.88	0.037	124.1/134.1	4.73	4.73	3.41	2.26
27		well 1 + well 2	APRIL 27, 2022	1137-1237	1 h	2.74/2.73	5.45	0.038	134.1/140.5	4.26	4.26	3.35	2.49
28		well 1 + well 2	APRIL 27, 2022	1237-1337	1 h	2.99/2.98	5.93	0.037	145.5/170.5	4.56	4.56	3.32	2.49
29		well 1 + well 2	APRIL 27, 2022	1337-1437	1 h	3.23/3.24	6.43	0.038	185.6/187.5	4.8	4.8	3.25	2.5
30		well 1 + well 2	APRIL 28, 2022	0737-0837	1 h	3.39/3.39	6.74	0.039	176.3/207.1	4.58	4.58	3.15	2.4
31	Treatment Trains 1 & 2 Together	well 1	MAY 4, 2022	0948-1048	1 h	5	5	0.03 (0.11)	4.8/5.0 (12.3/12.7)	3.89	3.89	2.48	2.4
32		well 1	MAY 4, 2022	1049-1149	1 h	5.49	5.5	0.032 (0.097)	6.6/7.1 (14.5/15.0)	4.25	4.25	2.42	2.4
33		well 1	MAY 4, 2022	1151-1251	1 h	6	6	0.032 (0.097)	9.0/10.6 (17.1/18.5)	3.89	3.89	2.45	2.4
34		well 1	MAY 4, 2022	1253-1353	1 h	6.5	6.5	0.032 (0.097)	12.7/13.5 (20.8/21.8)	4.19	4.19	2.5	2.38
35		well 1	MAY 4, 2022	1357-1457	1 h	6.78	6.79	0.032 (0.097)	15.3/16.1 (23.2/23.9)	4.01	4.01	2.56	2.4
36		well 2	May 5, 2022	0757-0857	1 h	4.99	4.97	0.034 (0.026)	7.3/7.4 (14.6/14.7)	4.68	4.68	2.21	2.17
37		well 2	May 5, 2022	0858-0958	1 h	5.48	5.46	0.032 (0.024)	7.6/9.5 (16.6/16.8)	3.54	3.54	2.38	2.17
38		well 2	May 5, 2022	0959-1059	1 h	5.98	6.01	0.032 (0.024)	11.4/11.3 (19.0/19.0)	4.53	4.53	2.37	2.21
39		well 2	May 5, 2022	1100-1200	1 h	6.5	6.47	0.032 (0.024)	13.3/13.3 (21.2/21.2)	3.59	3.59	2.51	2.24
40		Well 2	May 5, 2022	1202-1302	1 h	6.8	6.8	0.032 (0.024)	14.6/14.9 (22.5/22.5)	4.01	4.01	2.57	2.26
41		Well 1 + Well 2	May 5, 2022	1308-1408	1 h	2.50/2.51	4.99	0.032 (0.026)	7.7/8.0 (14.7/15.0)	5.43	5.43	2.26	2.17
42		Well 1 + Well 2	May 5, 2022	1409-1509	1 h	2.74/2.75	5.47	0.032 (0.024)	9.7/9.9 (17.0/17.3)	4.26	4.26	2.22	2.25
43		Well 1 + Well 2	May 9, 2022	08:03 – 09:03	1 h	2.97/2.96	5.91	0.034 (0.028)	11.5/11.1 (18.6/18.2)	4.59	4.59	2.45	2.35
44		Well 1 + Well 2	May 9, 2022	09:07 – 10:07	1 h	3.26/3.28	6.52	0.032 (0.027)	13.3/13.7 (21.3/21.5)	4.16	4.16	2.7	2.34
45		Well 1 + Well 2	May 9, 2022	10:12 – 11:12	1 h	3.41/3.40	6.8	0.032 (0.026)	14.7/15.0 (22.7/23.2)	3.99	3.99	2.81	2.33

4 Flow Analysis

4.1 Historical Raw Water Taking

As indicated in the PTTW, the total combined rate of taking (maximum allowable) for all three wells shall not exceed 589,162 litres per day (589 m³/day) at a maximum pumping rate of 6.8 L/s. However, the historical data review (January 2017 to December 2021) concludes that the average water taking (175 m³/day) was substantially lower than what the system is allowed to take on a daily basis. Figure 4-1 shows the raw water taking trend during the period of reference (2017-2021).




Figure 4-1: Historical Raw Water Taking (2017-2021)

A substantial reduction in the average daily water taking was observed in 2020 (first year of COVID-19 pandemic), as compared to previous years (21% reduction as compared to 2017, 15% reduction as compared to 2018 and 18% reduction as compared to 2019). It should be noted that this “reduction” trend is opposite to what it was experienced in majority of the drinking water systems across the province due to the stay at home measures adopted to combat the pandemic. 2021 showed a slight increase from 2020; however, still lower than the water taking values shown in 2017, 2018 and 2019.

In summary, it appears that the drinking water system is currently using only 30% of the total permitted water taking to meet the current water demands of this community which indicates there is some spare capacity to accommodate some future growth/development without the need of amending the current water taking permit.

4.2 Historical Treated Water Usage/Consumption

As indicated by the MDWL currently in place, the facility has a rated capacity of 588 m³/day, which matches the maximum water taking allowance as indicated in the PTTW.

A review of the historical flow data (January 2017 up to December 2021) for this facility concludes that the average treated water production (174 m³/day) is substantially lower than the design capacity (588 m³/day) of the treatment system currently in place. Figure 4-2 shows the treated water flows during the period of reference (2017-2021).




Figure 4-2: Historical Treated Water Flows (2017-2021)

During the review of the raw and treated flow data, a discrepancy (accounting for approximately 1 m³/day) was detected between the combined raw water flow readings and the overall treated water flow for the first 3 years (2017, 2018 and 2019) of the period. As informed by the operating authority

(OCWA), this situation has been addressed by replacing the existing three flow metering devices with new ones as follows:

- Raw Water Flowmeter for well pump 2 (RW2) replaced in October 27, 2020
- Raw Water Flowmeter for well pump 1 (RW1) replaced in April 29, 2021
- Treated Water Flowmeter at the facility (TW) replaced in April 29, 2021

In summary, the historical average treated water flow (174 m³/day) accounts for only 29% of the overall rated capacity (558 m³/day) of the water treatment facility; which indicates that this facility is capable to treat additional water flows to meet the future water demands as result of growth/development.

For the purpose of this study, this historical average treated water flow (174 m³/day) will be considered the baseline consumption/production.

4.3 Water Quality

Based on the last two annual reports for 2020 and 2021; there have been no exceedances and/or compliance issues, with the exception of one Adverse Water Quality Incident reported in December 2020 where the Treatment Train 2 failed to meet the performance criterion for filtered water turbidity (less than or equal to 0.2 NTU in 95% of the measurements each month) during maintenance operations. This situation was quickly corrected by the operating authority (OCWA).

5 Growth/Development Forecast

The municipality has expressed interest in developing/growing this area; however there is no specific development strategy planned for this community. In absence of a planning strategy, the future water demand will be forecasted using well known standards/guidelines currently in place in the province of Ontario factoring in the current migration trends.

5.1 Population Projection

Based on the most recent census⁸ (2021) information, the community of Woodville has experienced a 13% reduction in the population between 2016 (826 people) and 2021 (718 people). At present there are 295 private houses; however only 275 are currently occupied by residents. Based on this information, the house occupation rate has been calculated as 2.6 people per residence.

Despite the above statistics, the unprecedented migration trends observed in 2020 and 2021 have impacted the natural/historical growth rate of many small communities across Ontario. During these two years, a significant population exodus from the big city centers to the small rural communities in search of better quality of life during the COVID-19 pandemic has been experienced. Consequently; this migration pattern has triggered an increase in the housing demand for these small communities, forcing municipalities to take immediate actions to address the sudden growth/development needs. Given the

⁸ 2021 Census: <https://www12.statcan.gc.ca/census-recensement/2021/dp-pd/prof/details/page.cfm?Lang=E&SearchText=woodville&DGUIDlist=2021A0006350073&GENDERlist=1&STATISTIClist=1&HEADERlist=0>

current circumstances, the population/growth data trends collected during the 2021 census no longer apply as they do not accurately reflect the impact that the COVID-19 pandemic has had on population growth rate for these small communities.

For the purpose of this assessment, a house occupation rate of 4 people per house will be used instead of the calculated 2.6 people per house based on 2021 census information. This conservative approach is taken to ensure that the calculated future demand does not surpasses the existing capacity of the system to provide safe drinking water.

5.2 Future Water Demand Forecast

In absence of a planning strategy, the estimate potential growth and capacity to accommodate additional service connection will be based on current industry standards and other applicable guidelines/codes within the province of Ontario factoring in the current migration trends experienced.

Based on information provided by OCWA, all services connections have water meters; however there is no water usage data available to estimate the historical and current household's water usage for this community. In absence of this information, standards domestic water demand of 270 to 450 L/cap-d stated in the Ontario Ministry of Environment (MOE) Design Guidelines for Drinking-Water Systems (2008)⁹, will be used for this determination.

Based on the same Design Guidelines, the drinking-water system including the water treatment plant and treated water storage should be designed to satisfy the greater of the following demands: Maximum day demand plus fire flow (where fire protection is to be provided) or peak hour demand. Table 5-1 shows the assumptions used to estimate the future water demand for the Woodville DWS.

Table 5-1: Basis and Assumptions for the Water Demand Forecast

ITEM	GUIDELINES & STANDARDS	COMMENTS	REFERENCE
Per-Capita Domestic Water Demand	270 to 450 L/cap-d	450 L/cap-d (0.45 m ³ /cap-d) will be used as a conservative value in absence of accurate household consumption information.	MOE Design Guidelines for Drinking-Water Systems (2008): https://www.ontario.ca/document/design-guidelines-drinking-water-systems-0
Maximum Day Factor	2.75	Recommended Max Day Factor to be used with the average day demand for a population between 500-1000 people	

For the purpose of estimating the future water flows/demands, the maximum day demand will be used.

5.3 Regulatory Requirements

Although it is not a prescribed policy, it has been noticed that in instances where the Average Day Flow is at or is exceeding 80% of the rated capacity specified in the Approval, the Ministry (MECP) expects

⁹ MOE Design Guidelines for Drinking-Water Systems (2008): <https://www.ontario.ca/document/design-guidelines-drinking-water-systems-0>

that actions will be taken to avoid potential flow exceedances and/or compliance issue during the operation of water and wastewater facilities. These actions may include:

- Optimization (where possible), flow reduction measures (i.e. water use audits, etc.). This option could be easily implemented in relatively short time; however it may result in marginal capacity gain (if any).
- Exploring the feasibility of re-rating the facility's capacity. Although possible, additional studies are required (i.e. Process Audit, etc.). This option can be a lengthy process (3 to 5 years) and may result in marginal capacity gain (if any).
- Upgrade/expansion of the Works. Municipal Class EA (most likely schedule C). This option can also be lengthy process (4 to 5 years) until the DWS is expanded/upgraded (Figure 5-1); however it will address the growth/development challenges in the medium and long term.

Estimated Timelines




Figure 5-1: Estimated Timeline for a Water/Wastewater System Expansion and/or Upgrade

6 Capacity Assessment

The capacity assessment for the Woodville DWS has been done using the following phased approach:

- **Phase-1:** Estimate possible development up to 80% of the rated capacity. At 80% capacity, the City must assess what to do next as per MECP guidelines. This could include a variety of options including “do nothing” (i.e. no further growth) or complete a municipal Class EA if increased capacity beyond the approved rated capacity to accommodate any future planned growth is needed.
- **Phase-2:** Estimate any potential growth that could be handled between 80% and 100% capacity, while the existing treatment system is upgraded.

It should be noted that this assessment has been completed from the water quantity (spare capacity the current system have to produce water up to its rated capacity) standpoint but does not factor in any hydraulic limitation this system may have (i.e. will additional pressure zone be required, does the existing linear infrastructure need to be expanded/upgraded to meet the future forecasted flows, etc.).

Using the historical average treated water flow (174 m³/day) as baseline water demand, there is approximately 296 m³/day available to accommodate growth/development before reaching the 80% rated capacity (470 m³/day) mark and 414 m³/day available before reaching the full rated capacity (588 m³/day). Based on the current unused capacity of the existing system, the Woodville DWS can accommodate the following growth/development options.

6.1 Potential Residential Development (Scenario 1)

Scenario 1 projects a conservative residential development based on single house subdivisions. Based on the standards shown in Table 5-1; the system has capacity to accommodate an estimated additional 60 single houses before reaching 80% of the rated capacity. An estimated additional 20 single houses would then bring the capacity up from 80% to the full rated capacity. Table 6-1 shows the forecasted water demand in this scenario.

Table 6-1: Potential Conservative Residential Development (Scenario 1).

PROPOSED DEVELOPMENT	UNITS TYPE	NUMBER OF UNITS	PEOPLE PER UNIT	PER-CAPITA WATER CONSUMPTION	AVG. DAY DEMAND	MAXIMUM DAY FACTOR (2.75)
Residential Development Phase 1 (up to 80% rated Capacity)	Single House	60	4.0	450 L/cap-d	108 m ³ /day	297 m ³ /day
Residential Development Phase 2 (up to Rated Capacity)	Single House	20	4.0	450 L/cap-d	36 m ³ /day	99 m ³ /day
Total		80				396 m³/day

As indicated previously, caution should be applied as the 80% of rated capacity criteria is reached. Once the first 60 or so single houses are built and occupied, the water demands should be re-assessed to determine more accurate water flows and spare capacity before approving the construction of additional houses.

In addition, once the 80% of rated capacity limit is reached, the municipality should start investigating any needed expansion/upgrades to the existing system based on development plans. Typically, to expand/upgrade a system above and beyond the existing rated capacity, a full Municipal Class Environmental Assessment¹⁰ (most likely a schedule C) is required.

Despite the 20 new houses that could theoretically be built to reach the full rated capacity (588 m³/day), it is recommended that the rated capacity of the facility not be maxed out until the new upgraded WTP facility is fully functional. Operating at full rated capacity increases the risk for water shortages should

¹⁰Municipal Engineers Association Municipal Class Environmental Assessment (MCEA):
<https://municipalclassea.ca/manual/index.html>

there be a failure in the system and also limits the operational flexibility of the system to manage planned standard operating procedures such as flushing, maintenance and/or repair operations, etc. and unplanned events. Figure 6-1 shows the two-tiered approach for scenario 1.



Figure 6-1: Two-phased Approach for Conservative Scenario 1 (80 single houses)

6.2 Potential Residential Development (Scenario 2)

Scenario 2 projects also a conservative residential development based on a combination of residential building (condominiums) and single house subdivisions. Based on the standards shown in Table 5-1, the system is capable of accommodating an additional 110-unit residential complex (condominium building) before reaching 80% of the rated capacity and then additional 20 single houses before reaching the full rated capacity. Table 6-1 shows the forecasted water demand in this scenario.

Table 6-2: Potential Conservative Residential Development (Scenario 2).

PHASE	PROPOSED DEVELOPMENT	UNITS TYPE	NUMBER OF UNITS	PEOPLE PER UNIT	PER-CAPITA WATER COMSUPTION	AVG. DAY DEMAND	MAXIMUM DAY FACTOR (2.75)
Phase 1 (up to 80% rated Capacity)	Residential complex (Condominium building)	40% will be 2-bdrn units.	44	3	450 L/cap-d	59 m³/day	163 m³/day
		40% will be 1-bdrn units.	44	2	450 L/cap-d	40 m³/day	109 m³/day
		20% will bachelors units.	22	1	450 L/cap-d	10 m³/day	27 m³/day
	Total Phase 1		110			109 m3/day	299 m³/day
Phase 2 (up to Rated Capacity)	Residential Development	Single House	20	4.0	450 L/cap-d	36 m³/day	99 m³/day
	Total Phase 2		20			36 m³/day	99 m³/day
Total							413 m³/day

As indicated previously, caution should be applied as the 80% of rated capacity criteria is reached. Once the 110-units residential complex (condominium) is built and occupied, the water flows should be re-assessed to determine more accurate water flows and how much spare capacity is left before reaching the maximum rated capacity of the DWS.

In addition, once the 80% of rated capacity limit is reached, the municipality should start investigating any needed expansion/upgrades to the existing system based on development plans. Typically, to expand/upgrade any given system above and beyond the existing rated capacity, a full Municipal Class Environmental Assessment¹¹ (most likely a schedule C) is required.

Despite the 20 new houses that could theoretically be built to reach the full rated capacity (588 m³/day), it is recommended that the existing capacity of the facility not be maxed out until the new upgraded WTP facility is fully functional. Operating at full rated capacity increases the risk for water shortages should there be a failure in the system and also limits the operational flexibility of the system to manage planned standard operating procedures such as flushing, maintenance and/or repair operations, etc. and unplanned events Figure 6-2 shows the two-tiered approach for scenario 2.

¹¹Municipal Engineers Association Municipal Class Environmental Assessment (MCEA):
<https://municipalclassea.ca/manual/index.html>




Figure 6-2: Two-tiered approach for scenario 2 (110-units Condominium + 20 Single houses)

7 Conclusions

Upon completion of this assessment the following can be concluded:

1. In terms of Flow (Operations Standpoint)
 - a. Based on the flow testing results, it appears the Woodville WTP facility is capable of processing water up to the maximum flow (rated capacity) for which this facility was designed (6.8 L/s). This could be achieved using either one well pump at the time or both well-pumps combined up to the maximum water taking allowed in the PTTW and using either one treatment train or both trains at once.
 - b. Operational bottleneck and/or potentially compliance issues may be faced if the supply shortage of 1-micron absolute ANSI/NFS 53 certified cartridge filters is not resolved.
2. In terms of Capacity (Future Growth/Development)
 - a. Based on a review of the historical raw and treated flows for the last five years (2017-2021), the Woodville DWS is operating at approximately 29% of the rated capacity (588 m³/day).

- b. Without the need for expansion/upgrades, the existing DWS has approximately **296 m³/day** up to 80% rated capacity threshold (470 m³/day) and approximately **414 m³/day** up to full rated capacity (588 m³/day) to accommodate a moderate growth/development in the community.
- c. In absence of a development plan, two conservative growth/development scenarios 1 and 2 were developed for illustration purpose only as they not necessarily represent the Municipality's desires and/or priorities.
- d. Despite the above, growth/development should not occur up to the full rated capacity (588 m³/day); otherwise the existing DWS will have very limited operational flexibility (if none) thus at risk of failure and/or potential compliance issues.

8 Recommendations

Based on the outcome of this assessment, any growth/development completed by the City should be implemented in a phased-approach as follows:

1. Phase-1 Development (up to 80% rated capacity):
 - a. Proceed with moderate growth/development up to 80% capacity (daily flows up to 470 m³/day).
 - b. Once completed and fully occupied (inhabited), reassess current demand/flows and compare it against the available facility's capacity up to the full rated capacity of 588 m³/day).
 - c. Assess whether additional growth/development is possible/feasible.
2. Once Phase-1 is completed (up to 80% rated capacity); the City should take actions to expand/upgrade the existing DWS to accommodate future growth/development above and beyond the existing rated capacity. Most likely, Municipal Class EA (Schedule C) will be required.
3. Phase-2 Development (up to rated capacity): Although theoretically there is capacity for limited growth/development up to the full rated capacity (588 m³/day), it is recommended that once the 80% rated capacity flows is reached no further development is completed until the existing DWS is expanded/upgraded. **It is strongly recommended that phase-2 development does not max-out the DWS capacity since it may increase the risk for water shortages should there be a failure in the system and also limits the operational flexibility of the system to manage planned standard operating procedures (i.e. flushing, etc.). More importantly, it could also cause compliance issues with the regulatory requirements in place.**

APPENDIX A


Flow Testing Schedule

TREATMENT TRAIN	WELL	FLOW INCREMENT (0.5 L/S INCREMENT)	TEST DURATION	MONITORING PARAMETERS
Treatment Train # 1	Well 1	5 l/s	1 hour	Water Quantity - Raw water flow from both wells (Well 1 and 2) - Treated water flow (flowmeter treated water) Filter Performance - Turbidity at the filters - Pressure at the filters Residual Chlorine - Chlorine residual before the contact chamber - Chlorine residual at monitoring station at the end of the chlorine contact Chamber
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
	Well 2	5 L/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
	Well 1 + Well 2	5 l/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
Treatment Train # 2	Well 1	5 l/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
	Well 2	5 L/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
	Well 1 + Well 2	5 l/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
Treatment Train 1 & 2 together	Well 1	5 l/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
	Well 2	5 L/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	
	Well 1 + Well 2	5 l/s	1 hour	
		5.5L/s	1 hour	
		6 L/s	1 hour	
		6.5 L/s	1 hour	
		6.8 L/s	1 hour	

APPENDIX B


Flow Testing Results

Woodville DWS- April 26, 2022- Test #1- Well 2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.001	0.002	\\OWHISTORIAN1\InS	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST		m	2.100	2.800	\\OWHISTORIAN1\InS	0.00.00.000			2.619	2.239
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	3.200	6.300	\\OWHISTORIAN1\InS	0.00.00.000			5.067	4.997
☒ WoodvilleW	Well 2 Level	4	OWHIST		m	7.500	8.100	\\OWHISTORIAN1\InS	0.00.00.000			7.978	7.620
☐ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST		NTU	0.737	0.748	\\OWHISTORIAN1\InS	0.00.00.000			0.740	0.740
☐ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	0.100	\\OWHISTORIAN1\InS	0.00.00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST		NTU	0.030	0.070	\\OWHISTORIAN1\InS	0.00.00.000			0.038	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	30.000	100.000	\\OWHISTORIAN1\InS	0.00.00.000			77.420	73.953
☒ WoodvilleW	Discharge Chlorine	9	OWHIST		mg/L	1.000	5.000	\\OWHISTORIAN1\InS	0.00.00.000			2.423	3.424
☒ WoodvilleW	Discharge Chlorine	10	OWHIST		mg/L	2.250	2.300	\\OWHISTORIAN1\InS	0.00.00.000			2.295	2.273
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	3.000	7.000	\\OWHISTORIAN1\InS	0.00.00.000			5.042	4.961

Woodville DWS- April 26, 2022- Test #2- Well 2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.001	0.002	\OWHISTORIAN1\mS	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST		m	2.100	2.800	\OWHISTORIAN1\mS	0.00.00.000			2.619	2.239
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	3.200	6.300	\OWHISTORIAN1\mS	0.00.00.000			5.067	4.997
☒ WoodvilleW	Well 2 Level	4	OWHIST		m	7.500	8.100	\OWHISTORIAN1\mS	0.00.00.000			7.978	7.620
☐ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST		NTU	0.737	0.748	\OWHISTORIAN1\mS	0.00.00.000			0.740	0.740
☐ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	0.100	\OWHISTORIAN1\mS	0.00.00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST		NTU	0.030	0.070	\OWHISTORIAN1\mS	0.00.00.000			0.038	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	30.000	100.000	\OWHISTORIAN1\mS	0.00.00.000			77.420	73.953
☒ WoodvilleW	Discharge Chlorine	9	OWHIST		mg/L	1.000	5.000	\OWHISTORIAN1\mS	0.00.00.000			2.423	3.424
☒ WoodvilleW	Distribution Chlorine	10	OWHIST		mg/L	2.250	2.300	\OWHISTORIAN1\mS	0.00.00.000			2.295	2.273
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	3.000	7.000	\OWHISTORIAN1\mS	0.00.00.000			5.042	4.961

Woodville DWS- April 26, 2022- Test #3- Well 2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.001	0.002	\OWHISTORIAN1\mS	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST		m	2.100	2.800	\OWHISTORIAN1\mS	0.00.00.000			2.619	2.239
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	3.200	6.300	\OWHISTORIAN1\mS	0.00.00.000			5.067	4.997
☒ WoodvilleW	Well 2 Level	4	OWHIST		m	7.500	8.100	\OWHISTORIAN1\mS	0.00.00.000			7.978	7.620
☐ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST		NTU	0.737	0.748	\OWHISTORIAN1\mS	0.00.00.000			0.740	0.740
☐ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	0.100	\OWHISTORIAN1\mS	0.00.00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST		NTU	0.030	0.070	\OWHISTORIAN1\mS	0.00.00.000			0.038	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	30.000	100.000	\OWHISTORIAN1\mS	0.00.00.000			77.420	73.553
☒ WoodvilleW	Discharge Chlorine	9	OWHIST		mg/L	1.000	5.000	\OWHISTORIAN1\mS	0.00.00.000			2.423	3.424
☒ WoodvilleW	Distribution Chlorine	10	OWHIST		mg/L	2.250	2.300	\OWHISTORIAN1\mS	0.00.00.000			2.295	2.273
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	3.000	7.000	\OWHISTORIAN1\mS	0.00.00.000			5.042	4.961

Woodville DWS- April 26, 2022- Test #4- Well 2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.001	0.002	\OWHISTORIAN1\InS	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST		m	2.100	2.800	\OWHISTORIAN1\InS	0.00.00.000			2.619	2.239
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	3.200	6.300	\OWHISTORIAN1\InS	0.00.00.000			5.067	4.997
☒ WoodvilleW	Well 2 Level	4	OWHIST		m	7.500	8.100	\OWHISTORIAN1\InS	0.00.00.000			7.978	7.620
☐ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST		NTU	0.737	0.748	\OWHISTORIAN1\InS	0.00.00.000			0.740	0.740
☐ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	0.100	\OWHISTORIAN1\InS	0.00.00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST		NTU	0.030	0.070	\OWHISTORIAN1\InS	0.00.00.000			0.038	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	30.000	100.000	\OWHISTORIAN1\InS	0.00.00.000			77.420	73.953
☒ WoodvilleW	Discharge Chlorine	9	OWHIST		mg/L	1.000	5.000	\OWHISTORIAN1\InS	0.00.00.000			2.423	3.424
☒ WoodvilleW	Distribution Chlorine	10	OWHIST		mg/L	2.260	2.300	\OWHISTORIAN1\InS	0.00.00.000			2.295	2.273
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	3.000	7.000	\OWHISTORIAN1\InS	0.00.00.000			5.042	4.961

Woodville DWS- April 26, 2022- Test #5- Well 2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.001	0.002	\\OWHISTORIAN1\InS	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2.100	2.800	\\OWHISTORIAN1\InS	0.00.00.000			2.619	2.239
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	3.200	6.300	\\OWHISTORIAN1\InS	0.00.00.000			5.067	4.997
☒ WoodvilleW	Well 2 Level	4	OWHIST	Blue	m	7.500	8.100	\\OWHISTORIAN1\InS	0.00.00.000			7.978	7.620
☐ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Orange	NTU	0.737	0.748	\\OWHISTORIAN1\InS	0.00.00.000			0.740	0.740
☐ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	0.100	\\OWHISTORIAN1\InS	0.00.00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Purple	NTU	0.030	0.070	\\OWHISTORIAN1\InS	0.00.00.000			0.038	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	30.000	100.000	\\OWHISTORIAN1\InS	0.00.00.000			77.420	73.953
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Dark Blue	mg/L	1.000	5.000	\\OWHISTORIAN1\InS	0.00.00.000			2.423	3.424
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Light Green	mg/L	2.260	2.300	\\OWHISTORIAN1\InS	0.00.00.000			2.295	2.273
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Blue	l/s	3.000	7.000	\\OWHISTORIAN1\InS	0.00.00.000			5.042	4.961

Woodville DWS- April 26, 2022- Test #6- Well 1- Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\\OWHISTORIAN1\h5	0:00:00.000			4.984	5.009
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2.200	2.600	\\OWHISTORIAN1\h5	0:00:00.000			2.300	2.412
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	7.000	\\OWHISTORIAN1\h5	0:00:00.000			0.002	0.002
☒ WoodvilleW	Well 2 Level	4	OWHIST	Purple	m	7.400	8.200	\\OWHISTORIAN1\h5	0:00:00.000			7.984	8.107
☒ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Orange	NTU	1.760	2.010	\\OWHISTORIAN1\h5	0:00:00.000			2.000	2.000
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	0.100	\\OWHISTORIAN1\h5	0:00:00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Pink	NTU	0.030	0.130	\\OWHISTORIAN1\h5	0:00:00.000			0.040	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	30.000	110.000	\\OWHISTORIAN1\h5	0:00:00.000			81.008	88.527
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Light Green	mg/L	2.600	4.100	\\OWHISTORIAN1\h5	0:00:00.000			3.595	3.886
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Light Blue	mg/L	2.344	2.365	\\OWHISTORIAN1\h5	0:00:00.000			2.364	2.345
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Green	l/s	1.000	7.000	\\OWHISTORIAN1\h5	0:00:00.000			4.979	5.010

Woodville DWS- April 26, 2022- Test #7- Well 1- Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\\OWHISTORIAN1\hS	0.00.00.000			4.984	5.009
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2.200	2.600	\\OWHISTORIAN1\hS	0.00.00.000			2.300	2.412
☐ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	7.000	\\OWHISTORIAN1\hS	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 2 Level	4	OWHIST	Purple	m	7.400	8.200	\\OWHISTORIAN1\hS	0.00.00.000			7.984	8.107
☒ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Light Blue	NTU	1.760	2.010	\\OWHISTORIAN1\hS	0.00.00.000			2.000	2.000
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Dark Blue	kPa	0.000	0.100	\\OWHISTORIAN1\hS	0.00.00.000			0.000	0.000
☐ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Brown	NTU	0.030	0.130	\\OWHISTORIAN1\hS	0.00.00.000			0.040	0.036
☐ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Grey	kPa	30.000	110.000	\\OWHISTORIAN1\hS	0.00.00.000			81.008	88.527
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Yellow	mg/L	2.600	4.100	\\OWHISTORIAN1\hS	0.00.00.000			3.555	3.886
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Light Green	mg/L	2.344	2.365	\\OWHISTORIAN1\hS	0.00.00.000			2.364	2.345
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Green	l/s	1.000	7.000	\\OWHISTORIAN1\hS	0.00.00.000			4.979	5.010

Woodville DWS- April 27, 2022- Test #8- Well 1- Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\\OWHISTORIAN1\h1s	0:00:00.000			4.984	5.009
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2.200	2.600	\\OWHISTORIAN1\h2s	0:00:00.000			2.300	2.412
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	7.000	\\OWHISTORIAN1\h3s	0:00:00.000			0.002	0.002
☒ WoodvilleW	Well 2 Level	4	OWHIST	Blue	m	7.400	8.200	\\OWHISTORIAN1\h4s	0:00:00.000			7.984	8.107
☒ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Orange	NTU	1.760	2.010	\\OWHISTORIAN1\h5s	0:00:00.000			2.000	2.000
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	0.100	\\OWHISTORIAN1\h6s	0:00:00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Purple	NTU	0.030	0.130	\\OWHISTORIAN1\h7s	0:00:00.000			0.040	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	30.000	110.000	\\OWHISTORIAN1\h8s	0:00:00.000			81.008	88.527
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Light Green	mg/L	2.600	4.100	\\OWHISTORIAN1\h9s	0:00:00.000			3.595	3.886
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Dark Green	mg/L	2.344	2.365	\\OWHISTORIAN1\h10s	0:00:00.000			2.364	2.345
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Blue	l/s	1.000	7.000	\\OWHISTORIAN1\h12s	0:00:00.000			4.979	5.010

Woodville DWS- April 27, 2022- Test #9- Well 1- Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\\OWHISTORIAN1\hS	0.00.00.000			4.984	5.009
☒ WoodvllW	Well 1 Level	2	OWHIST	Red	m	2.200	2.600	\\OWHISTORIAN1\hS	0.00.00.000			2.300	2.412
☐ WoodvllW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	7.000	\\OWHISTORIAN1\hS	0.00.00.000			0.002	0.002
☐ WoodvllW	Well 2 Level	4	OWHIST	Purple	m	7.400	8.200	\\OWHISTORIAN1\hS	0.00.00.000			7.984	8.107
☒ WoodvllW	Filter 1 and 2 Turbidity	5	OWHIST	Orange	NTU	1.760	2.010	\\OWHISTORIAN1\hS	0.00.00.000			2.000	2.000
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Brown	kPa	0.000	0.100	\\OWHISTORIAN1\hS	0.00.00.000			0.000	0.000
☐ WoodvllW	Filter 3 and 4 Turbidity	7	OWHIST	Pink	NTU	0.030	0.130	\\OWHISTORIAN1\hS	0.00.00.000			0.040	0.036
☐ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Grey	kPa	30.000	110.000	\\OWHISTORIAN1\hS	0.00.00.000			81.008	88.527
☒ WoodvllW	Discharge Chlorine	9	OWHIST	Light Blue	mg/L	2.600	4.100	\\OWHISTORIAN1\hS	0.00.00.000			3.595	3.886
☒ WoodvllW	Distribution Chlorine	10	OWHIST	Light Green	mg/L	2.344	2.365	\\OWHISTORIAN1\hS	0.00.00.000			2.364	2.345
☒ WoodvllW	Discharge Flow	12	OWHIST	Dark Blue	l/s	1.000	7.000	\\OWHISTORIAN1\hS	0.00.00.000			4.979	5.010

Woodville DWS- April 27, 2022- Test #10- Well 1- Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.000	6.000	\\OWHISTORIAN1\InS	0:00:00.000			4.984	5.009
☒ WoodvilleW	Well 1 Level	2	OWHIST		m	2.200	2.600	\\OWHISTORIAN1\InS	0:00:00.000			2.300	2.412
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	0.000	7.000	\\OWHISTORIAN1\InS	0:00:00.000			0.002	0.002
☒ WoodvilleW	Well 2 Level	4	OWHIST		m	7.400	8.200	\\OWHISTORIAN1\InS	0:00:00.000			7.984	8.107
☒ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST		NTU	1.760	2.010	\\OWHISTORIAN1\InS	0:00:00.000			2.000	2.000
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	0.100	\\OWHISTORIAN1\InS	0:00:00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST		NTU	0.030	0.130	\\OWHISTORIAN1\InS	0:00:00.000			0.040	0.036
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	30.000	110.000	\\OWHISTORIAN1\InS	0:00:00.000			81.008	88.527
☒ WoodvilleW	Discharge Chlorine	9	OWHIST		mg/L	2.600	4.100	\\OWHISTORIAN1\InS	0:00:00.000			3.595	3.886
☒ WoodvilleW	Distribution Chlorine	10	OWHIST		mg/L	2.344	2.365	\\OWHISTORIAN1\InS	0:00:00.000			2.364	2.345
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	1.000	7.000	\\OWHISTORIAN1\InS	0:00:00.000			4.979	5.010

Woodville DWS- April 27, 2022- Test #11- Well 1&2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	1.000	7.000	\\OWHISTORIAN1\h1s	0.00.00.000			2.422	2.500
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2.200	2.700	\\OWHISTORIAN1\h1s	0.00.00.000			2.579	2.450
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	4.000	\\OWHISTORIAN1\h1s	0.00.00.000			2.597	2.525
☒ WoodvilleW	Well 2 Level	4	OWHIST	Yellow	m	7.800	8.300	\\OWHISTORIAN1\h1s	0.00.00.000			8.032	7.892
☐ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Purple	NTU	0.900	2.100	\\OWHISTORIAN1\h1s	0.00.00.000			1.326	1.320
☐ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Brown	kPa	0.000	0.100	\\OWHISTORIAN1\h1s	0.00.00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Pink	NTU	0.037	0.059	\\OWHISTORIAN1\h1s	0.00.00.000			0.038	0.038
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Grey	kPa	40.000	170.000	\\OWHISTORIAN1\h1s	0.00.00.000			138.327	134.482
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Cyan	mg/L	2.900	4.400	\\OWHISTORIAN1\h1s	0.00.00.000			3.565	3.036
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Magenta	mg/L	2.100	2.500	\\OWHISTORIAN1\h1s	0.00.00.000			2.145	2.464
☒ WoodvilleW	Discharge Flow	12	OWHIST	Dark Blue	l/s	2.000	7.000	\\OWHISTORIAN1\h1s	0.00.00.000			5.193	5.008

Woodville DWS- April 27, 2022- Test #12- Well 1&2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	1 000	7 000	\\OWHISTORIAN1\InS	0 00 00 000			2 422	2 500
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2 200	2 700	\\OWHISTORIAN1\InS	0 00 00 000			2 579	2 450
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0 000	4 000	\\OWHISTORIAN1\InS	0 00 00 000			2 557	2 525
☒ WoodvilleW	Well 2 Level	4	OWHIST	Cyan	m	7 800	8 300	\\OWHISTORIAN1\InS	0 00 00 000			8 032	7 892
☒ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Magenta	NTU	0 900	2 100	\\OWHISTORIAN1\InS	0 00 00 000			1 326	1 320
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0 000	0 100	\\OWHISTORIAN1\InS	0 00 00 000			0 000	0 000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Purple	NTU	0 037	0 059	\\OWHISTORIAN1\InS	0 00 00 000			0 038	0 038
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Orange	kPa	40 000	170 000	\\OWHISTORIAN1\InS	0 00 00 000			138 327	134 482
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Light Blue	mg/L	2 900	4 400	\\OWHISTORIAN1\InS	0 00 00 000			3 565	3 036
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Dark Blue	mg/L	2 100	2 500	\\OWHISTORIAN1\InS	0 00 00 000			2 145	2 464
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Green	l/s	2 000	7 000	\\OWHISTORIAN1\InS	0 00 00 000			5 193	5 008

Woodville DWS- April 27, 2022- Test #13- Well 1&2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Red	l/s	1.000	7.000	\\OWHISTORIAN1\hS	0:00:00.000			2.422	2.500
☒ WoodvilleW	Well 1 Level	2	OWHIST	Blue	m	2.200	2.700	\\OWHISTORIAN1\hS	0:00:00.000			2.579	2.450
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	4.000	\\OWHISTORIAN1\hS	0:00:00.000			2.597	2.525
☒ WoodvilleW	Well 2 Level	4	OWHIST	Cyan	m	7.800	8.300	\\OWHISTORIAN1\hS	0:00:00.000			8.032	7.892
☐ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Magenta	NTU	0.900	2.100	\\OWHISTORIAN1\hS	0:00:00.000			1.326	1.320
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	0.100	\\OWHISTORIAN1\hS	0:00:00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Orange	NTU	0.037	0.059	\\OWHISTORIAN1\hS	0:00:00.000			0.038	0.038
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Purple	kPa	40.000	170.000	\\OWHISTORIAN1\hS	0:00:00.000			138.327	134.482
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Brown	mg/L	2.900	4.400	\\OWHISTORIAN1\hS	0:00:00.000			3.565	3.036
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Grey	mg/L	2.100	2.500	\\OWHISTORIAN1\hS	0:00:00.000			2.145	2.464
☒ WoodvilleW	Discharge Flow	12	OWHIST	Pink	l/s	2.000	7.000	\\OWHISTORIAN1\hS	0:00:00.000			5.193	5.008

Woodville DWS- April 27, 2022- Test #14- Well 1&2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	1.000	7.000	\\OWHISTORIAN1\InS	0:00:00.000			2.422	2.500
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2.200	2.700	\\OWHISTORIAN1\InS	0:00:00.000			2.579	2.450
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	4.000	\\OWHISTORIAN1\InS	0:00:00.000			2.597	2.525
☒ WoodvilleW	Well 2 Level	4	OWHIST	Purple	m	7.800	8.300	\\OWHISTORIAN1\InS	0:00:00.000			8.032	7.892
☒ WoodvilleW	Filter 1 and 2 Turbidity	5	OWHIST	Orange	NTU	0.900	2.100	\\OWHISTORIAN1\InS	0:00:00.000			1.326	1.320
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	0.100	\\OWHISTORIAN1\InS	0:00:00.000			0.000	0.000
☒ WoodvilleW	Filter 3 and 4 Turbidity	7	OWHIST	Brown	NTU	0.037	0.059	\\OWHISTORIAN1\InS	0:00:00.000			0.038	0.038
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Pink	kPa	40.000	170.000	\\OWHISTORIAN1\InS	0:00:00.000			138.327	134.482
☒ WoodvilleW	Discharge Chlorine	9	OWHIST	Grey	mg/L	2.900	4.400	\\OWHISTORIAN1\InS	0:00:00.000			3.565	3.036
☒ WoodvilleW	Distribution Chlorine	10	OWHIST	Light Blue	mg/L	2.100	2.500	\\OWHISTORIAN1\InS	0:00:00.000			2.145	2.464
☒ WoodvilleW	Discharge Flow	12	OWHIST	Dark Blue	l/s	2.000	7.000	\\OWHISTORIAN1\InS	0:00:00.000			5.193	5.008

Woodville DWS- April 28, 2022- Test #15- Well 1&2- Train #2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST	Red	l/s	1.000	7.000	\\OWHISTORIAN1\hS	0.00.00.000			2.422	2.500
☒ WoodvllW	Well 1 Level	2	OWHIST	Blue	m	2.200	2.700	\\OWHISTORIAN1\hS	0.00.00.000			2.579	2.450
☒ WoodvllW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	4.000	\\OWHISTORIAN1\hS	0.00.00.000			2.597	2.525
☒ WoodvllW	Well 2 Level	4	OWHIST	Yellow	m	7.800	8.300	\\OWHISTORIAN1\hS	0.00.00.000			8.032	7.892
☒ WoodvllW	Filter 1 and 2 Turbidity	5	OWHIST	Purple	NTU	0.900	2.100	\\OWHISTORIAN1\hS	0.00.00.000			1.326	1.320
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Orange	kPa	0.000	0.100	\\OWHISTORIAN1\hS	0.00.00.000			0.000	0.000
☒ WoodvllW	Filter 3 and 4 Turbidity	7	OWHIST	Light Blue	NTU	0.037	0.059	\\OWHISTORIAN1\hS	0.00.00.000			0.038	0.038
☒ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Dark Blue	kPa	40.000	170.000	\\OWHISTORIAN1\hS	0.00.00.000			138.327	134.482
☒ WoodvllW	Discharge Chlorine	9	OWHIST	Light Green	mg/L	2.900	4.400	\\OWHISTORIAN1\hS	0.00.00.000			3.565	3.036
☒ WoodvllW	Distribution Chlorine	10	OWHIST	Dark Green	mg/L	2.100	2.500	\\OWHISTORIAN1\hS	0.00.00.000			2.145	2.464
☒ WoodvllW	Discharge Flow	12	OWHIST	Dark Green	l/s	2.000	7.000	\\OWHISTORIAN1\hS	0.00.00.000			5.193	5.008

Woodville DWS- April 28, 2022- Test #16- Well 1- Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\\OWHISTORIAN1\WS	0:00:00.000			5.006	4.992
☒ WoodvllW	Well 1 Level	2	OWHIST	Red	m	2.300	3.100	\\OWHISTORIAN1\WS	0:00:00.000			2.577	2.432
☐ WoodvllW	Well 2 Flow	3	OWHIST	Green	l/s	0.002	0.003	\\OWHISTORIAN1\WS	0:00:00.000			0.002	0.002
☐ WoodvllW	Well 2 Level	5	OWHIST	Orange	m	8.000	8.700	\\OWHISTORIAN1\WS	0:00:00.000			8.235	8.099
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	12.000	\\OWHISTORIAN1\WS	0:00:00.000			5.339	5.184
☒ WoodvllW	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.000	2.100	\\OWHISTORIAN1\WS	0:00:00.000			0.036	0.034
☐ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.100	0.140	\\OWHISTORIAN1\WS	0:00:00.000			0.120	0.120
☐ WoodvllW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.039	0.040	\\OWHISTORIAN1\WS	0:00:00.000			0.040	0.040
☒ WoodvllW	Discharge Chlorine	10	OWHIST	Light Green	mg/L	2.400	5.100	\\OWHISTORIAN1\WS	0:00:00.000			2.695	2.895
☒ WoodvllW	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.340	2.440	\\OWHISTORIAN1\WS	0:00:00.000			2.354	2.423
☒ WoodvllW	Discharge Flow	12	OWHIST	Light Blue	l/s	0.000	7.000	\\OWHISTORIAN1\WS	0:00:00.000			4.995	5.000

Woodville DWS- April 28, 2022- Test #17- Well 1 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\\OWHISTORIAN1\IHS	0:00:00.000			5.006	4.992
☒ WoodvllW	Well 1 Level	2	OWHIST	Red	m	2.300	3.100	\\OWHISTORIAN1\IHS	0:00:00.000			2.577	2.432
☒ WoodvllW	Well 2 Flow	3	OWHIST	Yellow	l/s	0.002	0.003	\\OWHISTORIAN1\IHS	0:00:00.000			0.002	0.002
☒ WoodvllW	Well 2 Level	5	OWHIST	Purple	m	8.000	8.700	\\OWHISTORIAN1\IHS	0:00:00.000			8.235	8.089
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Green	kPa	0.000	12.000	\\OWHISTORIAN1\IHS	0:00:00.000			5.339	5.184
☒ WoodvllW	Filter 1 and 2 Turbidity	7	OWHIST	Grey	NTU	0.000	2.100	\\OWHISTORIAN1\IHS	0:00:00.000			0.036	0.034
☒ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.100	0.140	\\OWHISTORIAN1\IHS	0:00:00.000			0.120	0.120
☒ WoodvllW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.039	0.040	\\OWHISTORIAN1\IHS	0:00:00.000			0.040	0.040
☒ WoodvllW	Discharge Chlorine	10	OWHIST	Magenta	mg/L	2.400	5.100	\\OWHISTORIAN1\IHS	0:00:00.000			2.695	2.895
☒ WoodvllW	Distribution Chlorine	11	OWHIST	Purple	mg/L	2.340	2.440	\\OWHISTORIAN1\IHS	0:00:00.000			2.354	2.423
☒ WoodvllW	Discharge Flow	12	OWHIST	Black	l/s	0.000	7.000	\\OWHISTORIAN1\IHS	0:00:00.000			4.995	5.000

Woodville DWS- April 28, 2022- Test #18- Well 1 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\\OWHISTORIAN1\mks	0:00:00.000			5.006	4.992
☒ WoodvllW	Well 1 Level	2	OWHIST	Red	m	2.300	3.100	\\OWHISTORIAN1\mks	0:00:00.000			2.577	2.432
☐ WoodvllW	Well 2 Flow	3	OWHIST	Yellow	l/s	0.002	0.003	\\OWHISTORIAN1\mks	0:00:00.000			0.002	0.002
☐ WoodvllW	Well 2 Level	5	OWHIST	Green	m	8.000	8.700	\\OWHISTORIAN1\mks	0:00:00.000			8.235	8.099
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Orange	kPa	0.000	12.000	\\OWHISTORIAN1\mks	0:00:00.000			5.339	5.184
☒ WoodvllW	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.000	2.100	\\OWHISTORIAN1\mks	0:00:00.000			0.036	0.034
☐ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Brown	kPa	0.100	0.140	\\OWHISTORIAN1\mks	0:00:00.000			0.120	0.120
☐ WoodvllW	Filter 3 and 4 Turbidity	9	OWHIST	Pink	NTU	0.039	0.040	\\OWHISTORIAN1\mks	0:00:00.000			0.040	0.040
☒ WoodvllW	Discharge Chlorine	10	OWHIST	Grey	mg/L	2.400	5.100	\\OWHISTORIAN1\mks	0:00:00.000			2.695	2.895
☒ WoodvllW	Distribution Chlorine	11	OWHIST	Light Blue	mg/L	2.340	2.440	\\OWHISTORIAN1\mks	0:00:00.000			2.354	2.423
☒ WoodvllW	Discharge Flow	12	OWHIST	Dark Blue	l/s	0.000	7.000	\\OWHISTORIAN1\mks	0:00:00.000			4.995	5.000

Woodville DWS- April 28, 2022- Test #19- Well 1 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.000	6.000	\\OWHISTORIAN1\WS	0:00:00.000			5.006	4.992
☒ WoodvilleW	Well 1 Level	2	OWHIST		m	2.300	3.100	\\OWHISTORIAN1\WS	0:00:00.000			2.577	2.432
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	0.002	0.003	\\OWHISTORIAN1\WS	0:00:00.000			0.002	0.002
☒ WoodvilleW	Well 2 Level	5	OWHIST		m	8.000	8.700	\\OWHISTORIAN1\WS	0:00:00.000			8.235	8.099
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	12.000	\\OWHISTORIAN1\WS	0:00:00.000			5.339	5.184
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST		NTU	0.000	2.100	\\OWHISTORIAN1\WS	0:00:00.000			0.036	0.034
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	0.100	0.140	\\OWHISTORIAN1\WS	0:00:00.000			0.120	0.120
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST		NTU	0.039	0.040	\\OWHISTORIAN1\WS	0:00:00.000			0.040	0.040
☒ WoodvilleW	Discharge Chlorine	10	OWHIST		mg/L	2.400	5.100	\\OWHISTORIAN1\WS	0:00:00.000			2.655	2.895
☒ WoodvilleW	Distribution Chlorine	11	OWHIST		mg/L	2.340	2.440	\\OWHISTORIAN1\WS	0:00:00.000			2.354	2.423
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	0.000	7.000	\\OWHISTORIAN1\WS	0:00:00.000			4.955	5.000

Woodville DWS- April 28, 2022- Test #20- Well 1 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	6.000	\OWHISTORIAN\WS	0:00:00.000			5.006	4.992
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	2.300	3.100	\OWHISTORIAN\WS	0:00:00.000			2.577	2.432
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.002	0.003	\OWHISTORIAN\WS	0:00:00.000			0.002	0.002
☒ WoodvilleW	Well 2 Level	5	OWHIST	Orange	m	8.000	8.700	\OWHISTORIAN\WS	0:00:00.000			8.235	8.099
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	12.000	\OWHISTORIAN\WS	0:00:00.000			5.339	5.184
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.000	2.100	\OWHISTORIAN\WS	0:00:00.000			0.036	0.034
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.100	0.140	\OWHISTORIAN\WS	0:00:00.000			0.120	0.120
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.039	0.040	\OWHISTORIAN\WS	0:00:00.000			0.040	0.040
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Grey	mg/L	2.400	5.100	\OWHISTORIAN\WS	0:00:00.000			2.695	2.095
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Brown	mg/L	2.340	2.440	\OWHISTORIAN\WS	0:00:00.000			2.354	2.423
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Green	l/s	0.000	7.000	\OWHISTORIAN\WS	0:00:00.000			4.995	5.000

Woodville DWS- April 28, 2022- Test #21- Well 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvBW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	8.000	\\OWHISTORIAN1\hns	0.00.00.000			0.002	0.002
☐ WoodvBW	Well 1 Level	2	OWHIST	Red	m	1.600	2.300	\\OWHISTORIAN1\hns	0.00.00.000			1.797	1.951
☒ WoodvBW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	6.000	\\OWHISTORIAN1\hns	0.00.00.000			5.443	4.995
☒ WoodvBW	Well 2 Level	5	OWHIST	Orange	m	7.100	8.200	\\OWHISTORIAN1\hns	0.00.00.000			7.221	7.370
☒ WoodvBW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	15.000	\\OWHISTORIAN1\hns	0.00.00.000			6.128	5.922
☒ WoodvBW	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.030	0.100	\\OWHISTORIAN1\hns	0.00.00.000			0.036	0.034
☐ WoodvBW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.100	0.180	\\OWHISTORIAN1\hns	0.00.00.000			0.154	0.154
☐ WoodvBW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.044	0.053	\\OWHISTORIAN1\hns	0.00.00.000			0.049	0.045
☒ WoodvBW	Discharge Chlorine	10	OWHIST	Light Green	mg/L	2.800	4.000	\\OWHISTORIAN1\hns	0.00.00.000			3.136	3.514
☒ WoodvBW	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.472	2.488	\\OWHISTORIAN1\hns	0.00.00.000			2.486	2.486
☒ WoodvBW	Discharge Flow	12	OWHIST	Light Blue	l/s	2.000	7.000	\\OWHISTORIAN1\hns	0.00.00.000			5.415	4.971

Woodville DWS- May 3, 2022- Test #22- Well 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST	Red	l/s	0.000	8.000	\\OWHISTORIAN1\inS	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST	Yellow	m	1.600	2.300	\\OWHISTORIAN1\inS	0.00.00.000			1.797	1.951
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.000	6.000	\\OWHISTORIAN1\inS	0.00.00.000			5.443	4.995
☒ WoodvilleW	Well 2 Level	5	OWHIST	Blue	m	7.100	8.200	\\OWHISTORIAN1\inS	0.00.00.000			7.221	7.370
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	0.000	15.000	\\OWHISTORIAN1\inS	0.00.00.000			6.128	5.922
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Brown	NTU	0.030	0.100	\\OWHISTORIAN1\inS	0.00.00.000			0.036	0.034
☐ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Pink	kPa	0.100	0.180	\\OWHISTORIAN1\inS	0.00.00.000			0.154	0.154
☐ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Grey	NTU	0.044	0.053	\\OWHISTORIAN1\inS	0.00.00.000			0.045	0.045
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Light Blue	mg/L	2.800	4.000	\\OWHISTORIAN1\inS	0.00.00.000			3.136	3.514
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Dark Blue	mg/L	2.472	2.488	\\OWHISTORIAN1\inS	0.00.00.000			2.486	2.486
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Green	l/s	2.000	7.000	\\OWHISTORIAN1\inS	0.00.00.000			5.415	4.971

Woodville DWS- May 3, 2022- Test #23- Well 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ Woodv1W	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	8.000	\\OWHISTORIAN1\UnS	0:00:00.000			0.002	0.002
☐ Woodv1W	Well 1 Level	2	OWHIST	Red	m	1.600	2.300	\\OWHISTORIAN1\UnS	0:00:00.000			1.797	1.951
☒ Woodv1W	Well 2 Flow	3	OWHIST	Green	l/s	0.000	6.000	\\OWHISTORIAN1\UnS	0:00:00.000			5.443	4.995
☒ Woodv1W	Well 2 Level	5	OWHIST	Orange	m	7.100	8.200	\\OWHISTORIAN1\UnS	0:00:00.000			7.221	7.370
☒ Woodv1W	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	15.000	\\OWHISTORIAN1\UnS	0:00:00.000			6.128	5.922
☒ Woodv1W	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.030	0.100	\\OWHISTORIAN1\UnS	0:00:00.000			0.036	0.034
☐ Woodv1W	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.100	0.180	\\OWHISTORIAN1\UnS	0:00:00.000			0.154	0.154
☐ Woodv1W	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.044	0.063	\\OWHISTORIAN1\UnS	0:00:00.000			0.049	0.045
☒ Woodv1W	Discharge Chlorine	10	OWHIST	Light Green	mg/L	2.800	4.000	\\OWHISTORIAN1\UnS	0:00:00.000			3.136	3.514
☒ Woodv1W	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.472	2.488	\\OWHISTORIAN1\UnS	0:00:00.000			2.486	2.486
☒ Woodv1W	Discharge Flow	12	OWHIST	Light Yellow	l/s	2.000	7.000	\\OWHISTORIAN1\UnS	0:00:00.000			5.415	4.971

Woodville DWS- May 3, 2022- Test #24- Well 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.000	8.000	\\OWHISTORIAN1\InS...	0:00:00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST		m	1.600	2.300	\\OWHISTORIAN1\InS...	0:00:00.000			1.797	1.951
☐ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	0.000	6.000	\\OWHISTORIAN1\InS...	0:00:00.000			5.443	4.995
☒ WoodvilleW	Well 2 Level	5	OWHIST		m	7.100	8.200	\\OWHISTORIAN1\InS...	0:00:00.000			7.221	7.370
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	15.000	\\OWHISTORIAN1\InS...	0:00:00.000			6.128	5.922
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST		NTU	0.030	0.100	\\OWHISTORIAN1\InS...	0:00:00.000			0.036	0.034
☐ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	0.100	0.180	\\OWHISTORIAN1\InS...	0:00:00.000			0.154	0.154
☐ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST		NTU	0.044	0.053	\\OWHISTORIAN1\InS...	0:00:00.000			0.049	0.045
☒ WoodvilleW	Discharge Chlorine	10	OWHIST		mg/L	2.800	4.000	\\OWHISTORIAN1\InS...	0:00:00.000			3.136	3.514
☒ WoodvilleW	Distribution Chlorine	11	OWHIST		mg/L	2.472	2.488	\\OWHISTORIAN1\InS...	0:00:00.000			2.486	2.486
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	2.000	7.000	\\OWHISTORIAN1\InS...	0:00:00.000			5.415	4.971

Woodville DWS- May 3, 2022- Test #25- Well 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ Woodv8W	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	8.000	\\OWHISTORIAN1\...	0:00:00.000			0.002	0.002
☐ Woodv8W	Well 1 Level	2	OWHIST	Red	m	1.600	2.300	\\OWHISTORIAN1\...	0:00:00.000			1.797	1.951
☒ Woodv8W	Well 2 Flow	3	OWHIST	Green	l/s	0.000	6.000	\\OWHISTORIAN1\...	0:00:00.000			5.443	4.995
☒ Woodv8W	Well 2 Level	5	OWHIST	Orange	m	7.100	8.200	\\OWHISTORIAN1\...	0:00:00.000			7.221	7.370
☒ Woodv8W	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	0.000	15.000	\\OWHISTORIAN1\...	0:00:00.000			6.128	5.922
☒ Woodv8W	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.030	0.100	\\OWHISTORIAN1\...	0:00:00.000			0.036	0.034
☐ Woodv8W	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.100	0.180	\\OWHISTORIAN1\...	0:00:00.000			0.154	0.154
☐ Woodv8W	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.044	0.053	\\OWHISTORIAN1\...	0:00:00.000			0.049	0.045
☒ Woodv8W	Discharge Chlorine	10	OWHIST	Light Green	mg/L	2.800	4.000	\\OWHISTORIAN1\...	0:00:00.000			3.136	3.514
☒ Woodv8W	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.472	2.488	\\OWHISTORIAN1\...	0:00:00.000			2.486	2.486
☒ Woodv8W	Discharge Flow	12	OWHIST	Light Blue	l/s	2.000	7.000	\\OWHISTORIAN1\...	0:00:00.000			5.415	4.971

Woodville DWS- May 3, 2022- Test #26- Well1 & 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ Woodvllw	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	4.000	\\OWHISTORIAN1\WS	0:00:00.000			3.063	2.700
☒ Woodvllw	Well 1 Level	2	OWHIST	Red	m	1.000	2.000	\\OWHISTORIAN1\WS	0:00:00.000			1.625	1.828
☒ Woodvllw	Well 2 Flow	3	OWHIST	Green	l/s	1.000	7.000	\\OWHISTORIAN1\WS	0:00:00.000			2.934	2.773
☒ Woodvllw	Well 2 Level	5	OWHIST	Orange	m	6.800	7.900	\\OWHISTORIAN1\WS	0:00:00.000			7.546	7.738
☒ Woodvllw	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	1.000	16.000	\\OWHISTORIAN1\WS	0:00:00.000			8.824	8.892
☒ Woodvllw	Filter 1 and 2 Turbidity	7	OWHIST	Brown	NTU	0.032	0.034	\\OWHISTORIAN1\WS	0:00:00.000			0.034	0.034
☒ Woodvllw	Filter 3 and 4 Headloss	8	OWHIST	Pink	kPa	0.100	0.160	\\OWHISTORIAN1\WS	0:00:00.000			0.120	0.137
☒ Woodvllw	Filter 3 and 4 Turbidity	9	OWHIST	Grey	NTU	0.205	0.216	\\OWHISTORIAN1\WS	0:00:00.000			0.210	0.214
☒ Woodvllw	Discharge Chlorine	10	OWHIST	Light Blue	mg/L	2.100	3.600	\\OWHISTORIAN1\WS	0:00:00.000			2.945	3.406
☒ Woodvllw	Distribution Chlorine	11	OWHIST	Light Green	mg/L	2.486	2.486	\\OWHISTORIAN1\WS	0:00:00.000			2.486	2.486
☒ Woodvllw	Discharge Flow	12	OWHIST	Dark Blue	l/s	4.000	6.900	\\OWHISTORIAN1\WS	0:00:00.000			6.038	5.492

Woodville DWS- May 3, 2022- Test #27- Well1 & 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	4.000	\\OWHISTORIAN1\InS	0:00:00.000			3.063	2.700
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.000	2.000	\\OWHISTORIAN1\InS	0:00:00.000			1.625	1.828
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	1.000	7.000	\\OWHISTORIAN1\InS	0:00:00.000			2.934	2.773
☒ WoodvilleW	Well 2 Level	5	OWHIST	Yellow	m	6.800	7.900	\\OWHISTORIAN1\InS	0:00:00.000			7.546	7.738
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	1.000	16.000	\\OWHISTORIAN1\InS	0:00:00.000			8.824	8.892
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Orange	NTU	0.032	0.034	\\OWHISTORIAN1\InS	0:00:00.000			0.034	0.034
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Brown	kPa	0.100	0.160	\\OWHISTORIAN1\InS	0:00:00.000			0.120	0.137
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Pink	NTU	0.205	0.216	\\OWHISTORIAN1\InS	0:00:00.000			0.210	0.214
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Grey	mg/L	2.100	3.600	\\OWHISTORIAN1\InS	0:00:00.000			2.945	3.405
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Light Blue	mg/L	2.486	2.486	\\OWHISTORIAN1\InS	0:00:00.000			2.486	2.486
☒ WoodvilleW	Discharge Flow	12	OWHIST	Dark Blue	l/s	4.000	6.900	\\OWHISTORIAN1\InS	0:00:00.000			6.038	5.492

Woodville DWS- May 3, 2022- Test #28- Well1 & 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	4.000	\\OWHISTORIAN1\h1s	0:00:00.000			3.063	2.700
☒ WoodvllW	Well 1 Level	2	OWHIST	Red	m	1.000	2.000	\\OWHISTORIAN1\h2s	0:00:00.000			1.625	1.828
☒ WoodvllW	Well 2 Flow	3	OWHIST	Green	l/s	1.000	7.000	\\OWHISTORIAN1\h3s	0:00:00.000			2.934	2.773
☒ WoodvllW	Well 2 Level	5	OWHIST	Orange	m	6.800	7.900	\\OWHISTORIAN1\h5s	0:00:00.000			7.546	7.738
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	1.000	16.000	\\OWHISTORIAN1\h6s	0:00:00.000			8.824	8.892
☒ WoodvllW	Filter 1 and 2 Turbidity	7	OWHIST	Yellow	NTU	0.032	0.034	\\OWHISTORIAN1\h7s	0:00:00.000			0.034	0.034
☒ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.100	0.160	\\OWHISTORIAN1\h8s	0:00:00.000			0.120	0.137
☒ WoodvllW	Filter 3 and 4 Turbidity	9	OWHIST	Light Green	NTU	0.205	0.216	\\OWHISTORIAN1\h9s	0:00:00.000			0.210	0.214
☒ WoodvllW	Discharge Chlorine	10	OWHIST	Light Blue	mg/L	2.100	3.600	\\OWHISTORIAN1\h10s	0:00:00.000			2.945	3.405
☒ WoodvllW	Distribution Chlorine	11	OWHIST	Purple	mg/L	2.486	2.486	\\OWHISTORIAN1\h11s	0:00:00.000			2.486	2.486
☒ WoodvllW	Discharge Flow	12	OWHIST	Green	l/s	4.000	6.900	\\OWHISTORIAN1\h12s	0:00:00.000			6.038	5.492

Woodville DWS- May 4, 2022- Test #29- Well1 & 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	4.000	\\OWHISTORIAN1\h...	0.00.00.000			3.063	2.700
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.000	2.000	\\OWHISTORIAN1\h...	0.00.00.000			1.625	1.828
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	1.000	7.000	\\OWHISTORIAN1\h...	0.00.00.000			2.934	2.773
☒ WoodvilleW	Well 2 Level	5	OWHIST	Yellow	m	6.800	7.900	\\OWHISTORIAN1\h...	0.00.00.000			7.546	7.738
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	1.000	16.000	\\OWHISTORIAN1\h...	0.00.00.000			8.824	8.892
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Orange	NTU	0.032	0.034	\\OWHISTORIAN1\h...	0.00.00.000			0.034	0.034
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Brown	kPa	0.100	0.160	\\OWHISTORIAN1\h...	0.00.00.000			0.120	0.137
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Pink	NTU	0.205	0.216	\\OWHISTORIAN1\h...	0.00.00.000			0.210	0.214
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Grey	mg/L	2.100	3.600	\\OWHISTORIAN1\h...	0.00.00.000			2.945	3.405
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Light Blue	mg/L	2.486	2.486	\\OWHISTORIAN1\h...	0.00.00.000			2.486	2.486
☒ WoodvilleW	Discharge Flow	12	OWHIST	Dark Blue	l/s	4.000	6.900	\\OWHISTORIAN1\h...	0.00.00.000			6.038	5.492

Woodville DWS- May 4, 2022- Test #30- Well1 & 2 -Train #1




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.000	4.000	\\OWHISTORIAN1\...	0:00:00.000			3.063	2.700
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.000	2.000	\\OWHISTORIAN1\...	0:00:00.000			1.625	1.828
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	1.000	7.000	\\OWHISTORIAN1\...	0:00:00.000			2.934	2.773
☒ WoodvilleW	Well 2 Level	5	OWHIST	Yellow	m	6.800	7.900	\\OWHISTORIAN1\...	0:00:00.000			7.546	7.738
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	1.000	16.000	\\OWHISTORIAN1\...	0:00:00.000			8.824	8.892
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Brown	NTU	0.032	0.034	\\OWHISTORIAN1\...	0:00:00.000			0.034	0.034
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Pink	kPa	0.100	0.160	\\OWHISTORIAN1\...	0:00:00.000			0.120	0.137
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Grey	NTU	0.205	0.216	\\OWHISTORIAN1\...	0:00:00.000			0.210	0.214
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Cyan	mg/L	2.100	3.600	\\OWHISTORIAN1\...	0:00:00.000			2.945	3.405
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Magenta	mg/L	2.486	2.486	\\OWHISTORIAN1\...	0:00:00.000			2.486	2.486
☒ WoodvilleW	Discharge Flow	12	OWHIST	Dark Blue	l/s	4.000	6.900	\\OWHISTORIAN1\...	0:00:00.000			6.038	5.492

Woodville DWS- May 4, 2022- Test #31- Well1 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW ...	Well 1 Flow	1	OWHIST	Blue	l/s	4.900	5.600	\\OWHISTORIAN1\InS...	0.00.00.000			4.986	5.515
☒ WoodvilleW ...	Well 1 Level	2	OWHIST	Red	m	1.790	1.900	\\OWHISTORIAN1\InS...	0.00.00.000			1.875	1.806
☒ WoodvilleW ...	Well 2 Flow	3	OWHIST	Green	l/s	0.002	0.003	\\OWHISTORIAN1\InS...	0.00.00.000			0.002	0.002
☒ WoodvilleW ...	Well 2 Level	5	OWHIST	Yellow	m	7.980	8.090	\\OWHISTORIAN1\InS...	0.00.00.000			8.049	8.037
☒ WoodvilleW ...	Filter 1 and 2 Headloss	6	OWHIST	Orange	kPa	4.000	8.000	\\OWHISTORIAN1\InS...	0.00.00.000			4.772	6.609
☒ WoodvilleW ...	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.032	0.033	\\OWHISTORIAN1\InS...	0.00.00.000			0.032	0.032
☒ WoodvilleW ...	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	0.000	16.000	\\OWHISTORIAN1\InS...	0.00.00.000			12.428	14.626
☒ WoodvilleW ...	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.000	0.600	\\OWHISTORIAN1\InS...	0.00.00.000			0.184	0.097
☒ WoodvilleW ...	Discharge Chlorine	10	OWHIST	Light Green	mg/L	2.000	3.300	\\OWHISTORIAN1\InS...	0.00.00.000			2.436	2.363
☒ WoodvilleW ...	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.395	2.396	\\OWHISTORIAN1\InS...	0.00.00.000			2.395	2.395
☒ WoodvilleW ...	Discharge Flow	12	OWHIST	Light Blue	l/s	4.900	5.700	\\OWHISTORIAN1\InS...	0.00.00.000			4.988	5.518

Woodville DWS- May 4, 2022- Test #32- Well1 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW...	Well 1 Flow	1	OWHIST...		l/s	4.900	5.600	\\OWHISTORIAN1\...	0.00.00.000			4.986	5.515
☒ WoodvilleW...	Well 1 Level	2	OWHIST...		m	1.790	1.900	\\OWHISTORIAN1\...	0.00.00.000			1.875	1.806
☒ WoodvilleW...	Well 2 Flow	3	OWHIST...		l/s	0.002	0.003	\\OWHISTORIAN1\...	0.00.00.000			0.002	0.002
☒ WoodvilleW...	Well 2 Level	5	OWHIST...		m	7.980	8.090	\\OWHISTORIAN1\...	0.00.00.000			8.049	8.037
☒ WoodvilleW...	Filter 1 and 2 Headloss	6	OWHIST...		kPa	4.000	8.000	\\OWHISTORIAN1\...	0.00.00.000			4.772	6.609
☒ WoodvilleW...	Filter 1 and 2 Turbidity	7	OWHIST...		NTU	0.032	0.033	\\OWHISTORIAN1\...	0.00.00.000			0.032	0.032
☒ WoodvilleW...	Filter 3 and 4 Headloss	8	OWHIST...		kPa	0.000	16.000	\\OWHISTORIAN1\...	0.00.00.000			12.428	14.626
☒ WoodvilleW...	Filter 3 and 4 Turbidity	9	OWHIST...		NTU	0.000	0.600	\\OWHISTORIAN1\...	0.00.00.000			0.184	0.097
☒ WoodvilleW...	Discharge Chlorine	10	OWHIST...		mg/L	2.000	3.300	\\OWHISTORIAN1\...	0.00.00.000			2.436	2.363
☒ WoodvilleW...	Distribution Chlorine	11	OWHIST...		mg/L	2.395	2.396	\\OWHISTORIAN1\...	0.00.00.000			2.395	2.395
☒ WoodvilleW...	Discharge Flow	12	OWHIST...		l/s	4.900	5.700	\\OWHISTORIAN1\...	0.00.00.000			4.988	5.518

Woodville DWS- May 4, 2022- Test #33- Well 1 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW...	Well 1 Flow	1	OWHIST	Blue	l/s	4.900	5.600	\OWHISTORIAN1\inS...	0.00.00.000			4.986	5.515
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.790	1.900	\OWHISTORIAN1\inS...	0.00.00.000			1.875	1.806
☐ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	0.002	0.003	\OWHISTORIAN1\inS...	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 2 Level	5	OWHIST	Yellow	m	7.980	8.090	\OWHISTORIAN1\inS...	0.00.00.000			8.049	8.037
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	4.000	8.000	\OWHISTORIAN1\inS...	0.00.00.000			4.772	6.609
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Light Blue	NTU	0.032	0.033	\OWHISTORIAN1\inS...	0.00.00.000			0.032	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Dark Blue	kPa	0.000	16.000	\OWHISTORIAN1\inS...	0.00.00.000			12.428	14.626
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Light Green	NTU	0.000	0.600	\OWHISTORIAN1\inS...	0.00.00.000			0.184	0.097
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Pink	mg/L	2.000	3.300	\OWHISTORIAN1\inS...	0.00.00.000			2.436	2.363
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Light Purple	mg/L	2.395	2.396	\OWHISTORIAN1\inS...	0.00.00.000			2.395	2.395
☒ WoodvilleW	Discharge Flow	12	OWHIST	Dark Green	l/s	4.900	5.700	\OWHISTORIAN1\inS...	0.00.00.000			4.988	5.518


Woodville DWS- May 4, 2022- Test #34- Well 1 -Train #1& 2



Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodviewW...	Well 1 Flow	1	OWHIST	Blue	L/s	4.900	5.600	\\OWHISTORIAN1\InS...	0.00.00.000			4.986	5.515
☒ WoodviewW	Well 1 Level	2	OWHIST	Red	m	1.790	1.900	\\OWHISTORIAN1\InS...	0.00.00.000			1.875	1.806
☐ WoodviewW	Well 2 Flow	3	OWHIST	Yellow	L/s	0.002	0.003	\\OWHISTORIAN1\InS...	0.00.00.000			0.002	0.002
☐ WoodviewW	Well 2 Level	5	OWHIST	Purple	m	7.980	8.090	\\OWHISTORIAN1\InS...	0.00.00.000			8.049	8.037
☒ WoodviewW	Filter 1 and 2 Headloss	6	OWHIST	Green	kPa	4.000	8.000	\\OWHISTORIAN1\InS...	0.00.00.000			4.772	6.609
☒ WoodviewW	Filter 1 and 2 Turbidity	7	OWHIST	Orange	NTU	0.032	0.033	\\OWHISTORIAN1\InS...	0.00.00.000			0.032	0.032
☒ WoodviewW	Filter 3 and 4 Headloss	8	OWHIST	Brown	kPa	0.000	16.000	\\OWHISTORIAN1\InS...	0.00.00.000			12.428	14.626
☒ WoodviewW	Filter 3 and 4 Turbidity	9	OWHIST	Pink	NTU	0.000	0.600	\\OWHISTORIAN1\InS...	0.00.00.000			0.184	0.097
☒ WoodviewW	Discharge Chlorine	10	OWHIST	Grey	mg/L	2.000	3.300	\\OWHISTORIAN1\InS...	0.00.00.000			2.436	2.363
☒ WoodviewW	Distribution Chlorine	11	OWHIST	Light Blue	mg/L	2.395	2.396	\\OWHISTORIAN1\InS...	0.00.00.000			2.395	2.395
☒ WoodviewW	Discharge Flow	12	OWHIST	Dark Blue	L/s	4.900	5.700	\\OWHISTORIAN1\InS...	0.00.00.000			4.988	5.518




Woodville DWS- May 5, 2022- Test #36- Well 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.002	0.002	\\OWHISTORIAN1\mS	0:00:00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST		m	1.470	1.700	\\OWHISTORIAN1\mS	0:00:00.000			1.630	1.525
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	4.200	5.700	\\OWHISTORIAN1\mS	0:00:00.000			4.981	4.993
☒ WoodvilleW	Well 2 Level	5	OWHIST		m	7.300	7.700	\\OWHISTORIAN1\mS	0:00:00.000			7.527	7.431
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	11.000	\\OWHISTORIAN1\mS	0:00:00.000			7.296	7.485
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST		NTU	0.020	0.280	\\OWHISTORIAN1\mS	0:00:00.000			0.038	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	10.000	120.000	\\OWHISTORIAN1\mS	0:00:00.000			14.660	14.849
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST		NTU	0.020	0.150	\\OWHISTORIAN1\mS	0:00:00.000			0.030	0.024
☒ WoodvilleW	Discharge Chlorine	10	OWHIST		mg/L	1.000	5.000	\\OWHISTORIAN1\mS	0:00:00.000			2.455	2.185
☒ WoodvilleW	Distribution Chlorine	11	OWHIST		mg/L	2.163	2.174	\\OWHISTORIAN1\mS	0:00:00.000			2.173	2.164
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	4.200	5.700	\\OWHISTORIAN1\mS	0:00:00.000			4.963	4.968

Woodville DWS- May 5, 2022- Test #37- Well 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	0.002	0.002	\\OWHISTORIAN1\h1s	0.00.00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.470	1.700	\\OWHISTORIAN1\h2s	0.00.00.000			1.630	1.525
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	4.200	5.700	\\OWHISTORIAN1\h3s	0.00.00.000			4.981	4.993
☒ WoodvilleW	Well 2 Level	5	OWHIST	Yellow	m	7.300	7.700	\\OWHISTORIAN1\h5s	0.00.00.000			7.527	7.431
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Orange	kPa	0.000	11.000	\\OWHISTORIAN1\h6s	0.00.00.000			7.296	7.485
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.020	0.280	\\OWHISTORIAN1\h7s	0.00.00.000			0.038	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	10.000	120.000	\\OWHISTORIAN1\h8s	0.00.00.000			14.660	14.849
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.020	0.150	\\OWHISTORIAN1\h9s	0.00.00.000			0.030	0.024
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Light Green	mg/L	1.000	5.000	\\OWHISTORIAN1\h10s	0.00.00.000			2.455	2.185
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.163	2.174	\\OWHISTORIAN1\h11s	0.00.00.000			2.173	2.164
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Blue	l/s	4.200	5.700	\\OWHISTORIAN1\h12s	0.00.00.000			4.963	4.968

Woodville DWS- May 5, 2022- Test #38- Well 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvllW	Well 1 Flow	1	OWHIST	Green	l/s	0.002	0.002	\\OWHISTORIAN1\InS	0:00:00.000			0.002	0.002
☐ WoodvllW	Well 1 Level	2	OWHIST	Blue	m	1.470	1.700	\\OWHISTORIAN1\InS	0:00:00.000			1.630	1.625
☒ WoodvllW	Well 2 Flow	3	OWHIST	Yellow	l/s	4.200	5.700	\\OWHISTORIAN1\InS	0:00:00.000			4.981	4.993
☒ WoodvllW	Well 2 Level	5	OWHIST	Red	m	7.300	7.700	\\OWHISTORIAN1\InS	0:00:00.000			7.527	7.431
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	0.000	11.000	\\OWHISTORIAN1\InS	0:00:00.000			7.296	7.485
☒ WoodvllW	Filter 1 and 2 Turbidity	7	OWHIST	Light Blue	NTU	0.020	0.280	\\OWHISTORIAN1\InS	0:00:00.000			0.038	0.032
☒ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Dark Blue	kPa	10.000	120.000	\\OWHISTORIAN1\InS	0:00:00.000			14.660	14.849
☒ WoodvllW	Filter 3 and 4 Turbidity	9	OWHIST	Grey	NTU	0.020	0.150	\\OWHISTORIAN1\InS	0:00:00.000			0.030	0.024
☒ WoodvllW	Discharge Chlorine	10	OWHIST	Brown	mg/L	1.000	5.000	\\OWHISTORIAN1\InS	0:00:00.000			2.455	2.185
☒ WoodvllW	Distribution Chlorine	11	OWHIST	Dark Red	mg/L	2.163	2.174	\\OWHISTORIAN1\InS	0:00:00.000			2.173	2.164
☒ WoodvllW	Discharge Flow	12	OWHIST	Red	l/s	4.200	5.700	\\OWHISTORIAN1\InS	0:00:00.000			4.963	4.968

Woodville DWS- May 5, 2022- Test #39- Well 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST		l/s	0.002	0.002	\\OWHISTORIAN1\hS	0.00.00.000			0.002	0.002
☒ WoodvllW	Well 1 Level	2	OWHIST		m	1.470	1.700	\\OWHISTORIAN1\hS	0.00.00.000			1.630	1.525
☒ WoodvllW	Well 2 Flow	3	OWHIST		l/s	4.200	5.700	\\OWHISTORIAN1\hS	0.00.00.000			4.981	4.993
☒ WoodvllW	Well 2 Level	5	OWHIST		m	7.300	7.700	\\OWHISTORIAN1\hS	0.00.00.000			7.527	7.431
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	11.000	\\OWHISTORIAN1\hS	0.00.00.000			7.296	7.485
☒ WoodvllW	Filter 1 and 2 Turbidity	7	OWHIST		NTU	0.020	0.280	\\OWHISTORIAN1\hS	0.00.00.000			0.038	0.032
☒ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST		kPa	10.000	120.000	\\OWHISTORIAN1\hS	0.00.00.000			14.660	14.849
☒ WoodvllW	Filter 3 and 4 Turbidity	9	OWHIST		NTU	0.020	0.150	\\OWHISTORIAN1\hS	0.00.00.000			0.030	0.024
☒ WoodvllW	Discharge Chlorine	10	OWHIST		mg/L	1.000	5.000	\\OWHISTORIAN1\hS	0.00.00.000			2.455	2.185
☒ WoodvllW	Distribution Chlorine	11	OWHIST		mg/L	2.163	2.174	\\OWHISTORIAN1\hS	0.00.00.000			2.173	2.164
☒ WoodvllW	Discharge Flow	12	OWHIST		l/s	4.200	5.700	\\OWHISTORIAN1\hS	0.00.00.000			4.963	4.968

Woodville DWS- May 5, 2022- Test #40- Well 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☐ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	0.002	0.002	\\OWHISTORIAN1\WS	0:00:00.000			0.002	0.002
☐ WoodvilleW	Well 1 Level	2	OWHIST		m	1.470	1.700	\\OWHISTORIAN1\WS	0:00:00.000			1.630	1.525
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	4.200	5.700	\\OWHISTORIAN1\WS	0:00:00.000			4.981	4.993
☒ WoodvilleW	Well 2 Level	5	OWHIST		m	7.300	7.700	\\OWHISTORIAN1\WS	0:00:00.000			7.527	7.431
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	0.000	11.000	\\OWHISTORIAN1\WS	0:00:00.000			7.296	7.485
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST		NTU	0.020	0.280	\\OWHISTORIAN1\WS	0:00:00.000			0.038	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	10.000	120.000	\\OWHISTORIAN1\WS	0:00:00.000			14.660	14.849
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST		NTU	0.020	0.150	\\OWHISTORIAN1\WS	0:00:00.000			0.030	0.024
☒ WoodvilleW	Discharge Chlorine	10	OWHIST		mg/L	1.000	5.000	\\OWHISTORIAN1\WS	0:00:00.000			2.455	2.185
☒ WoodvilleW	Distribution Chlorine	11	OWHIST		mg/L	2.163	2.174	\\OWHISTORIAN1\WS	0:00:00.000			2.173	2.164
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	4.200	5.700	\\OWHISTORIAN1\WS	0:00:00.000			4.963	4.968

Woodville DWS- May 5, 2022- Test #41- Well 1 & 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	2.400	2.900	WOWHISTORIAN1\IvS...	0.00:00:00			2.507	2.507
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.700	1.920	WOWHISTORIAN1\IvS...	0.00:00:00			1.782	1.838
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	2.400	2.900	WOWHISTORIAN1\IvS...	0.00:00:00			2.515	2.520
☒ WoodvilleW	Well 2 Level	5	OWHIST	Orange	m	7.580	7.760	WOWHISTORIAN1\IvS...	0.00:00:00			7.635	7.736
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	7.000	11.000	WOWHISTORIAN1\IvS...	0.00:00:00			7.708	7.982
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.020	0.170	WOWHISTORIAN1\IvS...	0.00:00:00			0.032	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	14.000	19.000	WOWHISTORIAN1\IvS...	0.00:00:00			14.986	15.364
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.020	0.130	WOWHISTORIAN1\IvS...	0.00:00:00			0.027	0.025
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Light Green	mg/L	1.500	3.700	WOWHISTORIAN1\IvS...	0.00:00:00			1.923	2.104
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.263	2.274	WOWHISTORIAN1\IvS...	0.00:00:00			2.264	2.264
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Blue	l/s	4.900	5.800	WOWHISTORIAN1\IvS...	0.00:00:00			5.008	5.006

Woodville DWS- May 5, 2022- Test #42- Well 1 & 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	l/s	2.400	2.900	\\OWHISTORIAN1\h-s	0:00:00.000			2.507	2.507
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.700	1.920	\\OWHISTORIAN1\h-s	0:00:00.000			1.782	1.838
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	l/s	2.400	2.900	\\OWHISTORIAN1\h-s	0:00:00.000			2.515	2.520
☒ WoodvilleW	Well 2 Level	5	OWHIST	Yellow	m	7.580	7.760	\\OWHISTORIAN1\h-s	0:00:00.000			7.635	7.736
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	7.000	11.000	\\OWHISTORIAN1\h-s	0:00:00.000			7.708	7.982
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Orange	NTU	0.020	0.170	\\OWHISTORIAN1\h-s	0:00:00.000			0.032	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Brown	kPa	14.000	19.000	\\OWHISTORIAN1\h-s	0:00:00.000			14.986	15.364
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Pink	NTU	0.020	0.130	\\OWHISTORIAN1\h-s	0:00:00.000			0.027	0.025
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Grey	mg/L	1.500	3.700	\\OWHISTORIAN1\h-s	0:00:00.000			1.923	2.104
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Light Blue	mg/L	2.263	2.274	\\OWHISTORIAN1\h-s	0:00:00.000			2.264	2.264
☒ WoodvilleW	Discharge Flow	12	OWHIST	Dark Blue	l/s	4.900	5.800	\\OWHISTORIAN1\h-s	0:00:00.000			5.008	5.006

Woodville DWS- May 9, 2022- Test #43- Well 1 & 2 -Train #1& 2




Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST	Blue	L/s	2.400	2.900	\\OWHISTORIAN1\h1s	0.00.00.000			2.507	2.507
☒ WoodvilleW	Well 1 Level	2	OWHIST	Red	m	1.700	1.920	\\OWHISTORIAN1\h1s	0.00.00.000			1.782	1.838
☒ WoodvilleW	Well 2 Flow	3	OWHIST	Green	L/s	2.400	2.900	\\OWHISTORIAN1\h1s	0.00.00.000			2.615	2.520
☒ WoodvilleW	Well 2 Level	5	OWHIST	Orange	m	7.580	7.760	\\OWHISTORIAN1\h1s	0.00.00.000			7.635	7.736
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST	Yellow	kPa	7.000	11.000	\\OWHISTORIAN1\h1s	0.00.00.000			7.708	7.982
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST	Purple	NTU	0.020	0.170	\\OWHISTORIAN1\h1s	0.00.00.000			0.032	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	14.000	19.000	\\OWHISTORIAN1\h1s	0.00.00.000			14.986	15.364
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.020	0.130	\\OWHISTORIAN1\h1s	0.00.00.000			0.027	0.025
☒ WoodvilleW	Discharge Chlorine	10	OWHIST	Light Green	mg/L	1.500	3.700	\\OWHISTORIAN1\h1s	0.00.00.000			1.923	2.104
☒ WoodvilleW	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.263	2.274	\\OWHISTORIAN1\h1s	0.00.00.000			2.264	2.264
☒ WoodvilleW	Discharge Flow	12	OWHIST	Light Blue	L/s	4.900	5.800	\\OWHISTORIAN1\h1s	0.00.00.000			5.008	5.006

Woodville DWS- May 9, 2022- Test #44- Well 1 & 2 -Train #1& 2



Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvllW	Well 1 Flow	1	OWHIST	Blue	l/s	2.400	2.900	\\OWHISTORIAN1\...	0.00.00.000			2.507	2.507
☒ WoodvllW	Well 1 Level	2	OWHIST	Red	m	1.700	1.920	\\OWHISTORIAN1\...	0.00.00.000			1.782	1.838
☒ WoodvllW	Well 2 Flow	3	OWHIST	Green	l/s	2.400	2.900	\\OWHISTORIAN1\...	0.00.00.000			2.515	2.520
☒ WoodvllW	Well 2 Level	5	OWHIST	Orange	m	7.580	7.780	\\OWHISTORIAN1\...	0.00.00.000			7.635	7.736
☒ WoodvllW	Filter 1 and 2 Headloss	6	OWHIST	Purple	kPa	7.000	11.000	\\OWHISTORIAN1\...	0.00.00.000			7.708	7.982
☒ WoodvllW	Filter 1 and 2 Turbidity	7	OWHIST	Yellow	NTU	0.020	0.170	\\OWHISTORIAN1\...	0.00.00.000			0.032	0.032
☒ WoodvllW	Filter 3 and 4 Headloss	8	OWHIST	Light Blue	kPa	14.000	19.000	\\OWHISTORIAN1\...	0.00.00.000			14.986	15.364
☒ WoodvllW	Filter 3 and 4 Turbidity	9	OWHIST	Dark Blue	NTU	0.020	0.130	\\OWHISTORIAN1\...	0.00.00.000			0.027	0.025
☒ WoodvllW	Discharge Chlorine	10	OWHIST	Light Green	mg/L	1.500	3.700	\\OWHISTORIAN1\...	0.00.00.000			1.923	2.104
☒ WoodvllW	Distribution Chlorine	11	OWHIST	Dark Green	mg/L	2.263	2.274	\\OWHISTORIAN1\...	0.00.00.000			2.264	2.264
☒ WoodvllW	Discharge Flow	12	OWHIST	Light Blue	l/s	4.900	5.800	\\OWHISTORIAN1\...	0.00.00.000			5.008	5.006

Woodville DWS- May 9, 2022- Test #45- Well 1 & 2 -Train #1& 2



Tag Name	Description	Number	Server	Color	Units	Minimum	Maximum	IO Address	Time Offset	Source Tag	Source Server	Value at X1	Value at X2
☒ WoodvilleW	Well 1 Flow	1	OWHIST		l/s	2.400	2.900	\\OWHISTORIAN1\h...	0:00:00.000			2.507	2.507
☒ WoodvilleW	Well 1 Level	2	OWHIST		m	1.700	1.920	\\OWHISTORIAN1\h...	0:00:00.000			1.782	1.838
☒ WoodvilleW	Well 2 Flow	3	OWHIST		l/s	2.400	2.900	\\OWHISTORIAN1\h...	0:00:00.000			2.515	2.520
☒ WoodvilleW	Well 2 Level	5	OWHIST		m	7.580	7.760	\\OWHISTORIAN1\h...	0:00:00.000			7.635	7.736
☒ WoodvilleW	Filter 1 and 2 Headloss	6	OWHIST		kPa	7.000	11.000	\\OWHISTORIAN1\h...	0:00:00.000			7.708	7.982
☒ WoodvilleW	Filter 1 and 2 Turbidity	7	OWHIST		NTU	0.020	0.170	\\OWHISTORIAN1\h...	0:00:00.000			0.032	0.032
☒ WoodvilleW	Filter 3 and 4 Headloss	8	OWHIST		kPa	14.000	19.000	\\OWHISTORIAN1\h...	0:00:00.000			14.986	15.364
☒ WoodvilleW	Filter 3 and 4 Turbidity	9	OWHIST		NTU	0.020	0.130	\\OWHISTORIAN1\h...	0:00:00.000			0.027	0.025
☒ WoodvilleW	Discharge Chlorine	10	OWHIST		mg/L	1.500	3.700	\\OWHISTORIAN1\h...	0:00:00.000			1.923	2.104
☒ WoodvilleW	Distribution Chlorine	11	OWHIST		mg/L	2.263	2.274	\\OWHISTORIAN1\h...	0:00:00.000			2.264	2.264
☒ WoodvilleW	Discharge Flow	12	OWHIST		l/s	4.900	5.800	\\OWHISTORIAN1\h...	0:00:00.000			5.008	5.006

Woodville DWS- April 26, 2022- Test #1- Well 2- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/26/22	7:29:00 AM	0.00	2.97	0.00	8.69	0.04	0.14	3.42	2.26	0.00
04/26/22	7:30:00 AM	0.00	2.97	0.00	8.69	0.04	0.14	3.00	2.27	0.00
04/26/22	7:31:00 AM	0.00	2.97	0.00	8.69	0.04	0.14	2.91	2.27	0.00
04/26/22	7:32:00 AM	0.00	2.97	0.00	8.67	0.04	0.12	2.95	2.27	0.00
04/26/22	7:33:00 AM	0.00	2.80	5.21	8.14	0.08	78.91	2.97	2.27	5.19
04/26/22	7:34:00 AM	0.00	2.71	5.27	8.05	0.06	80.61	1.26	2.27	5.23
04/26/22	7:35:00 AM	0.00	2.66	5.33	7.99	0.04	81.44	1.81	2.27	5.29
04/26/22	7:36:00 AM	0.00	2.62	5.07	7.98	0.04	77.42	2.42	2.30	5.04
04/26/22	7:37:00 AM	0.00	2.59	5.00	7.96	0.04	75.79	2.49	2.30	4.97
04/26/22	7:38:00 AM	0.00	2.57	5.00	7.93	0.04	76.65	2.86	2.30	4.98
04/26/22	7:39:00 AM	0.00	2.55	5.00	7.91	0.04	73.71	3.21	2.30	4.97
04/26/22	7:40:00 AM	0.00	2.53	5.01	7.89	0.04	73.92	3.19	2.30	4.97
04/26/22	7:41:00 AM	0.00	2.51	4.97	7.88	0.04	73.40	3.37	2.30	4.93
04/26/22	7:42:00 AM	0.00	2.49	4.98	7.86	0.04	73.68	3.07	2.29	4.95
04/26/22	7:43:00 AM	0.00	2.48	4.99	7.85	0.04	73.71	3.24	2.29	4.96
04/26/22	7:44:00 AM	0.00	2.47	5.00	7.83	0.04	74.06	3.24	2.29	4.97
04/26/22	7:45:00 AM	0.00	2.45	4.99	7.83	0.04	73.51	3.05	2.29	4.94
04/26/22	7:46:00 AM	0.00	2.44	4.98	7.81	0.04	73.40	2.96	2.29	4.95
04/26/22	7:47:00 AM	0.00	2.42	5.08	7.78	0.04	74.76	3.01	2.29	5.04
04/26/22	7:48:00 AM	0.00	2.42	4.98	7.79	0.04	74.21	3.57	2.27	4.97
04/26/22	7:49:00 AM	0.00	2.41	5.02	7.78	0.04	74.81	3.89	2.27	5.00
04/26/22	7:50:00 AM	0.00	2.40	5.01	7.77	0.04	74.81	3.57	2.27	4.98
04/26/22	7:51:00 AM	0.00	2.39	4.98	7.76	0.04	74.18	3.36	2.27	4.96
04/26/22	7:52:00 AM	0.00	2.38	5.00	7.76	0.04	74.57	3.56	2.27	4.98
04/26/22	7:53:00 AM	0.00	2.38	5.00	7.75	0.04	74.69	3.52	2.27	4.97
04/26/22	7:54:00 AM	0.00	2.37	4.32	7.83	0.04	40.31	3.89	2.27	3.99
04/26/22	7:55:00 AM	0.00	2.37	5.22	7.71	0.05	75.69	3.16	2.27	5.19
04/26/22	7:56:00 AM	0.00	2.36	5.00	7.74	0.04	72.68	2.95	2.26	4.95
04/26/22	7:57:00 AM	0.00	2.36	4.99	7.73	0.04	72.13	3.31	2.27	4.95
04/26/22	7:58:00 AM	0.00	2.35	5.03	7.72	0.04	73.13	2.88	2.27	4.99
04/26/22	7:59:00 AM	0.00	2.35	4.96	7.73	0.04	71.94	3.11	2.27	4.93
04/26/22	8:00:00 AM	0.00	2.34	5.00	7.72	0.04	72.44	3.11	2.27	4.96
04/26/22	8:01:00 AM	0.00	2.34	5.01	7.71	0.04	72.89	3.56	2.27	4.97
04/26/22	8:02:00 AM	0.00	2.33	4.97	7.71	0.04	72.36	3.30	2.27	4.93
04/26/22	8:03:00 AM	0.00	2.33	5.06	7.70	0.04	74.67	3.00	2.27	5.02
04/26/22	8:04:00 AM	0.00	2.32	5.03	7.69	0.04	73.59	3.35	2.27	4.99
04/26/22	8:05:00 AM	0.00	2.32	4.98	7.70	0.04	73.21	3.25	2.27	4.95
04/26/22	8:06:00 AM	0.00	2.32	4.99	7.69	0.04	73.04	3.31	2.29	4.96
04/26/22	8:07:00 AM	0.00	2.31	4.99	7.69	0.04	72.82	3.25	2.29	4.95
04/26/22	8:08:00 AM	0.00	2.31	4.98	7.69	0.04	73.03	2.90	2.29	4.94
04/26/22	8:09:00 AM	0.00	2.30	4.99	7.69	0.04	71.70	3.19	2.29	4.93
04/26/22	8:10:00 AM	0.00	2.30	4.99	7.68	0.04	73.35	3.11	2.29	4.96
04/26/22	8:11:00 AM	0.00	2.30	5.04	7.67	0.04	74.26	3.41	2.29	5.02
04/26/22	8:12:00 AM	0.00	2.29	4.99	7.67	0.04	73.70	3.62	2.29	4.97
04/26/22	8:13:00 AM	0.00	2.29	5.00	7.67	0.04	73.52	3.30	2.29	4.98
04/26/22	8:14:00 AM	0.00	2.29	5.00	7.66	0.04	74.00	3.51	2.29	4.98
04/26/22	8:15:00 AM	0.00	2.29	4.98	7.67	0.04	73.37	3.50	2.29	4.95
04/26/22	8:16:00 AM	0.00	2.30	3.37	7.82	0.04	49.20	3.67	2.29	3.25
04/26/22	8:17:00 AM	0.00	2.28	5.08	7.65	0.04	72.80	3.26	2.29	5.03
04/26/22	8:18:00 AM	0.00	2.28	4.98	7.66	0.04	72.34	3.37	2.29	4.95
04/26/22	8:19:00 AM	0.00	2.27	5.03	7.65	0.04	73.76	3.86	2.29	5.00
04/26/22	8:20:00 AM	0.00	2.27	4.98	7.65	0.04	72.80	3.36	2.29	4.93
04/26/22	8:21:00 AM	0.00	2.27	4.98	7.65	0.04	73.06	3.24	2.29	4.95
04/26/22	8:22:00 AM	0.00	2.26	5.01	7.64	0.04	73.71	3.30	2.29	4.98
04/26/22	8:23:00 AM	0.00	2.26	5.30	7.61	0.04	77.80	3.19	2.27	5.29
04/26/22	8:24:00 AM	0.00	2.26	4.98	7.64	0.04	73.35	2.91	2.27	4.94
04/26/22	8:25:00 AM	0.00	2.26	5.00	7.64	0.04	73.64	2.97	2.27	4.96
04/26/22	8:26:00 AM	0.00	2.26	5.00	7.64	0.04	73.68	3.02	2.27	4.97
04/26/22	8:27:00 AM	0.00	2.26	4.84	7.65	0.04	74.38	2.93	2.27	4.81
04/26/22	8:28:00 AM	0.00	2.25	4.99	7.63	0.04	73.78	3.00	2.27	4.97
04/26/22	8:29:00 AM	0.00	2.25	5.00	7.63	0.04	73.73	3.37	2.27	4.95
04/26/22	8:30:00 AM	0.00	2.25	5.00	7.63	0.04	73.87	3.25	2.27	4.97
04/26/22	8:31:00 AM	0.00	2.25	5.01	7.63	0.04	73.97	3.35	2.27	4.97
04/26/22	8:32:00 AM	0.00	2.24	5.00	7.62	0.04	74.06	3.57	2.27	4.98
04/26/22	8:33:00 AM	0.00	2.24	4.83	7.64	0.04	71.84	3.46	2.27	4.79
04/26/22	8:34:00 AM	0.00	2.24	4.99	7.63	0.04	73.87	3.56	2.27	4.96
04/26/22	8:35:00 AM	0.00	2.24	4.99	7.62	0.04	74.35	3.55	2.27	4.96
04/26/22	8:36:00 AM	0.00	2.24	5.21	7.59	0.04	78.59	3.45	2.27	5.15
04/26/22	8:37:00 AM	0.00	2.22	5.52	7.54	0.04	82.36	3.54	2.27	5.48
04/26/22	8:38:00 AM	0.00	2.21	5.48	7.53	0.04	82.12	3.19	2.27	5.45
04/26/22	8:39:00 AM	0.00	2.20	5.47	7.53	0.04	82.14	3.32	2.27	5.44
04/26/22	8:40:00 AM	0.00	2.20	5.50	7.52	0.04	82.19	3.46	2.27	5.47

Woodville DWS- April 26, 2022- Test #2- Well 2- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/26/22	8:33:00 AM	0.00	2.24	4.83	7.64	0.04	71.84	3.46	2.27	4.79
04/26/22	8:34:00 AM	0.00	2.24	4.99	7.63	0.04	73.87	3.56	2.27	4.96
04/26/22	8:35:00 AM	0.00	2.24	4.99	7.62	0.04	74.35	3.55	2.27	4.96
04/26/22	8:36:00 AM	0.00	2.24	5.21	7.59	0.04	78.59	3.45	2.27	5.15
04/26/22	8:37:00 AM	0.00	2.22	5.52	7.54	0.04	82.36	3.54	2.27	5.48
04/26/22	8:38:00 AM	0.00	2.21	5.48	7.53	0.04	82.12	3.19	2.27	5.45
04/26/22	8:39:00 AM	0.00	2.20	5.47	7.53	0.04	82.14	3.32	2.27	5.44
04/26/22	8:40:00 AM	0.00	2.20	5.50	7.52	0.04	82.19	3.46	2.27	5.47
04/26/22	8:41:00 AM	0.00	2.19	5.51	7.52	0.04	82.85	3.54	2.27	5.49
04/26/22	8:42:00 AM	0.00	2.19	5.49	7.52	0.04	82.36	3.25	2.27	5.47
04/26/22	8:43:00 AM	0.00	2.19	5.52	7.51	0.04	82.79	3.32	2.27	5.48
04/26/22	8:44:00 AM	0.00	2.19	5.52	7.51	0.04	83.00	3.50	2.27	5.47
04/26/22	8:45:00 AM	0.00	2.18	5.48	7.51	0.04	82.42	3.65	2.27	5.45
04/26/22	8:46:00 AM	0.00	2.18	5.53	7.50	0.04	83.34	3.96	2.27	5.49
04/26/22	8:47:00 AM	0.00	2.18	5.53	7.50	0.04	83.22	3.11	2.27	5.49
04/26/22	8:48:00 AM	0.00	2.17	5.48	7.50	0.04	82.36	3.10	2.27	5.44
04/26/22	8:49:00 AM	0.00	2.17	5.49	7.50	0.04	82.60	3.54	2.27	5.46
04/26/22	8:50:00 AM	0.00	2.17	5.52	7.49	0.04	83.19	3.44	2.27	5.47
04/26/22	8:51:00 AM	0.00	2.17	5.49	7.50	0.04	82.81	3.95	2.27	5.45
04/26/22	8:52:00 AM	0.00	2.16	5.49	7.49	0.04	82.72	3.74	2.27	5.46
04/26/22	8:53:00 AM	0.00	2.16	5.52	7.49	0.04	83.46	3.51	2.27	5.49
04/26/22	8:54:00 AM	0.00	2.16	5.47	7.49	0.04	82.79	3.21	2.27	5.44
04/26/22	8:55:00 AM	0.00	2.15	5.51	7.48	0.04	82.71	3.15	2.27	5.46
04/26/22	8:56:00 AM	0.00	2.15	5.52	7.48	0.04	83.58	3.41	2.27	5.48
04/26/22	8:57:00 AM	0.00	2.15	5.49	7.48	0.04	83.03	3.25	2.27	5.45
04/26/22	8:58:00 AM	0.00	2.15	5.53	7.48	0.04	83.82	3.00	2.27	5.50
04/26/22	8:59:00 AM	0.00	2.15	5.49	7.48	0.04	83.00	3.39	2.27	5.46
04/26/22	9:00:00 AM	0.00	2.14	5.06	7.53	0.04	68.92	3.27	2.27	4.93
04/26/22	9:01:00 AM	0.00	2.14	5.46	7.48	0.04	82.79	3.53	2.27	5.42
04/26/22	9:02:00 AM	0.00	2.14	5.49	7.47	0.04	82.97	3.44	2.27	5.45
04/26/22	9:03:00 AM	0.00	2.14	5.53	7.47	0.04	83.93	2.91	2.27	5.49
04/26/22	9:04:00 AM	0.00	2.14	5.48	7.47	0.04	83.03	2.91	2.27	5.44
04/26/22	9:05:00 AM	0.00	2.14	5.49	7.47	0.04	83.29	3.56	2.27	5.45
04/26/22	9:06:00 AM	0.00	2.14	5.54	7.46	0.04	83.96	3.36	2.27	5.51
04/26/22	9:07:00 AM	0.00	2.14	5.26	7.50	0.04	80.58	3.30	2.27	5.21
04/26/22	9:08:00 AM	0.00	2.14	5.51	7.46	0.04	83.77	3.00	2.27	5.47
04/26/22	9:09:00 AM	0.00	2.13	5.52	7.46	0.04	83.67	3.33	2.27	5.47
04/26/22	9:10:00 AM	0.00	2.13	5.47	7.46	0.04	83.24	3.02	2.27	5.44
04/26/22	9:11:00 AM	0.00	2.13	5.52	7.46	0.04	83.84	2.86	2.27	5.48
04/26/22	9:12:00 AM	0.00	2.13	5.52	7.46	0.04	84.24	3.27	2.27	5.49
04/26/22	9:13:00 AM	0.00	2.13	5.47	7.46	0.04	83.55	3.35	2.27	5.45
04/26/22	9:14:00 AM	0.00	2.13	5.48	7.46	0.04	83.75	3.39	2.27	5.46
04/26/22	9:15:00 AM	0.00	2.13	5.73	7.43	0.04	91.03	3.30	2.27	5.74
04/26/22	9:16:00 AM	0.00	2.13	5.51	7.46	0.04	84.24	3.51	2.27	5.48
04/26/22	9:17:00 AM	0.00	2.12	5.51	7.45	0.04	84.18	3.90	2.27	5.47
04/26/22	9:18:00 AM	0.00	2.12	5.49	7.46	0.04	83.55	3.45	2.27	5.45
04/26/22	9:19:00 AM	0.00	2.12	5.48	7.46	0.04	83.33	3.24	2.27	5.43
04/26/22	9:20:00 AM	0.00	2.12	5.51	7.45	0.04	84.06	3.16	2.27	5.47
04/26/22	9:21:00 AM	0.00	2.12	5.35	7.47	0.04	82.62	2.91	2.27	5.32
04/26/22	9:22:00 AM	0.00	2.12	5.50	7.45	0.04	84.29	2.89	2.29	5.45
04/26/22	9:23:00 AM	0.00	2.12	5.50	7.45	0.04	84.10	3.05	2.29	5.46
04/26/22	9:24:00 AM	0.00	2.12	5.50	7.45	0.04	84.18	3.00	2.29	5.45
04/26/22	9:25:00 AM	0.00	2.12	5.51	7.45	0.04	84.00	3.27	2.29	5.47
04/26/22	9:26:00 AM	0.00	2.12	5.51	7.45	0.04	84.30	3.42	2.30	5.47
04/26/22	9:27:00 AM	0.00	2.12	5.50	7.45	0.04	84.30	3.66	2.30	5.47
04/26/22	9:28:00 AM	0.00	2.11	5.50	7.45	0.04	84.34	3.26	2.30	5.47
04/26/22	9:29:00 AM	0.00	2.11	5.55	7.44	0.04	84.85	4.00	2.30	5.50
04/26/22	9:30:00 AM	0.00	2.11	5.48	7.44	0.04	84.41	3.33	2.30	5.45
04/26/22	9:31:00 AM	0.00	2.11	5.50	7.44	0.04	84.48	3.15	2.32	5.47
04/26/22	9:32:00 AM	0.00	2.11	5.51	7.44	0.04	84.72	3.81	2.32	5.47
04/26/22	9:33:00 AM	0.00	2.11	5.52	7.44	0.04	84.68	3.55	2.34	5.47
04/26/22	9:34:00 AM	0.00	2.11	5.50	7.44	0.04	84.56	3.27	2.34	5.46
04/26/22	9:35:00 AM	0.00	2.11	5.50	7.44	0.04	84.44	3.50	2.35	5.45
04/26/22	9:36:00 AM	0.00	2.11	5.49	7.44	0.04	84.20	3.39	2.35	5.45
04/26/22	9:37:00 AM	0.00	2.10	6.08	7.36	0.04	92.75	3.16	2.35	6.02
04/26/22	9:38:00 AM	0.00	2.09	6.02	7.36	0.04	93.47	3.40	2.35	5.98
04/26/22	9:39:00 AM	0.00	2.08	6.00	7.35	0.04	93.04	3.39	2.35	5.95
04/26/22	9:40:00 AM	0.00	2.07	6.01	7.35	0.04	93.21	3.60	2.35	5.96

Woodville DWS- April 26, 2022- Test #3- Well 2- Train #2

Date	Time	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/26/22	9:31:00 AM	5.50	7.44	0.04	84.48	3.15	2.32	5.47
04/26/22	9:32:00 AM	5.51	7.44	0.04	84.72	3.81	2.32	5.47
04/26/22	9:33:00 AM	5.52	7.44	0.04	84.68	3.55	2.34	5.47
04/26/22	9:34:00 AM	5.50	7.44	0.04	84.56	3.27	2.34	5.46
04/26/22	9:35:00 AM	5.50	7.44	0.04	84.44	3.50	2.35	5.45
04/26/22	9:36:00 AM	5.49	7.44	0.04	84.20	3.39	2.35	5.45
04/26/22	9:37:00 AM	6.08	7.36	0.04	92.75	3.16	2.35	6.02
04/26/22	9:38:00 AM	6.02	7.36	0.04	93.47	3.40	2.35	5.98
04/26/22	9:39:00 AM	6.00	7.35	0.04	93.04	3.39	2.35	5.95
04/26/22	9:40:00 AM	6.01	7.35	0.04	93.21	3.60	2.35	5.96
04/26/22	9:41:00 AM	6.00	7.35	0.04	92.89	3.92	2.35	5.95
04/26/22	9:42:00 AM	5.98	7.35	0.04	92.36	3.05	2.35	5.91
04/26/22	9:43:00 AM	5.93	7.35	0.04	94.74	3.00	2.35	5.91
04/26/22	9:44:00 AM	5.97	7.34	0.04	92.56	3.04	2.35	5.92
04/26/22	9:45:00 AM	6.00	7.33	0.04	93.49	3.04	2.35	5.97
04/26/22	9:46:00 AM	5.99	7.33	0.04	93.09	3.19	2.35	5.94
04/26/22	9:47:00 AM	6.03	7.33	0.04	93.66	3.57	2.35	5.99
04/26/22	9:48:00 AM	5.98	7.33	0.04	92.66	3.61	2.35	5.95
04/26/22	9:49:00 AM	6.00	7.33	0.04	93.14	3.91	2.35	5.95
04/26/22	9:50:00 AM	5.98	7.33	0.04	92.90	3.27	2.35	5.94
04/26/22	9:51:00 AM	6.01	7.32	0.04	93.80	3.27	2.35	5.96
04/26/22	9:52:00 AM	5.98	7.33	0.04	93.09	3.10	2.35	5.93
04/26/22	9:53:00 AM	6.00	7.32	0.04	93.27	3.35	2.35	5.98
04/26/22	9:54:00 AM	6.01	7.32	0.04	93.87	3.29	2.35	5.98
04/26/22	9:55:00 AM	5.98	7.32	0.04	93.28	3.39	2.35	5.95
04/26/22	9:56:00 AM	6.02	7.32	0.04	93.97	3.54	2.35	5.98
04/26/22	9:57:00 AM	6.09	7.31	0.04	97.95	3.46	2.35	6.08
04/26/22	9:58:00 AM	6.03	7.31	0.04	94.30	3.11	2.35	5.99
04/26/22	9:59:00 AM	6.01	7.31	0.04	94.09	3.24	2.35	5.96
04/26/22	10:00:00 AM	6.01	7.31	0.04	93.88	3.07	2.35	5.97
04/26/22	10:01:00 AM	6.00	7.31	0.04	93.66	3.39	2.35	5.96
04/26/22	10:02:00 AM	5.98	7.32	0.04	93.27	4.27	2.35	5.94
04/26/22	10:03:00 AM	6.16	7.29	0.04	93.11	3.65	2.34	6.10
04/26/22	10:04:00 AM	5.98	7.31	0.04	94.00	3.40	2.35	5.95
04/26/22	10:05:00 AM	5.99	7.31	0.04	93.42	3.15	2.35	5.95
04/26/22	10:06:00 AM	6.02	7.31	0.04	94.05	3.19	2.35	5.97
04/26/22	10:07:00 AM	6.02	7.31	0.04	94.24	3.15	2.35	5.97
04/26/22	10:08:00 AM	5.99	7.31	0.04	94.09	3.54	2.35	5.95
04/26/22	10:09:00 AM	6.01	7.30	0.04	94.40	3.35	2.35	5.97
04/26/22	10:10:00 AM	5.98	7.31	0.04	93.52	3.36	2.35	5.92
04/26/22	10:11:00 AM	5.98	7.31	0.04	93.66	3.45	2.35	5.94
04/26/22	10:12:00 AM	5.65	7.36	0.04	93.57	3.25	2.35	5.64
04/26/22	10:13:00 AM	5.97	7.31	0.04	93.11	3.26	2.35	5.91
04/26/22	10:14:00 AM	6.01	7.30	0.04	94.55	4.07	2.35	5.96
04/26/22	10:15:00 AM	6.00	7.30	0.04	94.04	3.10	2.35	5.95
04/26/22	10:16:00 AM	6.03	7.30	0.04	94.72	3.16	2.35	5.99
04/26/22	10:17:00 AM	5.98	7.30	0.04	93.93	3.29	2.35	5.94
04/26/22	10:18:00 AM	5.99	7.30	0.04	94.07	3.37	2.35	5.94
04/26/22	10:19:00 AM	6.02	7.30	0.04	94.64	3.77	2.35	5.99
04/26/22	10:20:00 AM	5.97	7.31	0.04	93.45	3.37	2.35	5.92
04/26/22	10:21:00 AM	5.99	7.30	0.04	94.07	3.25	2.35	5.94
04/26/22	10:22:00 AM	6.00	7.30	0.04	94.28	3.49	2.35	5.94
04/26/22	10:23:00 AM	5.98	7.30	0.04	94.78	3.45	2.35	5.94
04/26/22	10:24:00 AM	6.02	7.30	0.04	94.57	3.39	2.35	5.97
04/26/22	10:25:00 AM	6.01	7.30	0.04	94.59	3.51	2.35	5.96
04/26/22	10:26:00 AM	6.01	7.29	0.04	94.76	3.65	2.35	5.96
04/26/22	10:27:00 AM	5.99	7.30	0.04	94.69	3.40	2.35	5.96
04/26/22	10:28:00 AM	5.99	7.30	0.04	94.52	3.27	2.35	5.95
04/26/22	10:29:00 AM	5.82	7.32	0.04	85.13	3.30	2.35	5.70
04/26/22	10:30:00 AM	5.95	7.31	0.04	93.54	3.60	2.35	5.91
04/26/22	10:31:00 AM	6.03	7.29	0.04	94.59	3.61	2.35	5.97
04/26/22	10:32:00 AM	5.98	7.30	0.04	94.14	3.45	2.35	5.93
04/26/22	10:33:00 AM	6.03	7.29	0.04	95.14	3.22	2.35	5.99
04/26/22	10:34:00 AM	6.04	7.29	0.04	95.57	3.29	2.35	5.98
04/26/22	10:35:00 AM	6.00	7.29	0.04	94.59	3.19	2.35	5.95
04/26/22	10:36:00 AM	6.26	7.25	0.04	100.34	3.30	2.35	6.23
04/26/22	10:37:00 AM	6.47	7.22	0.04	102.83	3.62	2.35	6.42
04/26/22	10:38:00 AM	6.57	7.19	0.04	102.67	3.45	2.35	6.50
04/26/22	10:39:00 AM	6.52	7.19	0.04	103.75	3.67	2.35	6.48

Woodville DWS- April 26, 2022- Test #4- Well 2- Train #2

Date	Time	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/26/22	10:30:00 AM	5.95	7.31	0.04	93.54	3.60	2.35	5.91
04/26/22	10:31:00 AM	6.03	7.29	0.04	94.59	3.61	2.35	5.97
04/26/22	10:32:00 AM	5.98	7.30	0.04	94.14	3.45	2.35	5.93
04/26/22	10:33:00 AM	6.03	7.29	0.04	95.14	3.22	2.35	5.99
04/26/22	10:34:00 AM	6.04	7.29	0.04	95.57	3.29	2.35	5.98
04/26/22	10:35:00 AM	6.00	7.29	0.04	94.59	3.19	2.35	5.95
04/26/22	10:36:00 AM	6.26	7.25	0.04	100.34	3.30	2.35	6.23
04/26/22	10:37:00 AM	6.47	7.22	0.04	102.83	3.62	2.35	6.42
04/26/22	10:38:00 AM	6.57	7.19	0.04	102.67	3.45	2.35	6.50
04/26/22	10:39:00 AM	6.52	7.19	0.04	103.75	3.67	2.35	6.48
04/26/22	10:40:00 AM	6.50	7.19	0.04	103.65	3.62	2.35	6.45
04/26/22	10:41:00 AM	6.51	7.19	0.04	103.56	3.37	2.35	6.45
04/26/22	10:42:00 AM	6.48	7.19	0.04	103.22	3.54	2.35	6.43
04/26/22	10:43:00 AM	6.50	7.19	0.04	103.56	3.55	2.35	6.46
04/26/22	10:44:00 AM	6.50	7.18	0.04	103.48	3.44	2.35	6.45
04/26/22	10:45:00 AM	6.47	7.19	0.04	103.10	3.15	2.35	6.43
04/26/22	10:46:00 AM	6.31	7.22	0.04	99.38	3.10	2.36	6.22
04/26/22	10:47:00 AM	6.53	7.18	0.04	104.59	3.07	2.35	6.49
04/26/22	10:48:00 AM	6.48	7.18	0.04	104.01	3.14	2.35	6.43
04/26/22	10:49:00 AM	6.52	7.18	0.04	104.22	3.04	2.35	6.47
04/26/22	10:50:00 AM	6.51	7.18	0.04	103.84	2.92	2.35	6.47
04/26/22	10:51:00 AM	6.48	7.18	0.04	103.15	3.14	2.35	6.41
04/26/22	10:52:00 AM	6.50	7.18	0.04	103.56	3.24	2.35	6.46
04/26/22	10:53:00 AM	6.59	7.17	0.04	108.49	3.14	2.35	6.58
04/26/22	10:54:00 AM	6.51	7.17	0.04	105.18	3.30	2.35	6.48
04/26/22	10:55:00 AM	6.52	7.17	0.04	104.25	3.56	2.35	6.48
04/26/22	10:56:00 AM	6.50	7.17	0.04	104.10	3.35	2.35	6.46
04/26/22	10:57:00 AM	6.51	7.17	0.04	104.03	3.47	2.35	6.46
04/26/22	10:58:00 AM	6.50	7.17	0.04	103.94	3.74	2.35	6.47
04/26/22	10:59:00 AM	6.52	7.16	0.04	104.11	3.27	2.35	6.45
04/26/22	11:00:00 AM	6.49	7.17	0.04	103.99	3.32	2.35	6.46
04/26/22	11:01:00 AM	6.50	7.16	0.04	103.86	3.32	2.35	6.45
04/26/22	11:02:00 AM	6.32	7.20	0.04	99.31	3.00	2.35	6.23
04/26/22	11:03:00 AM	6.49	7.16	0.04	104.56	3.15	2.36	6.46
04/26/22	11:04:00 AM	6.49	7.17	0.04	103.96	2.95	2.36	6.42
04/26/22	11:05:00 AM	6.50	7.16	0.04	104.05	3.35	2.36	6.43
04/26/22	11:06:00 AM	6.51	7.16	0.04	104.58	3.40	2.36	6.47
04/26/22	11:07:00 AM	6.49	7.16	0.04	103.63	3.49	2.36	6.42
04/26/22	11:08:00 AM	6.50	7.16	0.04	104.23	3.37	2.36	6.44
04/26/22	11:09:00 AM	6.51	7.16	0.04	104.35	3.67	2.36	6.46
04/26/22	11:10:00 AM	6.48	7.16	0.04	103.93	3.25	2.36	6.44
04/26/22	11:11:00 AM	6.49	7.16	0.04	104.23	3.60	2.36	6.44
04/26/22	11:12:00 AM	6.32	7.20	0.04	53.52	3.40	2.36	4.60
04/26/22	11:13:00 AM	6.42	7.16	0.04	102.09	3.07	2.35	6.43
04/26/22	11:14:00 AM	6.50	7.16	0.05	99.12	3.16	2.35	6.46
04/26/22	11:15:00 AM	6.51	7.15	0.04	99.17	3.71	2.35	6.47
04/26/22	11:16:00 AM	6.51	7.15	0.04	99.26	3.26	2.35	6.45
04/26/22	11:17:00 AM	6.53	7.15	0.04	99.53	2.92	2.35	6.46
04/26/22	11:18:00 AM	6.48	7.15	0.04	99.32	3.19	2.36	6.44
04/26/22	11:19:00 AM	6.51	7.15	0.04	99.34	3.54	2.36	6.45
04/26/22	11:20:00 AM	6.48	7.16	0.04	99.07	3.49	2.36	6.44
04/26/22	11:21:00 AM	6.51	7.15	0.04	100.03	3.16	2.36	6.47
04/26/22	11:22:00 AM	6.50	7.15	0.04	99.84	3.30	2.36	6.46
04/26/22	11:23:00 AM	6.47	7.15	0.04	99.46	2.97	2.36	6.42
04/26/22	11:24:00 AM	6.49	7.15	0.04	99.77	3.42	2.36	6.44
04/26/22	11:25:00 AM	6.51	7.15	0.04	100.03	3.37	2.36	6.46
04/26/22	11:26:00 AM	6.47	7.16	0.04	99.38	3.35	2.36	6.41
04/26/22	11:27:00 AM	6.51	7.15	0.04	100.11	3.62	2.36	6.45
04/26/22	11:28:00 AM	6.50	7.15	0.04	100.27	3.15	2.36	6.45
04/26/22	11:29:00 AM	6.49	7.15	0.04	100.60	3.35	2.36	6.47
04/26/22	11:30:00 AM	6.50	7.15	0.04	100.51	3.54	2.36	6.46
04/26/22	11:31:00 AM	6.50	7.15	0.04	100.32	3.70	2.36	6.45
04/26/22	11:32:00 AM	6.50	7.15	0.04	100.41	3.45	2.37	6.45
04/26/22	11:33:00 AM	6.51	7.15	0.04	100.54	3.50	2.37	6.46
04/26/22	11:34:00 AM	6.50	7.15	0.04	100.78	3.26	2.37	6.47
04/26/22	11:35:00 AM	6.50	7.15	0.04	100.78	3.42	2.37	6.45
04/26/22	11:36:00 AM	6.62	7.13	0.04	103.58	3.27	2.37	6.57
04/26/22	11:37:00 AM	6.78	7.10	0.04	105.56	3.15	2.37	6.73

Woodville DWS- April 26, 2022- Test #5- Well 2- Train #2

Date	Time	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/26/22	11:32:00 AM	6.50	7.15	0.04	100.41	3.45	2.37	6.45
04/26/22	11:33:00 AM	6.51	7.15	0.04	100.54	3.50	2.37	6.46
04/26/22	11:34:00 AM	6.50	7.15	0.04	100.78	3.26	2.37	6.47
04/26/22	11:35:00 AM	6.50	7.15	0.04	100.78	3.42	2.37	6.45
04/26/22	11:36:00 AM	6.62	7.13	0.04	103.58	3.27	2.37	6.57
04/26/22	11:37:00 AM	6.78	7.10	0.04	105.56	3.15	2.37	6.73
04/26/22	11:38:00 AM	6.80	7.09	0.04	105.73	3.35	2.37	6.74
04/26/22	11:39:00 AM	6.81	7.09	0.04	105.99	3.51	2.37	6.75
04/26/22	11:40:00 AM	6.81	7.08	0.04	106.29	3.54	2.37	6.74
04/26/22	11:41:00 AM	6.80	7.08	0.04	106.26	3.54	2.37	6.75
04/26/22	11:42:00 AM	6.79	7.08	0.04	106.55	3.25	2.37	6.75
04/26/22	11:43:00 AM	6.79	7.08	0.04	106.26	3.30	2.37	6.74
04/26/22	11:44:00 AM	6.82	7.08	0.04	106.79	3.07	2.37	6.76
04/26/22	11:45:00 AM	6.79	7.08	0.04	106.47	3.16	2.37	6.73
04/26/22	11:46:00 AM	6.80	7.07	0.04	106.91	3.00	2.37	6.75
04/26/22	11:47:00 AM	6.79	7.07	0.04	106.52	2.84	2.37	6.76
04/26/22	11:48:00 AM	6.81	7.07	0.04	107.22	3.54	2.36	6.76
04/26/22	11:49:00 AM	6.80	7.07	0.04	106.93	3.26	2.36	6.74
04/26/22	11:50:00 AM	6.81	7.07	0.04	106.67	2.90	2.36	6.76
04/26/22	11:51:00 AM	6.79	7.07	0.04	106.64	3.07	2.36	6.74
04/26/22	11:52:00 AM	6.83	7.07	0.04	107.38	3.24	2.36	6.75
04/26/22	11:53:00 AM	6.80	7.07	0.04	107.17	3.39	2.36	6.76
04/26/22	11:54:00 AM	6.78	7.07	0.04	107.02	3.30	2.36	6.74
04/26/22	11:55:00 AM	6.82	7.07	0.04	107.62	3.18	2.37	6.78
04/26/22	11:56:00 AM	6.79	7.07	0.04	106.98	3.19	2.37	6.73
04/26/22	11:57:00 AM	6.80	7.07	0.04	107.32	3.19	2.36	6.75
04/26/22	11:58:00 AM	6.79	7.07	0.04	107.38	3.46	2.36	6.75
04/26/22	11:59:00 AM	6.78	7.07	0.04	106.88	3.30	2.36	6.73
04/26/22	12:00:00 PM	6.82	7.06	0.04	107.77	3.30	2.36	6.76
04/26/22	12:01:00 PM	6.79	7.07	0.04	107.58	3.56	2.36	6.75
04/26/22	12:02:00 PM	6.80	7.07	0.04	107.62	3.39	2.37	6.75
04/26/22	12:03:00 PM	6.79	7.07	0.04	107.10	3.72	2.37	6.73
04/26/22	12:04:00 PM	6.82	7.06	0.04	107.43	3.46	2.36	6.77
04/26/22	12:05:00 PM	6.82	7.06	0.04	108.13	3.10	2.37	6.76
04/26/22	12:06:00 PM	6.80	7.07	0.04	107.51	3.24	2.37	6.73
04/26/22	12:07:00 PM	6.80	7.06	0.04	107.82	2.85	2.37	6.75
04/26/22	12:08:00 PM	6.78	7.07	0.04	107.50	3.35	2.37	6.72
04/26/22	12:09:00 PM	6.81	7.06	0.04	108.08	3.49	2.37	6.75
04/26/22	12:10:00 PM	6.79	7.06	0.04	107.67	3.19	2.37	6.73
04/26/22	12:11:00 PM	6.82	7.06	0.04	108.39	3.10	2.37	6.76
04/26/22	12:12:00 PM	6.81	7.06	0.04	108.08	3.03	2.37	6.77
04/26/22	12:13:00 PM	6.80	7.06	0.04	107.99	3.49	2.37	6.76
04/26/22	12:14:00 PM	6.82	7.06	0.04	108.29	3.49	2.37	6.77
04/26/22	12:15:00 PM	6.79	7.06	0.04	107.74	3.56	2.37	6.75
04/26/22	12:16:00 PM	6.82	7.06	0.04	108.63	3.35	2.37	6.77
04/26/22	12:17:00 PM	6.81	7.06	0.04	108.51	3.10	2.37	6.77
04/26/22	12:18:00 PM	6.79	7.05	0.04	106.81	3.69	2.37	6.74
04/26/22	12:19:00 PM	6.82	7.05	0.04	108.23	3.24	2.37	6.74
04/26/22	12:20:00 PM	6.80	7.05	0.04	108.70	3.35	2.37	6.76
04/26/22	12:21:00 PM	6.79	7.05	0.04	108.63	3.24	2.37	6.75
04/26/22	12:22:00 PM	6.78	7.06	0.04	108.08	3.19	2.37	6.73
04/26/22	12:23:00 PM	6.80	7.05	0.04	108.85	3.61	2.37	6.75
04/26/22	12:24:00 PM	6.78	7.06	0.04	108.20	3.26	2.37	6.74
04/26/22	12:25:00 PM	6.93	7.04	0.04	111.91	3.19	2.37	6.92
04/26/22	12:26:00 PM	6.79	7.05	0.04	109.33	3.36	2.37	6.75
04/26/22	12:27:00 PM	6.78	7.06	0.04	107.98	3.05	2.37	6.72
04/26/22	12:28:00 PM	6.81	7.05	0.04	109.11	2.89	2.36	6.74
04/26/22	12:29:00 PM	6.81	7.05	0.04	109.09	3.14	2.36	6.75
04/26/22	12:30:00 PM	6.79	7.05	0.04	108.68	2.92	2.36	6.74
04/26/22	12:31:00 PM	6.81	7.05	0.04	109.45	3.25	2.36	6.77
04/26/22	12:32:00 PM	6.81	7.05	0.04	104.01	3.62	2.36	6.69
04/26/22	12:33:00 PM	6.81	7.05	0.04	108.17	3.46	2.36	6.74
04/26/22	12:34:00 PM	6.33	7.51	0.04	105.83	3.20	2.36	6.56
04/26/22	12:35:00 PM	0.00	7.96	0.05	81.28	3.07	2.36	5.13
04/26/22	12:36:00 PM	0.00	7.96	0.05	80.05	3.41	2.36	4.97
04/26/22	12:37:00 PM	0.00	7.99	0.04	80.85	3.56	2.36	5.02
04/26/22	12:38:00 PM	0.00	7.99	0.04	78.14	3.27	2.36	4.97
04/26/22	12:39:00 PM	0.00	8.01	0.04	81.63	3.15	2.36	5.00
04/26/22	12:40:00 PM	0.00	8.04	0.04	82.18	3.53	2.36	4.99

Woodville DWS- April 26, 2022- Test #6- Well 1- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/26/22	12:33:00 PM	0.00	1.85	0.04	108.17	3.46	2.36	6.74
04/26/22	12:34:00 PM	0.00	2.58	0.04	105.83	3.20	2.36	6.56
04/26/22	12:35:00 PM	5.20	2.27	0.05	81.28	3.07	2.36	5.13
04/26/22	12:36:00 PM	4.97	2.29	0.05	80.05	3.41	2.36	4.97
04/26/22	12:37:00 PM	5.01	2.28	0.04	80.85	3.56	2.36	5.02
04/26/22	12:38:00 PM	5.03	2.33	0.04	78.14	3.27	2.36	4.97
04/26/22	12:39:00 PM	5.01	2.31	0.04	81.63	3.15	2.36	5.00
04/26/22	12:40:00 PM	4.99	2.32	0.04	82.18	3.53	2.36	4.99
04/26/22	12:41:00 PM	4.99	2.33	0.04	83.24	3.21	2.36	4.99
04/26/22	12:42:00 PM	5.01	2.33	0.04	80.12	3.35	2.36	5.02
04/26/22	12:43:00 PM	5.00	2.35	0.04	79.70	3.57	2.36	5.02
04/26/22	12:44:00 PM	5.09	2.35	0.04	89.09	3.77	2.36	5.29
04/26/22	12:45:00 PM	5.02	2.36	0.04	80.61	3.65	2.36	5.02
04/26/22	12:46:00 PM	5.00	2.34	0.04	80.30	3.40	2.36	5.00
04/26/22	12:47:00 PM	5.02	2.35	0.04	80.17	3.81	2.35	5.01
04/26/22	12:48:00 PM	4.98	2.34	0.04	79.58	3.40	2.36	4.96
04/26/22	12:49:00 PM	5.01	2.35	0.04	80.39	3.40	2.36	5.00
04/26/22	12:50:00 PM	4.97	2.36	0.04	79.77	3.35	2.35	4.96
04/26/22	12:51:00 PM	5.01	2.36	0.04	80.48	3.05	2.35	4.99
04/26/22	12:52:00 PM	4.99	2.38	0.04	80.46	3.69	2.35	4.97
04/26/22	12:53:00 PM	5.00	2.35	0.04	80.97	3.44	2.35	5.01
04/26/22	12:54:00 PM	5.00	2.37	0.04	81.25	3.45	2.35	5.00
04/26/22	12:55:00 PM	4.99	2.37	0.04	81.16	3.32	2.35	4.99
04/26/22	12:56:00 PM	5.00	2.35	0.04	81.37	3.30	2.35	5.00
04/26/22	12:57:00 PM	5.01	2.37	0.04	81.78	3.16	2.35	5.01
04/26/22	12:58:00 PM	4.99	2.38	0.04	71.19	3.46	2.35	4.79
04/26/22	12:59:00 PM	5.00	2.36	0.04	81.18	3.61	2.35	4.97
04/26/22	1:00:00 PM	5.01	2.38	0.04	81.47	3.44	2.35	4.99
04/26/22	1:01:00 PM	5.00	2.38	0.04	82.04	3.39	2.35	4.99
04/26/22	1:02:00 PM	5.00	2.36	0.04	82.40	3.79	2.35	5.00
04/26/22	1:03:00 PM	5.00	2.37	0.04	82.91	3.56	2.35	5.01
04/26/22	1:04:00 PM	5.03	2.37	0.04	83.07	3.62	2.35	5.02
04/26/22	1:05:00 PM	5.00	2.37	0.04	82.88	3.54	2.35	4.98
04/26/22	1:06:00 PM	5.00	2.39	0.04	82.86	3.30	2.35	5.00
04/26/22	1:07:00 PM	5.06	2.36	0.04	85.85	3.62	2.35	5.10
04/26/22	1:08:00 PM	4.99	2.38	0.04	83.24	3.69	2.35	4.98
04/26/22	1:09:00 PM	5.01	2.39	0.04	83.98	3.21	2.35	5.01
04/26/22	1:10:00 PM	4.99	2.37	0.04	83.22	3.14	2.35	4.99
04/26/22	1:11:00 PM	5.01	2.39	0.04	83.82	3.45	2.35	5.01
04/26/22	1:12:00 PM	4.99	2.38	0.04	83.74	3.52	2.35	4.97
04/26/22	1:13:00 PM	5.01	2.38	0.04	84.63	3.62	2.35	5.01
04/26/22	1:14:00 PM	5.00	2.39	0.04	82.78	3.65	2.35	4.94
04/26/22	1:15:00 PM	4.98	2.38	0.04	84.17	3.54	2.35	4.98
04/26/22	1:16:00 PM	4.99	2.39	0.04	84.29	3.81	2.35	4.97
04/26/22	1:17:00 PM	4.99	2.38	0.04	84.32	3.57	2.35	4.98
04/26/22	1:18:00 PM	5.02	2.38	0.04	85.71	3.73	2.35	5.03
04/26/22	1:19:00 PM	4.98	2.38	0.04	84.99	3.63	2.35	4.98
04/26/22	1:20:00 PM	4.99	2.38	0.04	85.57	3.09	2.35	5.00
04/26/22	1:21:00 PM	5.00	2.40	0.04	85.18	3.56	2.35	4.99
04/26/22	1:22:00 PM	4.98	2.39	0.04	85.28	3.30	2.35	4.97
04/26/22	1:23:00 PM	5.04	2.40	0.04	86.28	3.49	2.35	5.04
04/26/22	1:24:00 PM	4.99	2.40	0.04	86.72	3.24	2.35	5.00
04/26/22	1:25:00 PM	5.00	2.39	0.04	86.57	3.50	2.35	4.99
04/26/22	1:26:00 PM	4.99	2.40	0.04	86.72	3.65	2.35	4.99
04/26/22	1:27:00 PM	5.01	2.39	0.04	86.91	3.39	2.35	5.00
04/26/22	1:28:00 PM	4.97	2.40	0.04	86.72	3.45	2.35	4.97
04/26/22	1:29:00 PM	5.01	2.40	0.04	87.53	3.65	2.35	5.01
04/26/22	1:30:00 PM	4.97	2.40	0.04	86.83	3.50	2.35	4.95
04/26/22	1:31:00 PM	5.01	2.40	0.04	87.84	3.30	2.35	5.01
04/26/22	1:32:00 PM	5.00	2.41	0.04	87.98	3.82	2.35	5.00
04/26/22	1:33:00 PM	5.01	2.39	0.04	87.81	3.65	2.35	5.00
04/26/22	1:34:00 PM	5.01	2.41	0.04	88.53	3.89	2.35	5.01
04/26/22	1:35:00 PM	5.01	2.39	0.04	87.72	4.01	2.35	4.99
04/26/22	1:36:00 PM	5.48	2.45	0.04	97.81	3.14	2.35	5.50
04/26/22	1:37:00 PM	5.52	2.43	0.04	97.88	3.07	2.34	5.50
04/26/22	1:38:00 PM	5.48	2.43	0.04	97.78	3.49	2.35	5.46
04/26/22	1:39:00 PM	5.50	2.41	0.04	98.05	3.25	2.35	5.49

Woodville DWS April 26, 2022 Test #7- Well 1- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/26/22	1:33:00 PM	5.01	2.39	0.04	87.81	3.65	2.35	5.00
04/26/22	1:34:00 PM	5.01	2.41	0.04	88.53	3.89	2.35	5.01
04/26/22	1:35:00 PM	5.01	2.39	0.04	87.72	4.01	2.35	4.99
04/26/22	1:36:00 PM	5.48	2.45	0.04	97.81	3.14	2.35	5.50
04/26/22	1:37:00 PM	5.52	2.43	0.04	97.88	3.07	2.34	5.50
04/26/22	1:38:00 PM	5.48	2.43	0.04	97.78	3.49	2.35	5.46
04/26/22	1:39:00 PM	5.50	2.41	0.04	98.05	3.25	2.35	5.49
04/26/22	1:40:00 PM	5.50	2.44	0.04	98.81	3.35	2.35	5.49
04/26/22	1:41:00 PM	5.51	2.42	0.04	99.15	3.27	2.35	5.49
04/26/22	1:42:00 PM	5.50	2.41	0.04	99.14	3.05	2.35	5.50
04/26/22	1:43:00 PM	5.50	2.41	0.04	99.08	3.42	2.35	5.48
04/26/22	1:44:00 PM	5.50	2.41	0.04	99.98	3.15	2.35	5.49
04/26/22	1:45:00 PM	5.51	2.43	0.04	100.34	3.68	2.35	5.51
04/26/22	1:46:00 PM	5.48	2.41	0.04	99.96	3.20	2.35	5.47
04/26/22	1:47:00 PM	5.48	2.43	0.04	101.45	3.47	2.35	5.46
04/26/22	1:48:00 PM	5.48	2.41	0.04	101.04	3.55	2.35	5.48
04/26/22	1:49:00 PM	5.52	2.41	0.04	101.71	3.08	2.35	5.51
04/26/22	1:50:00 PM	5.48	2.41	0.04	101.57	3.46	2.35	5.47
04/26/22	1:51:00 PM	5.52	2.42	0.04	102.48	3.90	2.35	5.52
04/26/22	1:52:00 PM	5.48	2.42	0.04	102.12	3.74	2.35	5.47
04/26/22	1:53:00 PM	5.51	2.44	0.04	102.71	3.37	2.35	5.50
04/26/22	1:54:00 PM	5.49	2.41	0.04	103.84	3.30	2.35	5.49
04/26/22	1:55:00 PM	5.52	2.43	0.04	103.46	3.56	2.35	5.51
04/26/22	1:56:00 PM	5.49	2.42	0.04	103.07	3.91	2.35	5.48
04/26/22	1:57:00 PM	5.51	2.42	0.04	104.05	3.46	2.35	5.50
04/26/22	1:58:00 PM	5.48	2.40	0.04	104.13	3.56	2.35	5.48
04/26/22	1:59:00 PM	5.52	2.41	0.04	104.32	3.38	2.35	5.50
04/26/22	2:00:00 PM	5.49	2.40	0.04	104.22	3.25	2.35	5.49
04/26/22	2:01:00 PM	5.51	2.41	0.04	101.81	3.46	2.35	5.43
04/26/22	2:02:00 PM	5.48	2.40	0.04	103.96	3.76	2.35	5.45
04/26/22	2:03:00 PM	5.51	2.42	0.04	105.57	3.27	2.35	5.50
04/26/22	2:04:00 PM	5.50	2.43	0.04	105.52	3.54	2.35	5.50
04/26/22	2:05:00 PM	5.51	2.43	0.04	106.33	3.57	2.36	5.49
04/26/22	2:06:00 PM	5.49	2.42	0.04	106.40	3.42	2.36	5.49
04/26/22	2:07:00 PM	5.51	2.41	0.04	106.86	3.35	2.36	5.49
04/26/22	2:08:00 PM	5.51	2.41	0.04	107.12	3.80	2.36	5.49
04/26/22	2:09:00 PM	5.51	2.41	0.04	107.03	3.35	2.36	5.49
04/26/22	2:10:00 PM	5.50	2.41	0.04	107.60	3.69	2.36	5.49
04/26/22	2:11:00 PM	5.50	2.42	0.04	107.94	3.39	2.36	5.50
04/26/22	2:12:00 PM	5.49	2.40	0.04	108.08	3.54	2.36	5.48
04/26/22	2:13:00 PM	5.51	2.41	0.04	108.54	3.56	2.36	5.51
04/26/22	2:14:00 PM	5.50	2.41	0.04	109.02	3.55	2.36	5.49
04/26/22	2:15:00 PM	5.49	2.43	0.04	108.80	3.61	2.37	5.47
04/26/22	2:16:00 PM	5.50	2.43	0.04	109.33	3.05	2.37	5.49
04/26/22	2:17:00 PM	5.48	2.40	0.04	109.66	3.56	2.37	5.48
04/26/22	2:18:00 PM	5.52	2.41	0.04	110.53	3.60	2.37	5.51
04/26/22	2:19:00 PM	5.49	2.41	0.04	110.50	3.79	2.37	5.47
04/26/22	2:20:00 PM	5.51	2.45	0.04	112.08	3.55	2.37	5.52
04/26/22	2:21:00 PM	5.48	2.43	0.04	111.68	3.46	2.37	5.49
04/26/22	2:22:00 PM	5.52	2.40	0.04	112.92	3.35	2.37	5.53
04/26/22	2:23:00 PM	5.49	2.41	0.04	112.80	3.76	2.37	5.48
04/26/22	2:24:00 PM	5.51	2.44	0.04	113.66	3.41	2.37	5.49
04/26/22	2:25:00 PM	5.46	2.42	0.04	114.45	3.41	2.37	5.46
04/26/22	2:26:00 PM	5.51	2.42	0.04	115.92	3.84	2.37	5.51
04/26/22	2:27:00 PM	5.50	2.44	0.04	116.56	3.74	2.37	5.50
04/26/22	2:28:00 PM	5.50	2.42	0.04	118.05	3.67	2.37	5.48
04/26/22	2:29:00 PM	5.49	2.43	0.04	118.28	3.57	2.37	5.48
04/26/22	2:30:00 PM	5.52	2.45	0.04	120.25	3.30	2.37	5.51
04/26/22	2:31:00 PM	5.48	2.44	0.04	120.20	3.45	2.37	5.47
04/26/22	2:32:00 PM	5.51	2.44	0.04	122.05	3.27	2.37	5.50
04/26/22	2:33:00 PM	5.50	2.44	0.04	123.03	3.54	2.37	5.50
04/26/22	2:34:00 PM	5.50	2.42	0.04	123.75	3.62	2.37	5.49
04/26/22	2:35:00 PM	5.49	2.45	0.04	124.78	3.89	2.37	5.49
04/26/22	2:36:00 PM	5.48	2.44	0.04	125.97	3.55	2.37	5.47
04/26/22	2:37:00 PM	0.00	2.06	0.04	127.01	3.22	2.37	5.61
04/26/22	2:38:00 PM	0.00	2.05	0.11	111.58	4.93	2.37	5.14

Woodville DWS April 27, 2022 Test #8- Well 1- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/27/22	7:25:00 AM	0.00	2.93	0.05	0.12	3.10	2.24	0.00
04/27/22	7:26:00 AM	0.00	2.93	0.04	0.12	3.11	2.24	0.00
04/27/22	7:27:00 AM	0.00	2.93	0.04	0.15	3.10	2.24	0.00
04/27/22	7:28:00 AM	0.00	2.93	0.05	0.12	3.09	2.24	0.00
04/27/22	7:29:00 AM	0.00	2.93	0.05	0.14	3.09	2.24	0.00
04/27/22	7:30:00 AM	0.00	2.93	0.05	0.12	3.07	2.25	0.00
04/27/22	7:31:00 AM	4.79	3.24	0.05	115.39	3.09	2.25	6.05
04/27/22	7:32:00 AM	6.01	3.13	0.49	127.94	5.00	2.25	5.96
04/27/22	7:33:00 AM	5.96	3.08	0.05	131.58	1.79	2.24	5.94
04/27/22	7:34:00 AM	5.99	3.04	0.04	135.99	2.05	2.26	5.98
04/27/22	7:35:00 AM	6.00	2.99	0.04	138.29	2.42	2.26	6.00
04/27/22	7:36:00 AM	5.98	2.98	0.04	141.50	2.52	2.26	5.98
04/27/22	7:37:00 AM	6.02	2.94	0.04	140.04	2.42	2.26	6.01
04/27/22	7:38:00 AM	5.99	2.92	0.04	139.31	2.53	2.26	5.97
04/27/22	7:39:00 AM	6.01	2.89	0.04	139.85	2.64	2.26	6.00
04/27/22	7:40:00 AM	5.99	2.88	0.04	138.76	3.00	2.26	5.97
04/27/22	7:41:00 AM	6.00	2.87	0.04	139.82	2.70	2.25	6.00
04/27/22	7:42:00 AM	5.99	2.84	0.04	138.34	2.91	2.25	5.96
04/27/22	7:43:00 AM	6.01	2.83	0.04	139.67	2.75	2.25	6.00
04/27/22	7:44:00 AM	6.01	2.81	0.04	139.87	2.75	2.25	6.00
04/27/22	7:45:00 AM	5.97	2.82	0.04	139.49	2.79	2.25	5.96
04/27/22	7:46:00 AM	6.01	2.80	0.04	140.03	2.44	2.25	5.98
04/27/22	7:47:00 AM	6.00	2.78	0.04	140.52	2.56	2.25	5.99
04/27/22	7:48:00 AM	6.00	2.77	0.04	140.28	2.81	2.25	5.98
04/27/22	7:49:00 AM	5.99	2.75	0.04	140.71	2.61	2.25	5.98
04/27/22	7:50:00 AM	5.99	2.75	0.04	140.32	2.49	2.25	5.97
04/27/22	7:51:00 AM	5.99	2.73	0.04	140.52	2.57	2.25	5.97
04/27/22	7:52:00 AM	6.02	2.71	0.04	142.03	2.62	2.25	6.01
04/27/22	7:53:00 AM	5.99	2.74	0.04	141.19	2.70	2.25	5.97
04/27/22	7:54:00 AM	5.99	2.73	0.04	140.95	2.91	2.25	5.96
04/27/22	7:55:00 AM	6.03	2.71	0.04	142.43	2.91	2.24	6.01
04/27/22	7:56:00 AM	5.99	2.71	0.04	141.12	2.75	2.24	5.97
04/27/22	7:57:00 AM	6.01	2.70	0.04	142.52	2.62	2.24	6.01
04/27/22	7:58:00 AM	5.99	2.69	0.04	141.64	2.72	2.24	5.97
04/27/22	7:59:00 AM	6.01	2.68	0.04	142.36	2.60	2.24	5.99
04/27/22	8:00:00 AM	6.01	2.69	0.04	141.61	2.79	2.24	5.98
04/27/22	8:01:00 AM	5.98	2.68	0.04	142.72	2.67	2.24	5.98
04/27/22	8:02:00 AM	6.01	2.66	0.04	142.88	2.76	2.24	6.00
04/27/22	8:03:00 AM	5.99	2.65	0.04	142.50	2.79	2.24	5.96
04/27/22	8:04:00 AM	6.02	2.65	0.04	143.13	2.81	2.24	5.99
04/27/22	8:05:00 AM	5.98	2.64	0.04	142.98	2.81	2.24	5.98
04/27/22	8:06:00 AM	6.02	2.61	0.04	143.36	2.79	2.24	6.00
04/27/22	8:07:00 AM	5.98	2.63	0.04	142.77	2.90	2.24	5.97
04/27/22	8:08:00 AM	6.00	2.62	0.04	143.58	2.81	2.24	5.99
04/27/22	8:09:00 AM	6.02	2.61	0.04	144.46	2.74	2.24	6.00
04/27/22	8:10:00 AM	5.99	2.60	0.04	144.01	2.72	2.24	5.97
04/27/22	8:11:00 AM	6.00	2.61	0.04	144.27	2.81	2.24	5.99
04/27/22	8:12:00 AM	6.00	2.60	0.04	143.77	2.84	2.24	5.98
04/27/22	8:13:00 AM	6.01	2.61	0.04	144.56	2.74	2.24	6.00
04/27/22	8:14:00 AM	5.99	2.61	0.04	144.20	2.65	2.24	5.98
04/27/22	8:15:00 AM	6.02	2.60	0.04	145.14	2.86	2.24	6.01
04/27/22	8:16:00 AM	5.97	2.60	0.04	144.04	2.65	2.24	5.97
04/27/22	8:17:00 AM	6.02	2.59	0.04	145.07	2.75	2.24	6.00
04/27/22	8:18:00 AM	6.00	2.56	0.04	143.80	2.81	2.24	5.97
04/27/22	8:19:00 AM	6.01	2.59	0.04	145.37	2.75	2.24	6.00
04/27/22	8:20:00 AM	6.02	2.57	0.04	146.33	2.96	2.24	6.03
04/27/22	8:21:00 AM	6.00	2.56	0.04	145.38	3.06	2.22	6.00
04/27/22	8:22:00 AM	6.01	2.56	0.04	145.11	2.97	2.22	5.99
04/27/22	8:23:00 AM	5.91	2.57	0.04	143.70	2.90	2.22	5.87
04/27/22	8:24:00 AM	5.99	2.55	0.04	145.81	2.84	2.22	5.98
04/27/22	8:25:00 AM	6.00	2.56	0.04	145.90	2.97	2.22	5.99
04/27/22	8:26:00 AM	6.01	2.56	0.04	146.65	3.00	2.22	6.00
04/27/22	8:27:00 AM	5.99	2.56	0.04	145.66	2.93	2.22	5.96
04/27/22	8:28:00 AM	6.00	2.56	0.04	146.02	2.95	2.22	5.98
04/27/22	8:29:00 AM	6.04	2.59	0.04	144.51	3.00	2.22	6.01
04/27/22	8:30:00 AM	6.00	2.56	0.04	146.26	2.97	2.22	5.99
04/27/22	8:31:00 AM	6.38	2.53	0.04	158.58	3.04	2.22	6.43
04/27/22	8:32:00 AM	6.53	2.54	0.04	159.03	2.85	2.22	6.50
04/27/22	8:33:00 AM	6.49	2.50	0.04	157.74	2.70	2.22	6.47
04/27/22	8:34:00 AM	6.28	2.57	0.04	157.71	2.60	2.22	6.96
04/27/22	8:35:00 AM	5.05	2.66	0.18	154.02	3.31	2.22	6.27

Woodville DWS April 27, 2022 Test # 9- Well 1- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/27/22	8:25:00 AM	6.00	2.56	0.04	145.90	2.97	2.22	5.99
04/27/22	8:26:00 AM	6.01	2.56	0.04	146.65	3.00	2.22	6.00
04/27/22	8:27:00 AM	5.99	2.56	0.04	145.66	2.93	2.22	5.96
04/27/22	8:28:00 AM	6.00	2.56	0.04	146.02	2.95	2.22	5.98
04/27/22	8:29:00 AM	6.04	2.59	0.04	144.51	3.00	2.22	6.01
04/27/22	8:30:00 AM	6.00	2.56	0.04	146.26	2.97	2.22	5.99
04/27/22	8:31:00 AM	6.38	2.53	0.04	158.58	3.04	2.22	6.43
04/27/22	8:32:00 AM	6.53	2.54	0.04	159.03	2.85	2.22	6.50
04/27/22	8:33:00 AM	6.49	2.50	0.04	157.74	2.70	2.22	6.47
04/27/22	8:34:00 AM	6.28	2.57	0.04	157.71	2.60	2.22	6.96
04/27/22	8:35:00 AM	5.05	2.66	0.18	154.02	3.31	2.22	6.27
04/27/22	8:36:00 AM	1.24	2.59	0.09	23.50	3.10	2.22	0.68
04/27/22	8:37:00 AM	0.99	2.57	0.05	0.12	2.70	2.21	0.00
04/27/22	8:38:00 AM	1.50	2.59	0.05	0.21	2.76	2.21	0.42
04/27/22	8:39:00 AM	1.31	2.56	0.05	0.14	2.14	2.21	0.29
04/27/22	8:40:00 AM	1.47	2.60	0.04	8.89	2.22	2.21	0.52
04/27/22	8:41:00 AM	2.58	2.17	0.04	4.03	2.22	2.21	1.24
04/27/22	8:42:00 AM	4.80	2.77	0.05	143.17	2.56	2.20	6.20
04/27/22	8:43:00 AM	0.00	2.31	0.04	0.14	3.11	2.20	0.00
04/27/22	8:44:00 AM	5.91	2.79	0.05	149.73	2.46	2.19	6.97
04/27/22	8:45:00 AM	6.12	2.70	0.06	121.97	3.35	2.16	6.01
04/27/22	8:46:00 AM	6.07	2.65	0.04	123.89	2.61	2.16	6.04
04/27/22	8:47:00 AM	6.10	2.62	0.04	126.77	2.74	2.15	6.09
04/27/22	8:48:00 AM	6.10	2.60	0.04	127.37	2.81	2.16	6.08
04/27/22	8:49:00 AM	6.09	2.59	0.04	128.27	2.72	2.15	6.08
04/27/22	8:50:00 AM	6.21	2.57	0.04	133.40	3.05	2.15	6.23
04/27/22	8:51:00 AM	6.41	2.56	0.04	136.80	2.91	2.14	6.38
04/27/22	8:52:00 AM	6.40	2.53	0.04	137.11	2.92	2.12	6.37
04/27/22	8:53:00 AM	6.44	2.55	0.04	139.65	2.86	2.12	6.44
04/27/22	8:54:00 AM	6.51	2.52	0.04	140.94	2.52	2.12	6.50
04/27/22	8:55:00 AM	6.48	2.50	0.04	141.11	2.76	2.11	6.46
04/27/22	8:56:00 AM	6.51	2.49	0.04	142.12	3.06	2.11	6.48
04/27/22	8:57:00 AM	0.00	2.18	0.04	0.14	2.67	2.09	0.00
04/27/22	8:58:00 AM	0.00	2.21	0.04	142.31	3.16	2.10	6.74
04/27/22	8:59:00 AM	0.00	2.12	0.07	136.88	5.00	2.09	6.33
04/27/22	9:00:00 AM	0.00	2.08	0.04	138.64	2.70	2.09	6.44
04/27/22	9:01:00 AM	0.00	2.06	0.04	139.70	2.57	2.09	6.44
04/27/22	9:02:00 AM	0.00	2.05	0.04	140.20	2.57	2.09	6.46
04/27/22	9:03:00 AM	0.00	2.03	0.04	135.65	2.72	2.09	6.45
04/27/22	9:04:00 AM	0.00	2.02	0.04	134.36	2.96	2.09	6.46
04/27/22	9:05:00 AM	0.00	2.02	0.04	134.79	3.25	2.09	6.45
04/27/22	9:06:00 AM	0.00	2.01	0.04	134.64	2.91	2.09	6.45
04/27/22	9:07:00 AM	0.00	2.00	0.04	135.85	2.89	2.09	6.46
04/27/22	9:08:00 AM	0.00	2.01	0.04	119.31	2.92	2.09	5.85
04/27/22	9:09:00 AM	0.00	2.03	0.04	112.90	2.71	2.09	5.44
04/27/22	9:10:00 AM	0.00	2.04	0.04	112.25	3.10	2.09	5.44
04/27/22	9:11:00 AM	0.00	2.05	0.04	112.71	2.84	2.09	5.45
04/27/22	9:12:00 AM	2.64	2.06	0.04	0.29	2.68	2.11	1.23
04/27/22	9:13:00 AM	5.09	2.63	0.05	145.45	2.39	2.11	6.34
04/27/22	9:14:00 AM	0.00	2.26	0.04	0.14	3.57	2.11	0.00
04/27/22	9:15:00 AM	0.00	2.34	0.04	0.14	2.00	2.11	0.00
04/27/22	9:16:00 AM	0.00	2.40	0.04	0.14	1.64	2.11	0.00
04/27/22	9:17:00 AM	0.00	2.44	0.04	0.14	2.15	2.11	0.00
04/27/22	9:18:00 AM	0.00	2.47	0.04	0.14	5.00	2.11	0.00
04/27/22	9:19:00 AM	0.00	2.50	0.04	0.14	5.00	2.11	0.00
04/27/22	9:20:00 AM	0.00	2.52	0.04	0.14	5.00	2.11	0.00
04/27/22	9:21:00 AM	0.00	2.54	0.04	0.14	5.00	2.11	0.00
04/27/22	9:22:00 AM	4.61	2.34	0.06	13.58	5.00	2.11	3.50
04/27/22	9:23:00 AM	3.34	2.33	0.06	1.08	5.00	2.11	1.91
04/27/22	9:24:00 AM	5.98	2.89	0.05	145.02	3.09	2.11	7.02
04/27/22	9:25:00 AM	5.83	2.77	0.05	113.35	3.16	2.11	5.74
04/27/22	9:26:00 AM	5.78	2.73	0.04	115.91	2.67	2.11	5.78
04/27/22	9:27:00 AM	6.07	2.72	0.04	124.13	3.04	2.11	6.09
04/27/22	9:28:00 AM	6.17	2.68	0.04	126.41	2.92	2.11	6.17
04/27/22	9:29:00 AM	6.22	2.62	0.04	128.44	2.80	2.10	6.22
04/27/22	9:30:00 AM	6.36	2.60	0.04	132.44	3.00	2.09	6.36
04/27/22	9:31:00 AM	6.39	2.60	0.04	133.71	2.85	2.09	6.37
04/27/22	9:32:00 AM	6.41	2.57	0.04	134.67	2.81	2.09	6.40
04/27/22	9:33:00 AM	6.39	2.54	0.04	134.95	2.84	2.09	6.39
04/27/22	9:34:00 AM	6.41	2.54	0.04	136.22	2.62	2.09	6.42
04/27/22	9:35:00 AM	6.41	2.53	0.04	136.68	2.86	2.10	6.40

Woodville DWS April 27, 2022 Test # 10 - Well 1- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/27/22	9:25:00 AM	5.83	2.77	0.05	113.35	3.16	2.11	5.74
04/27/22	9:26:00 AM	5.78	2.73	0.04	115.91	2.67	2.11	5.78
04/27/22	9:27:00 AM	6.07	2.72	0.04	124.13	3.04	2.11	6.09
04/27/22	9:28:00 AM	6.17	2.68	0.04	126.41	2.92	2.11	6.17
04/27/22	9:29:00 AM	6.22	2.62	0.04	128.44	2.80	2.10	6.22
04/27/22	9:30:00 AM	6.36	2.60	0.04	132.44	3.00	2.09	6.36
04/27/22	9:31:00 AM	6.39	2.60	0.04	133.71	2.85	2.09	6.37
04/27/22	9:32:00 AM	6.41	2.57	0.04	134.67	2.81	2.09	6.40
04/27/22	9:33:00 AM	6.39	2.54	0.04	134.95	2.84	2.09	6.39
04/27/22	9:34:00 AM	6.41	2.54	0.04	136.22	2.62	2.09	6.42
04/27/22	9:35:00 AM	6.41	2.53	0.04	136.68	2.86	2.10	6.40
04/27/22	9:36:00 AM	6.39	2.56	0.04	136.64	2.57	2.10	6.36
04/27/22	9:37:00 AM	6.39	2.52	0.04	137.28	2.89	2.10	6.38
04/27/22	9:38:00 AM	6.39	2.54	0.04	138.17	2.75	2.11	6.40
04/27/22	9:39:00 AM	6.41	2.50	0.04	139.56	2.85	2.11	6.43
04/27/22	9:40:00 AM	6.39	2.52	0.04	139.27	2.96	2.11	6.40
04/27/22	9:41:00 AM	6.41	2.48	0.04	140.03	2.80	2.11	6.38
04/27/22	9:42:00 AM	6.40	2.49	0.04	139.87	2.72	2.11	6.38
04/27/22	9:43:00 AM	6.40	2.48	0.04	141.37	2.76	2.11	6.39
04/27/22	9:44:00 AM	6.38	2.50	0.04	142.82	3.05	2.12	6.38
04/27/22	9:45:00 AM	6.39	2.50	0.04	141.95	2.91	2.12	6.37
04/27/22	9:46:00 AM	4.14	1.97	0.04	12.22	2.77	2.12	3.02
04/27/22	9:47:00 AM	5.84	2.70	0.04	159.06	2.72	2.12	6.97
04/27/22	9:48:00 AM	5.87	2.61	0.06	123.10	4.84	2.12	5.80
04/27/22	9:49:00 AM	6.20	2.53	0.04	132.44	3.05	2.12	6.19
04/27/22	9:50:00 AM	6.19	2.52	0.04	132.68	2.65	2.14	6.14
04/27/22	9:51:00 AM	6.20	2.52	0.04	134.50	2.72	2.14	6.19
04/27/22	9:52:00 AM	6.21	2.49	0.04	142.70	3.07	2.14	6.32
04/27/22	9:53:00 AM	6.20	2.51	0.04	135.51	3.19	2.14	6.18
04/27/22	9:54:00 AM	6.19	2.51	0.04	136.40	3.15	2.14	6.17
04/27/22	9:55:00 AM	6.21	2.48	0.04	137.30	3.19	2.14	6.18
04/27/22	9:56:00 AM	6.18	2.49	0.04	137.04	3.11	2.15	6.17
04/27/22	9:57:00 AM	6.20	2.49	0.04	138.36	3.09	2.15	6.19
04/27/22	9:58:00 AM	6.25	2.48	0.04	138.60	3.27	2.15	6.22
04/27/22	9:59:00 AM	6.18	2.48	0.04	138.72	3.37	2.14	6.15
04/27/22	10:00:00 AM	6.20	2.48	0.04	140.16	3.09	2.14	6.19
04/27/22	10:01:00 AM	6.19	2.49	0.04	139.61	3.07	2.12	6.17
04/27/22	10:02:00 AM	6.19	2.47	0.04	140.85	3.19	2.12	6.18
04/27/22	10:03:00 AM	6.21	2.47	0.04	142.14	3.65	2.12	6.18
04/27/22	10:04:00 AM	6.18	2.46	0.04	142.36	3.20	2.12	6.17
04/27/22	10:05:00 AM	6.21	2.48	0.04	143.36	3.41	2.11	6.20
04/27/22	10:06:00 AM	6.20	2.46	0.04	144.09	3.37	2.11	6.19
04/27/22	10:07:00 AM	6.21	2.44	0.04	144.58	3.37	2.11	6.19
04/27/22	10:08:00 AM	6.19	2.46	0.04	145.38	3.32	2.11	6.20
04/27/22	10:09:00 AM	6.19	2.47	0.04	146.09	3.35	2.11	6.19
04/27/22	10:10:00 AM	6.21	2.45	0.04	147.03	3.61	2.11	6.19
04/27/22	10:11:00 AM	6.27	2.45	0.04	147.48	3.07	2.11	6.27
04/27/22	10:12:00 AM	6.23	2.49	0.04	148.20	3.16	2.11	6.20
04/27/22	10:13:00 AM	6.18	2.47	0.04	148.58	3.04	2.11	6.15
04/27/22	10:14:00 AM	6.21	2.46	0.04	149.74	3.15	2.11	6.18
04/27/22	10:15:00 AM	6.21	2.46	0.04	150.45	3.14	2.12	6.19
04/27/22	10:16:00 AM	6.18	2.47	0.04	150.21	3.04	2.12	6.16
04/27/22	10:17:00 AM	6.18	2.46	0.04	151.39	3.14	2.12	6.17
04/27/22	10:18:00 AM	6.21	2.45	0.04	152.82	3.25	2.12	6.21
04/27/22	10:19:00 AM	6.18	2.42	0.04	152.33	3.23	2.12	6.16
04/27/22	10:20:00 AM	6.21	2.43	0.04	153.81	3.39	2.12	6.20
04/27/22	10:21:00 AM	6.18	2.43	0.04	153.42	3.57	2.12	6.16
04/27/22	10:22:00 AM	6.20	2.45	0.04	154.76	3.37	2.14	6.21
04/27/22	10:23:00 AM	6.20	2.45	0.04	154.72	3.32	2.14	6.17
04/27/22	10:24:00 AM	6.20	2.44	0.04	156.06	3.44	2.15	6.18
04/27/22	10:25:00 AM	6.16	2.45	0.04	153.42	3.25	2.16	6.11
04/27/22	10:26:00 AM	6.21	2.46	0.04	154.70	3.39	2.16	6.15
04/27/22	10:27:00 AM	6.19	2.45	0.04	155.94	3.39	2.16	6.14
04/27/22	10:28:00 AM	6.21	2.42	0.04	158.55	3.26	2.16	6.20
04/27/22	10:29:00 AM	6.21	2.43	0.04	158.34	3.10	2.16	6.20
04/27/22	10:30:00 AM	6.18	2.43	0.04	158.33	3.35	2.16	6.16
04/27/22	10:31:00 AM	2.51	2.41	0.04	62.06	3.25	2.15	2.56
04/27/22	10:32:00 AM	2.54	2.45	0.04	59.91	4.10	2.15	2.52
04/27/22	10:33:00 AM	2.50	2.49	0.04	59.58	3.85	2.15	2.49
04/27/22	10:34:00 AM	2.51	2.52	0.04	60.25	3.56	2.15	2.50
04/27/22	10:35:00 AM	2.52	2.54	0.04	61.03	3.50	2.15	2.52

Woodville DWS April 27, 2022 Test # 11 - Well 1 & 2- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/27/22	10:32:00 AM	2.54	2.45	0.00	8.05	0.04	59.91	4.10	2.15	2.52
04/27/22	10:33:00 AM	2.50	2.49	0.00	8.11	0.04	59.58	3.85	2.15	2.49
04/27/22	10:34:00 AM	2.51	2.52	0.00	8.12	0.04	60.25	3.56	2.15	2.50
04/27/22	10:35:00 AM	2.52	2.54	0.00	8.14	0.04	61.03	3.50	2.15	2.52
04/27/22	10:36:00 AM	2.51	2.56	0.00	8.17	0.04	60.99	3.45	2.14	2.52
04/27/22	10:37:00 AM	2.49	2.57	0.00	8.16	0.04	59.79	3.62	2.15	2.48
04/27/22	10:38:00 AM	2.42	2.58	2.60	8.03	0.04	138.33	3.56	2.15	5.19
04/27/22	10:39:00 AM	2.49	2.56	2.52	8.01	0.04	124.83	3.56	2.15	4.98
04/27/22	10:40:00 AM	2.50	2.55	2.54	7.97	0.04	126.84	3.35	2.14	5.03
04/27/22	10:41:00 AM	2.49	2.47	2.50	7.94	0.04	126.09	3.07	2.15	4.97
04/27/22	10:42:00 AM	2.49	2.54	2.51	7.96	0.04	126.72	3.20	2.15	4.96
04/27/22	10:43:00 AM	2.49	2.47	2.48	7.94	0.04	126.19	3.89	2.14	4.94
04/27/22	10:44:00 AM	2.52	2.47	2.49	7.94	0.04	127.51	3.84	2.15	4.98
04/27/22	10:45:00 AM	2.52	2.47	2.59	7.91	0.04	134.50	3.25	2.14	5.10
04/27/22	10:46:00 AM	2.50	2.50	2.54	7.94	0.04	127.98	3.44	2.15	5.00
04/27/22	10:47:00 AM	2.49	2.48	2.48	7.92	0.04	127.08	3.54	2.15	4.94
04/27/22	10:48:00 AM	2.54	2.48	2.51	7.92	0.04	128.87	3.35	2.14	5.03
04/27/22	10:49:00 AM	2.50	2.48	2.48	7.93	0.04	127.08	3.44	2.15	4.95
04/27/22	10:50:00 AM	2.49	2.45	2.52	7.90	0.04	128.61	3.50	2.15	4.98
04/27/22	10:51:00 AM	2.49	2.47	2.52	7.92	0.04	128.08	3.65	2.15	4.99
04/27/22	10:52:00 AM	2.49	2.50	2.52	7.92	0.04	128.63	3.40	2.15	4.98
04/27/22	10:53:00 AM	2.50	2.48	2.53	7.91	0.04	128.73	3.50	2.15	5.01
04/27/22	10:54:00 AM	2.50	2.50	2.54	7.92	0.04	128.83	3.60	2.15	5.00
04/27/22	10:55:00 AM	2.53	2.51	2.35	7.94	0.04	127.17	3.72	2.15	4.84
04/27/22	10:56:00 AM	2.47	2.48	2.51	7.91	0.04	128.87	3.35	2.15	4.97
04/27/22	10:57:00 AM	2.49	2.50	2.53	7.91	0.04	129.45	3.27	2.15	4.99
04/27/22	10:58:00 AM	2.50	2.50	2.51	7.94	0.04	127.86	3.46	2.15	4.98
04/27/22	10:59:00 AM	2.51	2.48	2.50	7.92	0.04	129.23	3.44	2.15	4.97
04/27/22	11:00:00 AM	2.47	2.48	2.51	7.94	0.04	127.53	3.35	2.15	4.95
04/27/22	11:01:00 AM	2.51	2.48	2.52	7.91	0.04	129.55	3.35	2.15	5.00
04/27/22	11:02:00 AM	2.49	2.52	2.53	7.93	0.04	129.50	3.10	2.16	4.99
04/27/22	11:03:00 AM	2.50	2.46	2.49	7.92	0.04	128.92	3.20	2.16	4.95
04/27/22	11:04:00 AM	2.49	2.46	2.51	7.92	0.04	130.02	3.61	2.16	4.97
04/27/22	11:05:00 AM	2.50	2.49	2.51	7.90	0.04	130.07	3.19	2.16	4.97
04/27/22	11:06:00 AM	2.34	2.49	2.21	7.96	0.04	114.41	3.16	2.16	4.49
04/27/22	11:07:00 AM	2.49	2.52	2.51	7.95	0.04	131.82	3.46	2.16	4.96
04/27/22	11:08:00 AM	2.49	2.45	2.51	7.90	0.04	130.79	3.50	2.19	4.96
04/27/22	11:09:00 AM	2.51	2.44	2.45	7.93	0.04	129.83	3.39	2.19	4.93
04/27/22	11:10:00 AM	2.50	2.46	2.53	7.90	0.04	130.21	3.35	2.20	4.98
04/27/22	11:11:00 AM	2.51	2.50	2.48	7.94	0.04	131.98	3.65	2.20	4.99
04/27/22	11:12:00 AM	2.49	2.49	2.51	7.93	0.04	131.79	3.35	2.20	4.99
04/27/22	11:13:00 AM	2.48	2.48	2.48	7.92	0.04	128.75	3.50	2.21	4.92
04/27/22	11:14:00 AM	2.49	2.47	2.50	7.92	0.04	131.05	3.54	2.22	4.96
04/27/22	11:15:00 AM	2.48	2.46	2.51	7.90	0.04	131.29	3.42	2.24	4.96
04/27/22	11:16:00 AM	2.53	2.51	2.48	7.91	0.04	132.11	3.55	2.26	4.98
04/27/22	11:17:00 AM	2.49	2.44	2.51	7.91	0.04	132.23	3.46	2.27	4.96
04/27/22	11:18:00 AM	2.52	2.48	2.49	7.90	0.04	132.20	3.35	2.27	4.97
04/27/22	11:19:00 AM	2.49	2.46	2.52	7.91	0.04	132.64	3.39	2.27	4.97
04/27/22	11:20:00 AM	2.49	2.47	2.50	7.92	0.04	132.83	3.65	2.30	4.95
04/27/22	11:21:00 AM	2.50	2.48	2.51	7.90	0.04	132.83	3.30	2.30	4.97
04/27/22	11:22:00 AM	2.51	2.46	2.48	7.91	0.04	129.80	3.51	2.32	4.92
04/27/22	11:23:00 AM	2.53	2.48	2.48	7.92	0.04	133.40	3.44	2.34	4.98
04/27/22	11:24:00 AM	2.50	2.42	2.49	7.90	0.04	133.26	3.45	2.34	4.97
04/27/22	11:25:00 AM	2.47	2.45	2.52	7.91	0.04	132.94	3.55	2.36	4.97
04/27/22	11:26:00 AM	2.49	2.48	2.54	7.91	0.04	133.97	3.30	2.37	4.99
04/27/22	11:27:00 AM	2.53	2.48	2.57	7.90	0.04	137.57	3.35	2.40	5.08
04/27/22	11:28:00 AM	2.49	2.50	2.50	7.91	0.04	133.26	3.21	2.40	4.97
04/27/22	11:29:00 AM	2.53	2.50	2.54	7.91	0.04	135.77	3.46	2.41	5.02
04/27/22	11:30:00 AM	2.48	2.48	2.51	7.91	0.04	133.35	3.15	2.42	4.95
04/27/22	11:31:00 AM	2.50	2.47	2.49	7.91	0.04	133.38	3.24	2.42	4.96
04/27/22	11:32:00 AM	2.51	2.47	2.47	7.91	0.04	134.10	3.45	2.44	4.96
04/27/22	11:33:00 AM	2.37	2.48	2.30	7.96	0.04	116.46	3.25	2.44	4.58
04/27/22	11:34:00 AM	2.53	2.46	2.55	7.89	0.04	137.97	3.51	2.45	5.06
04/27/22	11:35:00 AM	2.50	2.49	2.52	7.91	0.04	133.71	3.02	2.45	4.98
04/27/22	11:36:00 AM	2.50	2.52	2.50	7.92	0.04	135.32	3.07	2.46	4.98
04/27/22	11:37:00 AM	2.50	2.48	2.51	7.90	0.04	135.08	3.03	2.46	4.98
04/27/22	11:38:00 AM	2.85	2.47	3.02	7.86	0.04	106.71	3.19	2.46	4.90
04/27/22	11:39:00 AM	2.80	2.45	2.78	7.86	0.05	143.15	3.15	2.46	5.53
04/27/22	11:40:00 AM	2.71	2.45	2.76	7.86	0.04	139.20	3.30	2.46	5.44
04/27/22	11:41:00 AM	2.76	2.47	2.75	7.89	0.04	140.90	3.35	2.47	5.48
04/27/22	11:42:00 AM	2.75	2.42	2.76	7.85	0.04	140.15	3.19	2.47	5.47

Woodville DWS April 27, 2022 Test # 12 - Well 1 & 2- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/27/22	11:32:00 AM	2.51	2.47	2.47	7.91	0.04	134.10	3.45	2.44	4.96
04/27/22	11:33:00 AM	2.37	2.48	2.30	7.96	0.04	116.46	3.25	2.44	4.58
04/27/22	11:34:00 AM	2.53	2.46	2.55	7.89	0.04	137.97	3.51	2.45	5.06
04/27/22	11:35:00 AM	2.50	2.49	2.52	7.91	0.04	133.71	3.02	2.45	4.98
04/27/22	11:36:00 AM	2.50	2.52	2.50	7.92	0.04	135.32	3.07	2.46	4.98
04/27/22	11:37:00 AM	2.50	2.48	2.51	7.90	0.04	135.08	3.03	2.46	4.98
04/27/22	11:38:00 AM	2.85	2.47	3.02	7.86	0.04	106.71	3.19	2.46	4.90
04/27/22	11:39:00 AM	2.80	2.45	2.78	7.86	0.05	143.15	3.15	2.46	5.53
04/27/22	11:40:00 AM	2.71	2.45	2.76	7.86	0.04	139.20	3.30	2.46	5.44
04/27/22	11:41:00 AM	2.76	2.47	2.75	7.89	0.04	140.90	3.35	2.47	5.48
04/27/22	11:42:00 AM	2.75	2.42	2.76	7.85	0.04	140.15	3.19	2.47	5.47
04/27/22	11:43:00 AM	2.75	2.42	2.76	7.84	0.04	141.45	3.30	2.47	5.49
04/27/22	11:44:00 AM	2.75	2.45	2.76	7.88	0.04	141.18	3.51	2.47	5.48
04/27/22	11:45:00 AM	2.76	2.43	2.69	7.88	0.04	140.15	3.38	2.47	5.43
04/27/22	11:46:00 AM	2.75	2.42	2.75	7.84	0.04	140.99	3.25	2.47	5.46
04/27/22	11:47:00 AM	2.76	2.44	2.75	7.87	0.04	141.42	3.34	2.47	5.47
04/27/22	11:48:00 AM	2.75	2.47	2.74	7.88	0.04	141.04	3.07	2.47	5.44
04/27/22	11:49:00 AM	2.75	2.43	2.76	7.86	0.04	142.82	3.07	2.49	5.49
04/27/22	11:50:00 AM	2.74	2.46	2.73	7.86	0.04	140.61	3.40	2.49	5.43
04/27/22	11:51:00 AM	2.78	2.41	2.73	7.86	0.04	142.77	3.67	2.49	5.50
04/27/22	11:52:00 AM	2.74	2.44	2.72	7.88	0.04	141.06	3.39	2.49	5.43
04/27/22	11:53:00 AM	2.73	2.44	2.79	7.84	0.04	143.39	3.37	2.49	5.49
04/27/22	11:54:00 AM	2.75	2.42	2.73	7.85	0.04	141.52	3.10	2.49	5.43
04/27/22	11:55:00 AM	2.78	2.43	2.71	7.85	0.04	142.60	3.46	2.49	5.47
04/27/22	11:56:00 AM	2.74	2.43	2.72	7.85	0.04	141.18	3.35	2.49	5.43
04/27/22	11:57:00 AM	2.79	2.40	2.72	7.84	0.04	143.15	3.49	2.49	5.48
04/27/22	11:58:00 AM	2.74	2.40	2.70	7.84	0.04	141.50	3.56	2.49	5.39
04/27/22	11:59:00 AM	2.74	2.43	2.77	7.83	0.04	142.69	3.51	2.49	5.46
04/27/22	12:00:00 PM	2.76	2.45	2.75	7.85	0.04	144.04	3.25	2.50	5.48
04/27/22	12:01:00 PM	2.72	2.40	2.79	7.86	0.04	144.52	3.35	2.50	5.49
04/27/22	12:02:00 PM	2.77	2.41	2.79	7.83	0.04	145.95	3.32	2.50	5.53
04/27/22	12:03:00 PM	2.74	2.43	2.71	7.83	0.04	142.05	3.16	2.50	5.43
04/27/22	12:04:00 PM	2.76	2.42	2.76	7.83	0.04	144.78	3.32	2.50	5.50
04/27/22	12:05:00 PM	2.73	2.43	2.70	7.82	0.04	142.48	3.24	2.51	5.41
04/27/22	12:06:00 PM	2.76	2.40	2.76	7.82	0.04	144.73	3.44	2.50	5.48
04/27/22	12:07:00 PM	2.71	2.39	2.77	7.83	0.04	144.23	3.42	2.50	5.45
04/27/22	12:08:00 PM	2.76	2.44	2.75	7.86	0.04	144.85	3.32	2.50	5.46
04/27/22	12:09:00 PM	2.72	2.40	2.71	7.82	0.04	142.43	3.42	2.50	5.39
04/27/22	12:10:00 PM	2.76	2.41	2.75	7.84	0.04	145.35	3.07	2.50	5.47
04/27/22	12:11:00 PM	2.76	2.46	2.74	7.84	0.04	144.90	3.41	2.50	5.47
04/27/22	12:12:00 PM	2.76	2.40	2.76	7.81	0.04	145.95	3.44	2.50	5.49
04/27/22	12:13:00 PM	2.74	2.40	2.78	7.83	0.04	145.43	3.44	2.50	5.50
04/27/22	12:14:00 PM	2.76	2.39	2.75	7.81	0.04	145.33	3.27	2.50	5.47
04/27/22	12:15:00 PM	2.76	2.41	2.75	7.84	0.04	145.67	3.60	2.50	5.48
04/27/22	12:16:00 PM	2.75	2.44	2.74	7.83	0.04	145.07	3.65	2.50	5.46
04/27/22	12:17:00 PM	2.76	2.38	2.74	7.83	0.04	145.64	3.42	2.50	5.47
04/27/22	12:18:00 PM	2.76	2.39	2.74	7.83	0.04	145.55	3.55	2.50	5.47
04/27/22	12:19:00 PM	2.75	2.38	2.74	7.82	0.04	146.12	3.25	2.50	5.47
04/27/22	12:20:00 PM	2.76	2.42	2.75	7.86	0.04	146.31	3.40	2.50	5.46
04/27/22	12:21:00 PM	2.75	2.43	2.72	7.84	0.04	145.52	3.19	2.50	5.44
04/27/22	12:22:00 PM	2.74	2.44	2.74	7.85	0.04	145.86	3.41	2.50	5.45
04/27/22	12:23:00 PM	2.74	2.44	2.78	7.83	0.04	146.05	3.56	2.50	5.47
04/27/22	12:24:00 PM	2.77	2.45	2.76	7.83	0.04	147.03	3.35	2.50	5.49
04/27/22	12:25:00 PM	2.74	2.43	2.72	7.83	0.04	145.71	3.56	2.50	5.45
04/27/22	12:26:00 PM	2.75	2.39	2.74	7.84	0.04	146.12	3.46	2.50	5.44
04/27/22	12:27:00 PM	2.79	2.38	2.71	7.84	0.04	146.58	3.30	2.50	5.46
04/27/22	12:28:00 PM	2.74	2.43	2.72	7.85	0.04	145.50	3.30	2.50	5.43
04/27/22	12:29:00 PM	2.78	2.42	2.75	7.83	0.04	146.93	3.25	2.50	5.49
04/27/22	12:30:00 PM	2.74	2.40	2.73	7.84	0.04	146.02	3.32	2.49	5.44
04/27/22	12:31:00 PM	2.77	2.37	2.76	7.84	0.04	148.15	3.11	2.50	5.50
04/27/22	12:32:00 PM	2.73	2.45	2.79	7.84	0.04	147.77	3.27	2.50	5.47
04/27/22	12:33:00 PM	2.76	2.38	2.77	7.82	0.04	148.59	3.56	2.50	5.50
04/27/22	12:34:00 PM	2.75	2.40	2.72	7.84	0.04	146.53	3.27	2.50	5.43
04/27/22	12:35:00 PM	2.77	2.42	2.76	7.85	0.04	148.23	3.30	2.49	5.47
04/27/22	12:36:00 PM	2.73	2.43	2.71	7.84	0.04	145.28	3.20	2.50	5.41
04/27/22	12:37:00 PM	2.78	2.39	2.74	7.84	0.04	149.97	3.46	2.50	5.49
04/27/22	12:38:00 PM	2.75	2.43	2.70	7.84	0.04	146.46	3.30	2.50	5.43
04/27/22	12:39:00 PM	3.02	2.37	2.99	7.80	0.04	161.79	3.35	2.50	5.97
04/27/22	12:40:00 PM	2.99	2.37	3.00	7.78	0.04	160.54	3.32	2.50	5.93
04/27/22	12:41:00 PM	3.01	2.39	2.98	7.78	0.04	160.87	3.30	2.50	5.97
04/27/22	12:42:00 PM	2.98	2.36	3.00	7.77	0.04	159.99	3.07	2.50	5.94

Woodville DWS April 27, 2022 Test # 13 - Well 1 & 2- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/27/22	12:32:00 PM	2.73	2.45	2.79	7.84	0.04	147.77	3.27	2.50	5.47
04/27/22	12:33:00 PM	2.76	2.38	2.77	7.82	0.04	148.59	3.56	2.50	5.50
04/27/22	12:34:00 PM	2.75	2.40	2.72	7.84	0.04	146.53	3.27	2.50	5.43
04/27/22	12:35:00 PM	2.77	2.42	2.76	7.85	0.04	148.23	3.30	2.49	5.47
04/27/22	12:36:00 PM	2.73	2.43	2.71	7.84	0.04	145.28	3.20	2.50	5.41
04/27/22	12:37:00 PM	2.78	2.39	2.74	7.84	0.04	149.97	3.46	2.50	5.49
04/27/22	12:38:00 PM	2.75	2.43	2.70	7.84	0.04	146.46	3.30	2.50	5.43
04/27/22	12:39:00 PM	3.02	2.37	2.99	7.80	0.04	161.79	3.35	2.50	5.97
04/27/22	12:40:00 PM	2.99	2.37	3.00	7.78	0.04	160.54	3.32	2.50	5.93
04/27/22	12:41:00 PM	3.01	2.39	2.98	7.78	0.04	160.87	3.30	2.50	5.97
04/27/22	12:42:00 PM	2.98	2.36	3.00	7.77	0.04	159.99	3.07	2.50	5.94
04/27/22	12:43:00 PM	3.01	2.40	3.03	7.79	0.04	161.57	3.30	2.50	6.00
04/27/22	12:44:00 PM	2.97	2.36	2.99	7.77	0.04	159.85	3.50	2.50	5.93
04/27/22	12:45:00 PM	3.00	2.38	3.01	7.76	0.04	161.31	3.41	2.50	5.96
04/27/22	12:46:00 PM	3.01	2.35	2.98	7.77	0.04	161.33	3.07	2.50	5.96
04/27/22	12:47:00 PM	2.98	2.37	2.98	7.78	0.04	159.84	3.39	2.50	5.93
04/27/22	12:48:00 PM	3.00	2.38	3.03	7.76	0.04	162.67	3.35	2.50	5.99
04/27/22	12:49:00 PM	3.01	2.33	2.98	7.79	0.04	161.91	3.35	2.50	5.97
04/27/22	12:50:00 PM	3.00	2.36	2.97	7.77	0.04	162.12	3.39	2.50	5.94
04/27/22	12:51:00 PM	3.01	2.33	2.97	7.77	0.04	161.98	3.30	2.50	5.94
04/27/22	12:52:00 PM	2.99	2.37	3.01	7.77	0.04	163.06	3.11	2.50	5.95
04/27/22	12:53:00 PM	2.99	2.37	3.04	7.75	0.04	164.51	3.21	2.50	5.98
04/27/22	12:54:00 PM	2.99	2.37	3.03	7.76	0.04	164.44	3.37	2.49	5.97
04/27/22	12:55:00 PM	3.01	2.37	2.99	7.75	0.04	162.38	3.19	2.49	5.96
04/27/22	12:56:00 PM	3.00	2.36	3.02	7.76	0.04	165.02	3.40	2.49	5.97
04/27/22	12:57:00 PM	2.95	2.33	2.94	7.76	0.04	165.11	3.56	2.49	5.82
04/27/22	12:58:00 PM	3.00	2.35	3.04	7.78	0.04	164.80	3.67	2.48	6.00
04/27/22	12:59:00 PM	3.00	2.35	2.99	7.75	0.04	166.14	3.65	2.47	5.95
04/27/22	1:00:00 PM	2.99	2.34	2.98	7.77	0.04	165.19	3.40	2.47	5.93
04/27/22	1:01:00 PM	3.01	2.35	2.97	7.75	0.04	165.02	3.50	2.47	5.93
04/27/22	1:02:00 PM	3.10	2.35	3.29	7.75	0.04	185.43	3.46	2.47	6.45
04/27/22	1:03:00 PM	3.01	2.33	2.96	7.74	0.04	164.02	3.14	2.47	5.94
04/27/22	1:04:00 PM	3.00	2.35	3.01	7.76	0.04	165.05	3.11	2.47	5.97
04/27/22	1:05:00 PM	3.00	2.33	3.01	7.76	0.04	165.35	3.00	2.47	5.97
04/27/22	1:06:00 PM	2.99	2.36	3.02	7.76	0.04	166.19	3.00	2.47	5.97
04/27/22	1:07:00 PM	3.05	2.34	3.08	7.75	0.04	159.65	3.37	2.47	6.09
04/27/22	1:08:00 PM	3.07	2.32	3.15	7.74	0.04	181.84	3.51	2.47	6.24
04/27/22	1:09:00 PM	3.01	2.39	2.98	7.77	0.04	165.28	3.36	2.47	5.95
04/27/22	1:10:00 PM	2.99	2.36	2.99	7.75	0.04	164.78	3.14	2.47	5.95
04/27/22	1:11:00 PM	3.00	2.35	3.01	7.75	0.04	166.91	3.44	2.47	5.97
04/27/22	1:12:00 PM	3.01	2.33	2.99	7.76	0.04	167.20	3.35	2.47	5.95
04/27/22	1:13:00 PM	3.00	2.32	3.02	7.74	0.04	167.06	3.27	2.47	5.98
04/27/22	1:14:00 PM	3.01	2.33	3.00	7.74	0.04	167.94	3.25	2.47	5.97
04/27/22	1:15:00 PM	2.98	2.32	3.01	7.74	0.04	167.87	3.51	2.49	5.95
04/27/22	1:16:00 PM	3.03	2.36	2.99	7.76	0.04	169.07	3.30	2.49	5.98
04/27/22	1:17:00 PM	2.91	2.32	2.85	7.75	0.04	158.67	3.54	2.49	5.68
04/27/22	1:18:00 PM	3.00	2.35	3.03	7.75	0.04	170.38	3.35	2.49	5.98
04/27/22	1:19:00 PM	3.00	2.34	3.03	7.76	0.04	170.20	3.30	2.49	5.99
04/27/22	1:20:00 PM	3.00	2.33	3.03	7.78	0.04	169.91	3.40	2.49	5.99
04/27/22	1:21:00 PM	2.95	2.33	3.02	7.74	0.04	168.75	3.51	2.49	5.94
04/27/22	1:22:00 PM	3.00	2.36	3.00	7.76	0.04	170.15	3.35	2.49	5.94
04/27/22	1:23:00 PM	3.01	2.35	2.98	7.74	0.04	170.24	3.27	2.50	5.95
04/27/22	1:24:00 PM	2.98	2.33	2.99	7.73	0.04	169.11	3.35	2.50	5.91
04/27/22	1:25:00 PM	3.01	2.33	2.97	7.74	0.04	169.84	3.19	2.50	5.94
04/27/22	1:26:00 PM	3.02	2.32	2.98	7.74	0.04	170.24	3.40	2.50	5.94
04/27/22	1:27:00 PM	3.00	2.36	3.04	7.72	0.04	172.14	3.25	2.50	5.99
04/27/22	1:28:00 PM	2.98	2.36	3.00	7.75	0.04	170.53	3.30	2.50	5.95
04/27/22	1:29:00 PM	3.00	2.33	2.99	7.74	0.04	171.27	3.44	2.50	5.97
04/27/22	1:30:00 PM	2.99	2.34	3.02	7.75	0.04	171.58	3.16	2.50	5.99
04/27/22	1:31:00 PM	3.03	2.34	3.00	7.73	0.04	172.83	2.76	2.50	6.00
04/27/22	1:32:00 PM	3.01	2.31	3.01	7.74	0.04	171.96	3.10	2.50	5.95
04/27/22	1:33:00 PM	3.01	2.35	2.97	7.75	0.04	171.44	3.19	2.50	5.95
04/27/22	1:34:00 PM	3.01	2.33	2.97	7.73	0.04	172.04	3.10	2.50	5.95
04/27/22	1:35:00 PM	3.01	2.30	2.97	7.75	0.04	165.11	3.10	2.49	5.94
04/27/22	1:36:00 PM	3.03	2.31	2.99	7.75	0.04	171.39	3.24	2.50	5.98
04/27/22	1:37:00 PM	2.99	2.36	3.01	7.73	0.04	171.78	3.30	2.50	5.97
04/27/22	1:38:00 PM	3.25	2.33	3.25	7.71	0.04	186.46	3.24	2.50	6.47
04/27/22	1:39:00 PM	3.26	2.30	3.26	7.72	0.04	184.61	3.15	2.50	6.44
04/27/22	1:40:00 PM	3.26	2.29	3.25	7.72	0.04	185.36	3.27	2.50	6.48
04/27/22	1:41:00 PM	3.22	2.30	3.20	7.70	0.04	187.80	3.37	2.50	6.35
04/27/22	1:42:00 PM	3.25	2.28	3.25	7.68	0.04	183.15	3.44	2.50	6.45

Woodville DWS April 27, 2022 Test # 14 - Well 1 & 2- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/27/22	1:32:00 PM	3.01	2.31	3.01	7.74	0.04	171.96	3.10	2.50	5.95
04/27/22	1:33:00 PM	3.01	2.35	2.97	7.75	0.04	171.44	3.19	2.50	5.95
04/27/22	1:34:00 PM	3.01	2.33	2.97	7.73	0.04	172.04	3.10	2.50	5.95
04/27/22	1:35:00 PM	3.01	2.30	2.97	7.75	0.04	165.11	3.10	2.49	5.94
04/27/22	1:36:00 PM	3.03	2.31	2.99	7.75	0.04	171.39	3.24	2.50	5.98
04/27/22	1:37:00 PM	2.99	2.36	3.01	7.73	0.04	171.78	3.30	2.50	5.97
04/27/22	1:38:00 PM	3.25	2.33	3.25	7.71	0.04	186.46	3.24	2.50	6.47
04/27/22	1:39:00 PM	3.26	2.30	3.26	7.72	0.04	184.61	3.15	2.50	6.44
04/27/22	1:40:00 PM	3.26	2.29	3.25	7.72	0.04	185.36	3.27	2.50	6.48
04/27/22	1:41:00 PM	3.22	2.30	3.20	7.70	0.04	187.80	3.37	2.50	6.35
04/27/22	1:42:00 PM	3.25	2.28	3.25	7.68	0.04	183.15	3.44	2.50	6.45
04/27/22	1:43:00 PM	3.25	2.28	3.24	7.68	0.04	183.23	3.35	2.50	6.44
04/27/22	1:44:00 PM	3.25	2.27	3.23	7.68	0.04	183.01	3.25	2.50	6.44
04/27/22	1:45:00 PM	3.25	2.31	3.24	7.70	0.04	184.14	3.32	2.50	6.44
04/27/22	1:46:00 PM	3.25	2.29	3.24	7.71	0.04	183.71	3.10	2.50	6.42
04/27/22	1:47:00 PM	3.26	2.33	3.45	7.67	0.04	206.70	3.40	2.50	6.75
04/27/22	1:48:00 PM	3.26	2.30	3.26	7.67	0.04	182.72	3.21	2.50	6.45
04/27/22	1:49:00 PM	3.24	2.27	3.23	7.69	0.04	182.84	3.40	2.50	6.44
04/27/22	1:50:00 PM	3.23	2.32	3.27	7.68	0.04	183.61	3.23	2.50	6.46
04/27/22	1:51:00 PM	3.24	2.27	3.26	7.70	0.04	185.36	3.46	2.50	6.48
04/27/22	1:52:00 PM	3.22	2.30	3.39	7.69	0.04	192.40	3.12	2.50	6.59
04/27/22	1:53:00 PM	3.26	2.28	3.25	7.71	0.04	183.96	3.16	2.50	6.48
04/27/22	1:54:00 PM	3.24	2.29	3.23	7.67	0.04	182.63	3.20	2.50	6.43
04/27/22	1:55:00 PM	3.27	2.28	3.26	7.70	0.04	184.80	3.16	2.50	6.48
04/27/22	1:56:00 PM	3.23	2.28	3.23	7.67	0.04	183.44	3.39	2.50	6.43
04/27/22	1:57:00 PM	3.28	2.26	3.23	7.69	0.04	184.69	3.46	2.50	6.47
04/27/22	1:58:00 PM	3.23	2.31	3.24	7.73	0.04	183.56	3.21	2.50	6.42
04/27/22	1:59:00 PM	3.24	2.30	3.27	7.68	0.04	184.99	3.26	2.50	6.46
04/27/22	2:00:00 PM	3.25	2.29	3.26	7.64	0.04	186.15	3.26	2.50	6.48
04/27/22	2:01:00 PM	3.24	2.28	3.22	7.66	0.04	184.18	2.97	2.50	6.42
04/27/22	2:02:00 PM	3.27	2.27	3.22	7.67	0.04	185.64	3.16	2.50	6.46
04/27/22	2:03:00 PM	3.24	2.27	3.24	7.70	0.04	184.66	3.20	2.50	6.41
04/27/22	2:04:00 PM	3.27	2.30	3.26	7.68	0.04	186.94	3.15	2.50	6.48
04/27/22	2:05:00 PM	3.35	2.25	3.52	7.63	0.04	190.32	3.30	2.50	6.89
04/27/22	2:06:00 PM	3.25	2.30	3.24	7.68	0.04	184.16	3.49	2.50	6.45
04/27/22	2:07:00 PM	3.23	2.25	3.28	7.70	0.04	184.52	3.19	2.50	6.47
04/27/22	2:08:00 PM	3.25	2.28	3.23	7.69	0.04	183.47	3.39	2.50	6.45
04/27/22	2:09:00 PM	3.34	2.26	3.51	7.61	0.04	205.04	3.09	2.50	6.86
04/27/22	2:10:00 PM	3.28	2.26	3.24	7.66	0.04	185.21	2.91	2.50	6.49
04/27/22	2:11:00 PM	3.23	2.28	3.23	7.65	0.04	183.29	3.30	2.50	6.44
04/27/22	2:12:00 PM	3.27	2.27	3.28	7.70	0.04	186.55	3.27	2.49	6.51
04/27/22	2:13:00 PM	3.24	2.28	3.23	7.65	0.04	184.37	3.38	2.50	6.44
04/27/22	2:14:00 PM	3.28	2.27	3.22	7.69	0.04	185.23	3.43	2.50	6.45
04/27/22	2:15:00 PM	3.09	2.29	2.97	7.70	0.04	177.55	3.30	2.50	5.98
04/27/22	2:16:00 PM	3.26	2.26	3.28	7.67	0.04	187.46	3.14	2.50	6.50
04/27/22	2:17:00 PM	3.25	2.28	3.25	7.67	0.04	184.66	3.14	2.50	6.46
04/27/22	2:18:00 PM	3.25	2.29	3.23	7.69	0.04	183.90	3.30	2.50	6.44
04/27/22	2:19:00 PM	3.24	2.29	3.27	7.65	0.04	185.52	3.25	2.50	6.45
04/27/22	2:20:00 PM	3.27	2.26	3.26	7.64	0.04	185.79	3.32	2.50	6.48
04/27/22	2:21:00 PM	3.24	2.27	3.22	7.66	0.04	184.76	3.29	2.50	6.43
04/27/22	2:22:00 PM	3.28	2.28	3.23	7.68	0.04	186.27	3.30	2.50	6.46
04/27/22	2:23:00 PM	3.23	2.26	3.20	7.69	0.04	180.61	3.30	2.50	6.38
04/27/22	2:24:00 PM	3.25	2.24	3.25	7.65	0.04	184.56	3.16	2.50	6.45
04/27/22	2:25:00 PM	3.25	2.30	3.26	7.66	0.04	185.29	3.25	2.50	6.47
04/27/22	2:26:00 PM	3.28	2.27	3.24	7.65	0.04	185.60	3.30	2.50	6.48
04/27/22	2:27:00 PM	3.25	2.28	3.26	7.67	0.04	185.55	3.09	2.50	6.47
04/27/22	2:28:00 PM	3.25	2.27	3.25	7.67	0.04	186.00	3.39	2.50	6.46
04/27/22	2:29:00 PM	3.09	2.30	2.87	7.71	0.04	154.93	3.30	2.50	5.83
04/27/22	2:30:00 PM	3.25	2.24	3.20	7.68	0.04	183.97	3.37	2.50	6.41
04/27/22	2:31:00 PM	3.21	2.27	3.27	7.69	0.04	182.65	3.16	2.50	6.43
04/27/22	2:32:00 PM	3.25	2.27	3.25	7.66	0.04	185.12	3.09	2.50	6.46
04/27/22	2:33:00 PM	3.25	2.29	3.24	7.69	0.04	184.49	3.35	2.50	6.44
04/27/22	2:34:00 PM	3.25	2.26	3.25	7.69	0.04	185.17	3.19	2.50	6.45
04/27/22	2:35:00 PM	3.24	2.26	3.30	7.65	0.04	186.60	3.11	2.50	6.48
04/27/22	2:36:00 PM	3.25	2.25	3.25	7.67	0.04	185.59	3.30	2.50	6.44
04/27/22	2:37:00 PM	3.24	2.22	3.29	7.62	0.04	186.91	3.14	2.50	6.49
04/27/22	2:38:00 PM	3.24	2.24	3.26	7.67	0.04	186.15	3.00	2.50	6.43
04/27/22	2:39:00 PM	2.91	2.26	4.70	7.51	0.04	224.50	3.00	2.50	7.48
04/27/22	2:40:00 PM	0.00	1.86	5.39	7.25	0.04	145.85	3.25	2.49	5.36
04/27/22	2:41:00 PM	0.00	1.89	4.55	7.41	0.04	110.76	3.61	2.50	4.62
04/27/22	2:42:00 PM	2.34	2.39	2.22	7.82	0.04	137.28	3.46	2.50	4.84

Woodville DWS April 28, 2022 Test # 15 - Well 1 & 2- Train #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/28/22	7:32:00 AM	0.00	2.88	0.00	8.62	0.04	0.12	3.55	2.37	0.00
04/28/22	7:33:00 AM	0.00	2.88	0.00	8.62	0.04	0.12	3.51	2.37	0.00
04/28/22	7:34:00 AM	0.00	3.12	2.97	8.50	0.18	65.82	3.86	2.37	2.96
04/28/22	7:35:00 AM	3.12	2.96	2.98	8.42	0.23	151.60	4.97	2.36	6.03
04/28/22	7:36:00 AM	3.11	2.94	2.91	8.33	0.06	157.48	2.21	2.37	6.07
04/28/22	7:37:00 AM	3.36	2.84	3.30	8.23	0.04	173.02	2.70	2.40	6.59
04/28/22	7:38:00 AM	3.40	2.78	3.41	8.19	0.04	175.05	2.57	2.40	6.77
04/28/22	7:39:00 AM	3.39	2.76	3.42	8.14	0.04	174.26	2.65	2.40	6.75
04/28/22	7:40:00 AM	3.39	2.75	3.42	8.09	0.04	176.04	2.92	2.40	6.75
04/28/22	7:41:00 AM	3.39	2.68	3.38	8.06	0.04	175.03	3.11	2.40	6.73
04/28/22	7:42:00 AM	3.42	2.67	3.40	8.04	0.04	176.68	2.95	2.40	6.77
04/28/22	7:43:00 AM	3.38	2.62	3.40	8.02	0.04	175.35	3.12	2.40	6.71
04/28/22	7:44:00 AM	3.43	2.64	3.40	8.01	0.04	176.57	2.80	2.40	6.80
04/28/22	7:45:00 AM	3.41	2.61	3.39	7.99	0.04	173.96	3.15	2.40	6.76
04/28/22	7:46:00 AM	3.40	2.60	3.39	7.96	0.04	171.01	3.15	2.40	6.73
04/28/22	7:47:00 AM	3.39	2.58	3.43	7.95	0.04	172.90	3.00	2.40	6.77
04/28/22	7:48:00 AM	3.39	2.55	3.44	7.92	0.04	172.88	3.05	2.40	6.80
04/28/22	7:49:00 AM	3.39	2.53	3.34	7.91	0.04	160.23	3.19	2.40	6.64
04/28/22	7:50:00 AM	3.42	2.55	3.49	7.88	0.04	174.46	3.22	2.40	6.86
04/28/22	7:51:00 AM	3.42	2.49	3.41	7.91	0.04	172.21	3.44	2.40	6.76
04/28/22	7:52:00 AM	3.40	2.51	3.39	7.91	0.04	172.99	3.15	2.40	6.74
04/28/22	7:53:00 AM	3.40	2.50	3.40	7.89	0.04	173.84	3.31	2.40	6.74
04/28/22	7:54:00 AM	3.40	2.48	3.38	7.87	0.04	174.81	3.35	2.40	6.72
04/28/22	7:55:00 AM	3.39	2.49	3.37	7.88	0.04	174.48	3.30	2.40	6.71
04/28/22	7:56:00 AM	3.38	2.48	3.41	7.86	0.04	176.40	3.11	2.40	6.73
04/28/22	7:57:00 AM	3.41	2.50	3.39	7.84	0.04	178.56	3.57	2.40	6.76
04/28/22	7:58:00 AM	3.37	2.49	3.39	7.83	0.04	177.69	3.07	2.40	6.70
04/28/22	7:59:00 AM	3.40	2.44	3.38	7.85	0.04	179.77	2.97	2.40	6.73
04/28/22	8:00:00 AM	3.40	2.43	3.38	7.86	0.04	182.48	3.14	2.40	6.74
04/28/22	8:01:00 AM	3.42	2.45	3.40	7.83	0.04	184.64	3.09	2.39	6.77
04/28/22	8:02:00 AM	3.38	2.41	3.40	7.83	0.04	184.95	3.07	2.40	6.74
04/28/22	8:03:00 AM	3.43	2.41	3.39	7.83	0.04	187.10	3.32	2.40	6.76
04/28/22	8:04:00 AM	3.41	2.42	3.40	7.81	0.04	187.73	3.35	2.40	6.76
04/28/22	8:05:00 AM	3.39	2.43	3.43	7.78	0.04	189.24	2.87	2.40	6.77
04/28/22	8:06:00 AM	3.46	2.40	3.53	7.78	0.04	199.77	3.14	2.40	6.96
04/28/22	8:07:00 AM	3.37	2.41	3.39	7.77	0.04	189.41	3.07	2.40	6.72
04/28/22	8:08:00 AM	3.41	2.40	3.42	7.80	0.04	193.19	3.09	2.40	6.80
04/28/22	8:09:00 AM	3.40	2.39	3.37	7.81	0.04	191.35	3.02	2.40	6.72
04/28/22	8:10:00 AM	3.39	2.40	3.42	7.80	0.04	192.83	3.32	2.39	6.76
04/28/22	8:11:00 AM	3.39	2.37	3.42	7.80	0.04	193.81	3.19	2.40	6.76
04/28/22	8:12:00 AM	3.39	2.39	3.38	7.80	0.04	193.10	3.05	2.40	6.72
04/28/22	8:13:00 AM	3.39	2.38	3.40	7.76	0.04	194.68	3.27	2.40	6.72
04/28/22	8:14:00 AM	3.40	2.36	3.42	7.79	0.04	198.46	3.41	2.39	6.78
04/28/22	8:15:00 AM	3.40	2.39	3.38	7.74	0.04	196.40	3.39	2.40	6.72
04/28/22	8:16:00 AM	3.41	2.37	3.40	7.76	0.04	197.52	3.11	2.40	6.77
04/28/22	8:17:00 AM	3.39	2.36	3.41	7.78	0.04	198.41	3.02	2.39	6.76
04/28/22	8:18:00 AM	3.40	2.36	3.37	7.75	0.04	199.06	3.10	2.40	6.74
04/28/22	8:19:00 AM	3.39	2.34	3.41	7.76	0.04	200.25	3.21	2.40	6.73
04/28/22	8:20:00 AM	3.38	2.34	3.21	7.79	0.04	193.07	3.11	2.40	6.52
04/28/22	8:21:00 AM	3.39	2.36	3.41	7.74	0.04	200.62	3.36	2.40	6.75
04/28/22	8:22:00 AM	3.39	2.37	3.41	7.77	0.04	201.29	3.56	2.40	6.75
04/28/22	8:23:00 AM	3.43	2.34	3.38	7.75	0.04	202.43	3.27	2.40	6.77
04/28/22	8:24:00 AM	3.39	2.35	3.40	7.73	0.04	202.10	3.05	2.40	6.74
04/28/22	8:25:00 AM	3.42	2.33	3.37	7.76	0.04	203.16	3.07	2.39	6.74
04/28/22	8:26:00 AM	3.38	2.31	3.40	7.73	0.04	202.67	3.15	2.40	6.74
04/28/22	8:27:00 AM	3.40	2.35	3.41	7.74	0.04	202.91	3.19	2.40	6.74
04/28/22	8:28:00 AM	3.41	2.37	3.39	7.74	0.04	203.82	3.14	2.40	6.75
04/28/22	8:29:00 AM	3.38	2.36	3.41	7.75	0.04	203.15	3.26	2.40	6.72
04/28/22	8:30:00 AM	3.42	2.33	3.37	7.71	0.04	205.12	3.31	2.40	6.75
04/28/22	8:31:00 AM	3.38	2.34	3.40	7.74	0.04	205.53	2.85	2.40	6.74
04/28/22	8:32:00 AM	3.39	2.36	3.39	7.73	0.04	204.81	3.07	2.40	6.73
04/28/22	8:33:00 AM	3.42	2.33	3.39	7.73	0.04	206.05	3.14	2.40	6.76
04/28/22	8:34:00 AM	3.40	2.33	3.43	7.73	0.04	212.19	3.44	2.38	6.81
04/28/22	8:35:00 AM	3.40	2.29	3.42	7.74	0.04	205.96	3.36	2.37	6.77
04/28/22	8:36:00 AM	3.37	2.32	3.40	7.71	0.04	205.41	3.07	2.37	6.71
04/28/22	8:37:00 AM	3.41	2.35	3.36	7.74	0.04	206.34	3.07	2.37	6.71
04/28/22	8:38:00 AM	3.10	1.83	2.84	7.63	0.04	125.30	3.16	2.37	5.73
04/28/22	8:39:00 AM	0.00	2.15	0.00	7.92	0.04	0.15	3.15	2.36	0.00
04/28/22	8:40:00 AM	3.51	2.68	0.00	8.30	0.04	0.12	3.30	2.35	4.62
04/28/22	8:41:00 AM	4.98	2.42	0.00	8.09	0.04	0.12	5.00	2.35	4.87
04/28/22	8:42:00 AM	4.99	2.39	0.00	8.10	0.04	0.12	3.11	2.35	4.97

Woodville DWS April 28, 2022 Test # 16 - Well 1 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/28/22	9:04:00 AM	0.00	2.62	2.00	0.00	5.00	2.34	0.00
04/28/22	9:05:00 AM	0.00	2.63	2.00	0.00	5.00	2.35	0.00
04/28/22	9:06:00 AM	0.00	2.63	2.00	0.00	5.00	2.35	0.00
04/28/22	9:07:00 AM	0.00	2.64	1.96	0.00	5.00	2.34	0.00
04/28/22	9:08:00 AM	5.57	2.77	1.11	6.13	5.00	2.35	5.46
04/28/22	9:09:00 AM	4.97	2.72	0.08	5.46	5.00	2.34	4.96
04/28/22	9:10:00 AM	4.98	2.67	0.04	5.46	4.06	2.34	5.01
04/28/22	9:11:00 AM	4.98	2.64	0.04	4.96	3.04	2.35	4.88
04/28/22	9:12:00 AM	5.00	2.63	0.04	5.20	3.54	2.35	5.00
04/28/22	9:13:00 AM	5.02	2.62	0.04	5.36	3.44	2.35	5.02
04/28/22	9:14:00 AM	5.00	2.59	0.04	5.36	3.60	2.35	5.03
04/28/22	9:15:00 AM	5.01	2.58	0.04	5.17	3.11	2.35	5.00
04/28/22	9:16:00 AM	4.97	2.57	0.04	5.22	3.10	2.35	4.98
04/28/22	9:17:00 AM	5.01	2.56	0.04	5.29	3.44	2.36	5.00
04/28/22	9:18:00 AM	5.02	2.55	0.04	4.60	3.32	2.36	4.96
04/28/22	9:19:00 AM	4.98	2.53	0.04	5.18	3.35	2.37	4.94
04/28/22	9:20:00 AM	5.00	2.53	0.04	5.10	3.45	2.37	4.99
04/28/22	9:21:00 AM	5.00	2.52	0.04	5.17	3.67	2.37	4.99
04/28/22	9:22:00 AM	5.00	2.53	0.04	5.01	3.55	2.40	5.00
04/28/22	9:23:00 AM	4.99	2.52	0.04	5.08	3.35	2.40	4.99
04/28/22	9:24:00 AM	5.00	2.51	0.03	5.25	3.54	2.40	5.00
04/28/22	9:25:00 AM	5.00	2.50	0.03	5.08	3.16	2.40	5.01
04/28/22	9:26:00 AM	5.00	2.51	0.03	5.12	3.54	2.40	5.01
04/28/22	9:27:00 AM	4.99	2.49	0.03	5.18	3.39	2.40	5.00
04/28/22	9:28:00 AM	5.00	2.50	0.03	5.18	3.33	2.40	4.99
04/28/22	9:29:00 AM	5.00	2.49	0.03	5.10	2.65	2.40	5.00
04/28/22	9:30:00 AM	5.00	2.49	0.04	5.10	2.90	2.40	5.01
04/28/22	9:31:00 AM	5.00	2.48	0.03	5.24	3.19	2.40	5.00
04/28/22	9:32:00 AM	4.97	2.48	0.03	6.56	3.35	2.40	5.14
04/28/22	9:33:00 AM	5.00	2.48	0.04	5.37	3.27	2.40	5.00
04/28/22	9:34:00 AM	5.01	2.48	0.03	5.03	3.41	2.40	5.03
04/28/22	9:35:00 AM	5.01	2.47	0.03	5.46	3.36	2.40	5.03
04/28/22	9:36:00 AM	4.98	2.48	0.03	5.20	3.19	2.40	4.99
04/28/22	9:37:00 AM	5.01	2.46	0.03	5.34	3.72	2.40	5.01
04/28/22	9:38:00 AM	5.01	2.47	0.03	5.20	3.25	2.40	5.00
04/28/22	9:39:00 AM	5.01	2.46	0.03	5.24	2.75	2.40	5.01
04/28/22	9:40:00 AM	4.99	2.47	0.03	5.17	3.07	2.41	4.98
04/28/22	9:41:00 AM	5.01	2.45	0.03	5.30	2.72	2.41	5.00
04/28/22	9:42:00 AM	4.97	2.47	0.03	4.60	2.84	2.41	4.82
04/28/22	9:43:00 AM	5.00	2.47	0.04	5.15	3.35	2.41	5.01
04/28/22	9:44:00 AM	5.00	2.46	0.03	5.13	3.60	2.41	5.00
04/28/22	9:45:00 AM	5.00	2.46	0.03	5.17	3.54	2.41	5.02
04/28/22	9:46:00 AM	5.00	2.46	0.03	5.24	3.44	2.41	5.01
04/28/22	9:47:00 AM	5.01	2.46	0.03	5.18	3.36	2.42	5.00
04/28/22	9:48:00 AM	4.99	2.44	0.03	5.18	2.92	2.42	5.00
04/28/22	9:49:00 AM	5.01	2.45	0.03	5.13	2.89	2.42	5.01
04/28/22	9:50:00 AM	5.01	2.45	0.03	5.12	3.37	2.42	5.01
04/28/22	9:51:00 AM	5.01	2.44	0.03	5.13	3.65	2.42	5.00
04/28/22	9:52:00 AM	4.96	2.45	0.03	6.87	3.60	2.42	5.12
04/28/22	9:53:00 AM	5.01	2.44	0.03	5.51	3.39	2.42	5.01
04/28/22	9:54:00 AM	4.98	2.44	0.03	5.10	3.35	2.42	4.98
04/28/22	9:55:00 AM	4.99	2.44	0.03	5.18	3.30	2.42	4.99
04/28/22	9:56:00 AM	5.02	2.43	0.03	5.36	3.61	2.44	5.03
04/28/22	9:57:00 AM	4.98	2.43	0.03	5.22	3.32	2.44	4.98
04/28/22	9:58:00 AM	5.02	2.43	0.03	5.27	3.31	2.44	5.03
04/28/22	9:59:00 AM	4.99	2.45	0.03	5.18	3.42	2.44	4.99
04/28/22	10:00:00 AM	5.02	2.43	0.03	5.30	3.25	2.44	5.02
04/28/22	10:01:00 AM	5.04	2.43	0.03	4.89	3.00	2.44	4.98
04/28/22	10:02:00 AM	5.00	2.43	0.03	5.15	3.56	2.44	5.01
04/28/22	10:03:00 AM	5.00	2.43	0.03	5.29	3.51	2.44	5.00
04/28/22	10:04:00 AM	5.02	2.43	0.03	5.18	3.46	2.44	5.01
04/28/22	10:05:00 AM	4.99	2.43	0.03	5.27	2.90	2.42	4.99
04/28/22	10:06:00 AM	5.00	2.43	0.03	5.24	3.20	2.41	5.00
04/28/22	10:07:00 AM	5.00	2.45	0.03	5.18	3.24	2.41	4.99
04/28/22	10:08:00 AM	5.00	2.43	0.03	5.20	3.11	2.41	5.00
04/28/22	10:09:00 AM	5.00	2.42	0.03	5.30	3.60	2.41	5.00
04/28/22	10:10:00 AM	5.49	2.40	0.03	7.28	3.54	2.42	5.51
04/28/22	10:11:00 AM	5.51	2.39	0.03	7.19	3.35	2.42	5.52
04/28/22	10:12:00 AM	5.47	2.39	0.04	7.12	3.14	2.42	5.47
04/28/22	10:13:00 AM	5.51	2.39	0.04	7.16	3.07	2.42	5.53
04/28/22	10:14:00 AM	5.48	2.39	0.04	7.02	3.26	2.44	5.48

Woodville DWS April 28, 2022 Test # 17 - Well 1 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/28/22	10:04:00 AM	5.02	2.43	0.03	5.18	3.46	2.44	5.01
04/28/22	10:05:00 AM	4.99	2.43	0.03	5.27	2.90	2.42	4.99
04/28/22	10:06:00 AM	5.00	2.43	0.03	5.24	3.20	2.41	5.00
04/28/22	10:07:00 AM	5.00	2.45	0.03	5.18	3.24	2.41	4.99
04/28/22	10:08:00 AM	5.00	2.43	0.03	5.20	3.11	2.41	5.00
04/28/22	10:09:00 AM	5.00	2.42	0.03	5.30	3.60	2.41	5.00
04/28/22	10:10:00 AM	5.49	2.40	0.03	7.28	3.54	2.42	5.51
04/28/22	10:11:00 AM	5.51	2.39	0.03	7.19	3.35	2.42	5.52
04/28/22	10:12:00 AM	5.47	2.39	0.04	7.12	3.14	2.42	5.47
04/28/22	10:13:00 AM	5.51	2.39	0.04	7.16	3.07	2.42	5.53
04/28/22	10:14:00 AM	5.48	2.39	0.04	7.02	3.26	2.44	5.48
04/28/22	10:15:00 AM	5.54	2.37	0.04	6.85	3.14	2.44	5.57
04/28/22	10:16:00 AM	5.48	2.39	0.04	7.36	3.31	2.44	5.49
04/28/22	10:17:00 AM	5.50	2.36	0.04	7.21	3.37	2.44	5.51
04/28/22	10:18:00 AM	5.50	2.38	0.03	7.30	3.50	2.44	5.50
04/28/22	10:19:00 AM	5.51	2.37	0.04	7.16	3.42	2.45	5.51
04/28/22	10:20:00 AM	5.49	2.37	0.04	7.24	3.39	2.45	5.48
04/28/22	10:21:00 AM	5.50	2.36	0.04	7.23	3.44	2.45	5.49
04/28/22	10:22:00 AM	5.50	2.37	0.03	7.23	3.04	2.45	5.50
04/28/22	10:23:00 AM	5.50	2.37	0.04	7.14	3.09	2.44	5.50
04/28/22	10:24:00 AM	5.50	2.35	0.03	7.18	3.13	2.45	5.50
04/28/22	10:25:00 AM	5.50	2.37	0.04	7.12	3.35	2.45	5.50
04/28/22	10:26:00 AM	5.50	2.35	0.04	7.14	3.16	2.45	5.49
04/28/22	10:27:00 AM	5.52	2.36	0.04	7.19	3.37	2.45	5.51
04/28/22	10:28:00 AM	5.49	2.36	0.04	7.36	3.35	2.45	5.48
04/28/22	10:29:00 AM	5.49	2.35	0.03	7.19	3.54	2.45	5.49
04/28/22	10:30:00 AM	5.50	2.35	0.04	7.30	3.80	2.45	5.51
04/28/22	10:31:00 AM	5.49	2.35	0.03	7.28	3.32	2.44	5.50
04/28/22	10:32:00 AM	5.49	2.35	0.04	7.16	3.15	2.42	5.50
04/28/22	10:33:00 AM	5.50	2.35	0.04	7.21	3.07	2.42	5.50
04/28/22	10:34:00 AM	5.49	2.34	0.03	7.18	3.35	2.42	5.48
04/28/22	10:35:00 AM	5.51	2.32	0.03	7.23	3.56	2.42	5.49
04/28/22	10:36:00 AM	5.54	2.33	0.04	6.90	3.60	2.42	5.55
04/28/22	10:37:00 AM	5.50	2.35	0.04	7.19	3.30	2.42	5.52
04/28/22	10:38:00 AM	5.50	2.34	0.03	7.21	3.35	2.42	5.50
04/28/22	10:39:00 AM	5.49	2.35	0.03	7.23	3.60	2.42	5.50
04/28/22	10:40:00 AM	5.50	2.33	0.03	7.18	3.37	2.42	5.50
04/28/22	10:41:00 AM	5.50	2.35	0.03	7.16	3.24	2.42	5.50
04/28/22	10:42:00 AM	5.50	2.34	0.03	7.16	3.42	2.44	5.50
04/28/22	10:43:00 AM	5.50	2.33	0.03	7.18	3.19	2.44	5.50
04/28/22	10:44:00 AM	5.51	2.34	0.03	7.31	3.00	2.44	5.50
04/28/22	10:45:00 AM	5.51	2.35	0.03	7.26	3.42	2.44	5.51
04/28/22	10:46:00 AM	5.50	2.34	0.03	7.18	3.35	2.44	5.49
04/28/22	10:47:00 AM	5.48	2.34	0.03	7.11	3.31	2.44	5.47
04/28/22	10:48:00 AM	5.50	2.32	0.03	7.16	3.04	2.44	5.50
04/28/22	10:49:00 AM	5.50	2.31	0.03	7.26	2.74	2.44	5.50
04/28/22	10:50:00 AM	5.50	2.33	0.03	6.75	3.41	2.45	5.49
04/28/22	10:51:00 AM	5.50	2.33	0.03	7.21	3.62	2.45	5.47
04/28/22	10:52:00 AM	5.48	2.33	0.03	7.26	3.29	2.45	5.49
04/28/22	10:53:00 AM	5.50	2.31	0.03	7.26	3.62	2.45	5.50
04/28/22	10:54:00 AM	5.50	2.33	0.03	7.19	3.46	2.44	5.50
04/28/22	10:55:00 AM	5.50	2.32	0.03	7.33	3.49	2.45	5.48
04/28/22	10:56:00 AM	5.49	2.33	0.03	7.28	3.55	2.45	5.49
04/28/22	10:57:00 AM	5.49	2.32	0.03	7.26	3.31	2.45	5.50
04/28/22	10:58:00 AM	5.50	2.33	0.03	7.42	3.46	2.46	5.51
04/28/22	10:59:00 AM	5.49	2.34	0.03	7.31	3.30	2.46	5.49
04/28/22	11:00:00 AM	5.50	2.32	0.03	7.30	3.42	2.46	5.49
04/28/22	11:01:00 AM	5.49	2.31	0.03	7.21	3.11	2.46	5.48
04/28/22	11:02:00 AM	5.49	2.33	0.03	7.30	3.05	2.46	5.49
04/28/22	11:03:00 AM	5.49	2.33	0.03	7.28	3.30	2.46	5.48
04/28/22	11:04:00 AM	5.50	2.32	0.03	7.35	3.41	2.46	5.50
04/28/22	11:05:00 AM	5.49	2.31	0.03	7.31	3.41	2.46	5.50
04/28/22	11:06:00 AM	5.38	2.33	0.03	7.52	3.39	2.46	5.24
04/28/22	11:07:00 AM	5.51	2.33	0.03	7.83	3.55	2.46	5.54
04/28/22	11:08:00 AM	5.49	2.32	0.03	7.24	3.51	2.47	5.49
04/28/22	11:09:00 AM	5.48	2.33	0.03	7.21	3.38	2.47	5.47
04/28/22	11:10:00 AM	5.90	2.36	0.03	9.13	3.57	2.47	5.94
04/28/22	11:11:00 AM	6.01	2.38	0.04	9.34	3.30	2.47	6.00
04/28/22	11:12:00 AM	6.00	2.36	0.04	9.46	3.35	2.47	6.00
04/28/22	11:13:00 AM	5.98	2.36	0.04	9.29	3.56	2.47	5.98
04/28/22	11:14:00 AM	6.02	2.37	0.04	9.30	3.14	2.47	6.02

Woodville DWS April 28, 2022 Test # 18 - Well 1 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/28/22	11:04:00 AM	5.50	2.32	0.03	7.35	3.41	2.46	5.50
04/28/22	11:05:00 AM	5.49	2.31	0.03	7.31	3.41	2.46	5.50
04/28/22	11:06:00 AM	5.38	2.33	0.03	7.52	3.39	2.46	5.24
04/28/22	11:07:00 AM	5.51	2.33	0.03	7.83	3.55	2.46	5.54
04/28/22	11:08:00 AM	5.49	2.32	0.03	7.24	3.51	2.47	5.49
04/28/22	11:09:00 AM	5.48	2.33	0.03	7.21	3.38	2.47	5.47
04/28/22	11:10:00 AM	5.90	2.36	0.03	9.13	3.57	2.47	5.94
04/28/22	11:11:00 AM	6.01	2.38	0.04	9.34	3.30	2.47	6.00
04/28/22	11:12:00 AM	6.00	2.36	0.04	9.46	3.35	2.47	6.00
04/28/22	11:13:00 AM	5.98	2.36	0.04	9.29	3.56	2.47	5.98
04/28/22	11:14:00 AM	6.02	2.37	0.04	9.30	3.14	2.47	6.02
04/28/22	11:15:00 AM	5.98	2.37	0.04	9.30	2.89	2.47	5.98
04/28/22	11:16:00 AM	6.01	2.37	0.04	9.42	2.56	2.47	6.01
04/28/22	11:17:00 AM	6.04	2.35	0.04	9.15	3.05	2.47	6.09
04/28/22	11:18:00 AM	6.06	2.36	0.04	9.53	3.00	2.47	6.09
04/28/22	11:19:00 AM	6.00	2.37	0.04	9.44	3.51	2.47	6.02
04/28/22	11:20:00 AM	6.01	2.35	0.04	9.37	3.50	2.47	6.01
04/28/22	11:21:00 AM	6.01	2.36	0.04	9.39	3.44	2.47	6.00
04/28/22	11:22:00 AM	5.98	2.34	0.04	9.30	3.65	2.47	5.97
04/28/22	11:23:00 AM	5.94	2.37	0.04	9.41	3.54	2.47	5.82
04/28/22	11:24:00 AM	5.99	2.35	0.04	9.34	3.21	2.47	5.97
04/28/22	11:25:00 AM	6.00	2.36	0.04	9.41	3.10	2.47	6.00
04/28/22	11:26:00 AM	6.00	2.34	0.04	9.42	3.07	2.47	6.01
04/28/22	11:27:00 AM	6.01	2.35	0.04	9.39	3.24	2.47	6.00
04/28/22	11:28:00 AM	5.99	2.34	0.04	9.44	3.26	2.47	6.00
04/28/22	11:29:00 AM	6.00	2.34	0.04	9.54	3.30	2.47	6.01
04/28/22	11:30:00 AM	6.00	2.34	0.04	9.37	2.97	2.47	5.98
04/28/22	11:31:00 AM	6.00	2.35	0.04	9.44	3.10	2.47	5.99
04/28/22	11:32:00 AM	5.99	2.33	0.03	9.48	3.32	2.47	5.99
04/28/22	11:33:00 AM	6.00	2.34	0.04	9.48	3.39	2.47	6.00
04/28/22	11:34:00 AM	6.00	2.32	0.04	9.39	3.21	2.47	6.00
04/28/22	11:35:00 AM	6.00	2.35	0.03	9.56	3.14	2.47	6.00
04/28/22	11:36:00 AM	6.00	2.35	0.04	9.49	3.49	2.47	6.00
04/28/22	11:37:00 AM	6.00	2.32	0.03	9.44	3.35	2.47	5.99
04/28/22	11:38:00 AM	6.00	2.34	0.03	9.44	3.25	2.47	5.98
04/28/22	11:39:00 AM	6.02	2.34	0.03	9.56	3.39	2.47	6.00
04/28/22	11:40:00 AM	6.00	2.33	0.03	9.49	3.46	2.49	5.98
04/28/22	11:41:00 AM	5.99	2.33	0.03	9.54	3.26	2.49	5.98
04/28/22	11:42:00 AM	5.99	2.34	0.03	9.48	3.16	2.49	5.99
04/28/22	11:43:00 AM	5.99	2.33	0.03	9.72	3.16	2.49	5.98
04/28/22	11:44:00 AM	5.98	2.34	0.03	9.56	3.40	2.49	5.97
04/28/22	11:45:00 AM	5.98	2.33	0.04	9.61	3.15	2.49	5.98
04/28/22	11:46:00 AM	6.03	2.33	0.03	9.54	3.35	2.49	6.03
04/28/22	11:47:00 AM	5.98	2.33	0.03	9.66	3.57	2.49	5.98
04/28/22	11:48:00 AM	5.99	2.33	0.04	9.46	3.29	2.49	5.99
04/28/22	11:49:00 AM	6.01	2.32	0.03	9.70	3.46	2.49	6.00
04/28/22	11:50:00 AM	5.99	2.33	0.03	9.58	3.24	2.49	5.99
04/28/22	11:51:00 AM	6.01	2.35	0.03	9.84	3.50	2.50	6.02
04/28/22	11:52:00 AM	5.99	2.32	0.03	9.65	3.30	2.50	5.98
04/28/22	11:53:00 AM	5.99	2.30	0.03	9.68	3.30	2.49	5.98
04/28/22	11:54:00 AM	6.01	2.31	0.03	9.66	3.35	2.50	5.98
04/28/22	11:55:00 AM	5.99	2.32	0.03	9.73	3.32	2.50	5.98
04/28/22	11:56:00 AM	6.02	2.36	0.03	10.01	3.14	2.50	6.04
04/28/22	11:57:00 AM	5.99	2.31	0.03	9.70	3.37	2.50	6.00
04/28/22	11:58:00 AM	5.99	2.31	0.03	9.84	3.45	2.50	6.00
04/28/22	11:59:00 AM	5.99	2.30	0.03	9.78	3.10	2.50	5.99
04/28/22	12:00:00 PM	5.99	2.32	0.03	9.65	3.16	2.50	5.97
04/28/22	12:01:00 PM	6.02	2.32	0.03	9.82	3.42	2.50	6.02
04/28/22	12:02:00 PM	5.98	2.32	0.03	9.80	3.40	2.50	5.97
04/28/22	12:03:00 PM	6.02	2.32	0.03	9.78	3.14	2.50	6.01
04/28/22	12:04:00 PM	5.98	2.33	0.03	9.85	3.25	2.50	5.99
04/28/22	12:05:00 PM	6.01	2.31	0.03	9.73	3.02	2.50	5.99
04/28/22	12:06:00 PM	5.99	2.30	0.03	9.75	3.15	2.50	5.98
04/28/22	12:07:00 PM	6.01	2.30	0.03	9.78	3.30	2.50	5.99
04/28/22	12:08:00 PM	6.01	2.33	0.03	9.94	3.24	2.50	6.01
04/28/22	12:09:00 PM	5.99	2.30	0.03	9.72	3.25	2.50	5.98
04/28/22	12:10:00 PM	6.29	2.45	0.03	11.83	3.14	2.50	6.37
04/28/22	12:11:00 PM	6.50	2.42	0.03	12.17	3.02	2.50	6.50
04/28/22	12:12:00 PM	6.50	2.40	0.04	12.14	3.26	2.49	6.50
04/28/22	12:13:00 PM	6.52	2.40	0.04	12.22	3.30	2.50	6.53
04/28/22	12:14:00 PM	6.51	2.41	0.04	12.26	3.47	2.50	6.51

Woodville DWS April 28, 2022 Test # 19 - Well 1 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/28/22	12:04:00 PM	5.98	2.33	0.03	9.85	3.25	2.50	5.99
04/28/22	12:05:00 PM	6.01	2.31	0.03	9.73	3.02	2.50	5.99
04/28/22	12:06:00 PM	5.99	2.30	0.03	9.75	3.15	2.50	5.98
04/28/22	12:07:00 PM	6.01	2.30	0.03	9.78	3.30	2.50	5.99
04/28/22	12:08:00 PM	6.01	2.33	0.03	9.94	3.24	2.50	6.01
04/28/22	12:09:00 PM	5.99	2.30	0.03	9.72	3.25	2.50	5.98
04/28/22	12:10:00 PM	6.29	2.45	0.03	11.83	3.14	2.50	6.37
04/28/22	12:11:00 PM	6.50	2.42	0.03	12.17	3.02	2.50	6.50
04/28/22	12:12:00 PM	6.50	2.40	0.04	12.14	3.26	2.49	6.50
04/28/22	12:13:00 PM	6.52	2.40	0.04	12.22	3.30	2.50	6.53
04/28/22	12:14:00 PM	6.51	2.41	0.04	12.26	3.47	2.50	6.51
04/28/22	12:15:00 PM	6.50	2.40	0.04	12.09	3.32	2.49	6.50
04/28/22	12:16:00 PM	6.47	2.40	0.04	12.09	3.42	2.49	6.46
04/28/22	12:17:00 PM	6.49	2.40	0.04	12.15	3.50	2.49	6.48
04/28/22	12:18:00 PM	6.53	2.41	0.04	12.33	3.46	2.49	6.52
04/28/22	12:19:00 PM	6.50	2.40	0.04	12.26	3.35	2.50	6.50
04/28/22	12:20:00 PM	6.50	2.40	0.04	12.21	3.54	2.49	6.50
04/28/22	12:21:00 PM	6.50	2.39	0.04	12.24	3.45	2.49	6.49
04/28/22	12:22:00 PM	6.49	2.41	0.04	12.27	3.12	2.49	6.50
04/28/22	12:23:00 PM	6.50	2.40	0.04	12.27	3.24	2.49	6.49
04/28/22	12:24:00 PM	6.50	2.39	0.04	12.33	3.21	2.49	6.51
04/28/22	12:25:00 PM	6.49	2.40	0.04	12.34	3.49	2.49	6.49
04/28/22	12:26:00 PM	6.50	2.38	0.04	12.29	3.56	2.49	6.50
04/28/22	12:27:00 PM	6.49	2.37	0.04	12.34	3.40	2.49	6.50
04/28/22	12:28:00 PM	6.50	2.39	0.03	12.24	3.45	2.49	6.50
04/28/22	12:29:00 PM	6.50	2.40	0.04	12.31	3.19	2.49	6.51
04/28/22	12:30:00 PM	6.52	2.39	0.03	12.38	3.46	2.49	6.52
04/28/22	12:31:00 PM	6.49	2.38	0.03	12.26	3.42	2.49	6.49
04/28/22	12:32:00 PM	6.50	2.37	0.03	12.24	3.04	2.49	6.49
04/28/22	12:33:00 PM	6.52	2.38	0.03	12.50	3.30	2.49	6.52
04/28/22	12:34:00 PM	6.49	2.38	0.03	12.31	3.46	2.49	6.49
04/28/22	12:35:00 PM	6.49	2.37	0.03	12.22	3.24	2.49	6.47
04/28/22	12:36:00 PM	6.49	2.39	0.03	12.43	3.45	2.49	6.49
04/28/22	12:37:00 PM	6.51	2.38	0.03	12.55	3.21	2.49	6.51
04/28/22	12:38:00 PM	6.49	2.40	0.04	12.39	3.11	2.49	6.49
04/28/22	12:39:00 PM	6.49	2.37	0.03	12.36	3.39	2.49	6.49
04/28/22	12:40:00 PM	6.51	2.36	0.03	12.38	3.25	2.49	6.50
04/28/22	12:41:00 PM	6.49	2.39	0.03	12.36	3.14	2.49	6.49
04/28/22	12:42:00 PM	6.52	2.39	0.03	12.60	3.30	2.49	6.52
04/28/22	12:43:00 PM	6.49	2.37	0.03	12.41	3.39	2.49	6.49
04/28/22	12:44:00 PM	6.50	2.36	0.03	12.60	3.09	2.49	6.51
04/28/22	12:45:00 PM	6.49	2.36	0.03	12.41	3.37	2.49	6.49
04/28/22	12:46:00 PM	6.50	2.37	0.03	12.39	3.24	2.49	6.50
04/28/22	12:47:00 PM	6.50	2.38	0.03	12.36	2.86	2.49	6.49
04/28/22	12:48:00 PM	6.50	2.38	0.03	12.39	3.44	2.49	6.50
04/28/22	12:49:00 PM	6.49	2.39	0.03	12.33	3.07	2.49	6.47
04/28/22	12:50:00 PM	6.50	2.37	0.03	12.48	3.09	2.49	6.50
04/28/22	12:51:00 PM	6.49	2.37	0.03	12.38	3.02	2.49	6.50
04/28/22	12:52:00 PM	6.49	2.38	0.03	12.50	3.46	2.49	6.48
04/28/22	12:53:00 PM	6.52	2.37	0.03	12.33	3.42	2.49	6.50
04/28/22	12:54:00 PM	6.49	2.38	0.03	12.46	3.27	2.49	6.49
04/28/22	12:55:00 PM	6.49	2.36	0.03	12.46	3.42	2.49	6.48
04/28/22	12:56:00 PM	6.50	2.38	0.03	12.57	3.09	2.49	6.49
04/28/22	12:57:00 PM	6.50	2.36	0.03	12.48	3.09	2.49	6.49
04/28/22	12:58:00 PM	6.49	2.36	0.03	12.46	3.02	2.49	6.49
04/28/22	12:59:00 PM	6.50	2.35	0.03	12.51	3.23	2.49	6.51
04/28/22	1:00:00 PM	6.49	2.35	0.03	12.51	3.35	2.49	6.48
04/28/22	1:01:00 PM	6.50	2.37	0.03	12.50	3.60	2.49	6.50
04/28/22	1:02:00 PM	6.50	2.38	0.03	12.41	3.45	2.49	6.49
04/28/22	1:03:00 PM	6.49	2.36	0.03	12.48	3.51	2.49	6.50
04/28/22	1:04:00 PM	6.50	2.40	0.03	12.43	3.54	2.49	6.50
04/28/22	1:05:00 PM	6.50	2.37	0.03	12.29	3.09	2.49	6.49
04/28/22	1:06:00 PM	6.50	2.37	0.03	12.34	2.65	2.49	6.50
04/28/22	1:07:00 PM	6.50	2.38	0.03	12.39	3.05	2.49	6.49
04/28/22	1:08:00 PM	6.49	2.35	0.03	12.38	2.97	2.49	6.48
04/28/22	1:09:00 PM	6.51	2.37	0.03	12.50	3.45	2.49	6.50
04/28/22	1:10:00 PM	6.77	2.28	0.03	13.80	3.27	2.49	6.79
04/28/22	1:11:00 PM	6.83	2.29	0.03	14.06	3.42	2.49	6.84
04/28/22	1:12:00 PM	6.79	2.27	0.03	13.60	2.86	2.49	6.79
04/28/22	1:13:00 PM	6.83	2.28	0.04	13.80	2.92	2.49	6.83
04/28/22	1:14:00 PM	6.79	2.29	0.03	13.78	2.55	2.49	6.80

Woodville DWS April 28, 2022 Test # 20 - Well 1 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/28/22	1:04:00 PM	6.50	2.40	0.03	12.43	3.54	2.49	6.50
04/28/22	1:05:00 PM	6.50	2.37	0.03	12.29	3.09	2.49	6.49
04/28/22	1:06:00 PM	6.50	2.37	0.03	12.34	2.65	2.49	6.50
04/28/22	1:07:00 PM	6.50	2.38	0.03	12.39	3.05	2.49	6.49
04/28/22	1:08:00 PM	6.49	2.35	0.03	12.38	2.97	2.49	6.48
04/28/22	1:09:00 PM	6.51	2.37	0.03	12.50	3.45	2.49	6.50
04/28/22	1:10:00 PM	6.77	2.28	0.03	13.80	3.27	2.49	6.79
04/28/22	1:11:00 PM	6.83	2.29	0.03	14.06	3.42	2.49	6.84
04/28/22	1:12:00 PM	6.79	2.27	0.03	13.60	2.86	2.49	6.79
04/28/22	1:13:00 PM	6.83	2.28	0.04	13.80	2.92	2.49	6.83
04/28/22	1:14:00 PM	6.79	2.29	0.03	13.78	2.55	2.49	6.80
04/28/22	1:15:00 PM	6.82	2.28	0.03	14.02	2.83	2.49	6.83
04/28/22	1:16:00 PM	6.79	2.29	0.03	13.80	2.70	2.49	6.80
04/28/22	1:17:00 PM	6.81	2.27	0.03	13.99	2.65	2.49	6.82
04/28/22	1:18:00 PM	6.78	2.28	0.04	13.72	3.04	2.49	6.79
04/28/22	1:19:00 PM	6.81	2.26	0.04	14.13	2.61	2.49	6.81
04/28/22	1:20:00 PM	6.79	2.27	0.04	13.72	2.69	2.49	6.78
04/28/22	1:21:00 PM	6.81	2.27	0.04	13.99	2.91	2.49	6.82
04/28/22	1:22:00 PM	6.81	2.25	0.04	13.94	2.91	2.49	6.82
04/28/22	1:23:00 PM	6.78	2.28	0.04	13.96	3.18	2.49	6.81
04/28/22	1:24:00 PM	6.79	2.26	0.03	13.84	2.97	2.49	6.81
04/28/22	1:25:00 PM	6.80	2.26	0.03	13.80	2.65	2.49	6.81
04/28/22	1:26:00 PM	6.81	2.27	0.03	13.82	2.79	2.49	6.82
04/28/22	1:27:00 PM	6.81	2.28	0.03	13.84	3.00	2.49	6.82
04/28/22	1:28:00 PM	6.80	2.25	0.03	13.84	2.90	2.49	6.80
04/28/22	1:29:00 PM	6.81	2.25	0.04	13.80	2.86	2.49	6.81
04/28/22	1:30:00 PM	6.80	2.25	0.03	13.85	3.15	2.49	6.79
04/28/22	1:31:00 PM	6.81	2.26	0.03	13.77	3.07	2.49	6.80
04/28/22	1:32:00 PM	6.79	2.25	0.03	13.77	3.40	2.47	6.79
04/28/22	1:33:00 PM	6.80	2.26	0.03	13.96	3.39	2.47	6.81
04/28/22	1:34:00 PM	6.81	2.24	0.03	13.92	3.16	2.47	6.81
04/28/22	1:35:00 PM	6.77	2.27	0.04	13.82	2.73	2.47	6.78
04/28/22	1:36:00 PM	6.81	2.26	0.03	13.80	2.89	2.47	6.82
04/28/22	1:37:00 PM	6.81	2.27	0.03	13.84	2.84	2.47	6.81
04/28/22	1:38:00 PM	6.80	2.26	0.04	13.92	2.96	2.49	6.80
04/28/22	1:39:00 PM	6.81	2.25	0.03	13.84	2.80	2.47	6.82
04/28/22	1:40:00 PM	6.79	2.25	0.03	13.70	3.30	2.49	6.79
04/28/22	1:41:00 PM	6.80	2.26	0.03	13.87	2.91	2.49	6.81
04/28/22	1:42:00 PM	6.82	2.25	0.03	13.82	3.11	2.49	6.82
04/28/22	1:43:00 PM	6.79	2.24	0.03	13.77	3.07	2.49	6.79
04/28/22	1:44:00 PM	6.81	2.29	0.03	13.78	3.11	2.49	6.82
04/28/22	1:45:00 PM	6.79	2.28	0.03	13.82	3.11	2.49	6.78
04/28/22	1:46:00 PM	6.82	2.25	0.03	13.99	2.97	2.49	6.83
04/28/22	1:47:00 PM	6.80	2.25	0.03	13.97	3.16	2.49	6.79
04/28/22	1:48:00 PM	6.80	2.25	0.03	13.97	3.30	2.49	6.81
04/28/22	1:49:00 PM	6.79	2.24	0.03	13.77	3.26	2.49	6.79
04/28/22	1:50:00 PM	6.79	2.27	0.03	13.85	3.04	2.49	6.79
04/28/22	1:51:00 PM	6.83	2.24	0.03	13.99	3.19	2.49	6.82
04/28/22	1:52:00 PM	6.80	2.27	0.03	13.84	3.04	2.49	6.80
04/28/22	1:53:00 PM	6.80	2.25	0.03	13.92	3.05	2.49	6.81
04/28/22	1:54:00 PM	6.82	2.26	0.03	14.15	2.95	2.49	6.83
04/28/22	1:55:00 PM	6.80	2.25	0.03	13.92	3.08	2.49	6.80
04/28/22	1:56:00 PM	6.80	2.27	0.03	13.87	3.11	2.49	6.79
04/28/22	1:57:00 PM	6.81	2.23	0.03	13.92	2.84	2.49	6.80
04/28/22	1:58:00 PM	6.79	2.25	0.03	13.97	2.76	2.49	6.80
04/28/22	1:59:00 PM	6.80	2.27	0.03	13.89	3.00	2.49	6.79
04/28/22	2:00:00 PM	6.80	2.22	0.03	14.16	3.39	2.49	6.80
04/28/22	2:01:00 PM	6.80	2.25	0.03	14.21	3.26	2.49	6.81
04/28/22	2:02:00 PM	6.80	2.21	0.03	13.97	3.07	2.49	6.80
04/28/22	2:03:00 PM	6.80	2.22	0.03	14.06	3.07	2.49	6.81
04/28/22	2:04:00 PM	6.80	2.24	0.03	14.13	3.24	2.49	6.80
04/28/22	2:05:00 PM	6.80	2.22	0.03	14.13	3.44	2.49	6.80
04/28/22	2:06:00 PM	6.81	2.22	0.03	14.09	3.34	2.49	6.80
04/28/22	2:07:00 PM	6.80	2.22	0.03	14.13	2.95	2.49	6.80
04/28/22	2:08:00 PM	6.80	2.22	0.03	14.20	3.40	2.49	6.81
04/28/22	2:09:00 PM	6.81	2.23	0.03	14.13	3.15	2.49	6.81
04/28/22	2:10:00 PM	0.00	1.80	0.04	6.13	3.14	2.49	5.42
04/28/22	2:11:00 PM	0.00	1.82	0.09	6.06	3.60	2.49	4.99
04/28/22	2:12:00 PM	0.00	1.84	0.04	5.87	3.02	2.49	4.96
04/28/22	2:13:00 PM	0.00	1.85	0.03	6.06	3.30	2.49	4.99
04/28/22	2:14:00 PM	0.00	1.86	0.03	5.85	3.44	2.49	4.94

Woodville DWS April 28, 2022 Test # 21 - Well 2 - Train #1

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
04/28/22	2:04:00 PM	0.00	8.05	0.03	14.13	3.24	2.49	6.80
04/28/22	2:05:00 PM	0.00	8.07	0.03	14.13	3.44	2.49	6.80
04/28/22	2:06:00 PM	0.00	8.05	0.03	14.09	3.34	2.49	6.80
04/28/22	2:07:00 PM	0.00	8.08	0.03	14.13	2.95	2.49	6.80
04/28/22	2:08:00 PM	0.00	8.07	0.03	14.20	3.40	2.49	6.81
04/28/22	2:09:00 PM	0.00	8.06	0.03	14.13	3.15	2.49	6.81
04/28/22	2:10:00 PM	5.44	7.22	0.04	6.13	3.14	2.49	5.42
04/28/22	2:11:00 PM	5.03	7.27	0.09	6.06	3.60	2.49	4.99
04/28/22	2:12:00 PM	4.98	7.28	0.04	5.87	3.02	2.49	4.96
04/28/22	2:13:00 PM	5.01	7.29	0.03	6.06	3.30	2.49	4.99
04/28/22	2:14:00 PM	4.96	7.30	0.03	5.85	3.44	2.49	4.94
04/28/22	2:15:00 PM	5.23	7.28	0.03	4.89	3.45	2.49	5.16
04/28/22	2:16:00 PM	4.99	7.31	0.03	6.21	3.26	2.49	4.97
04/28/22	2:17:00 PM	4.97	7.31	0.03	5.84	3.04	2.49	4.94
04/28/22	2:18:00 PM	5.02	7.31	0.03	5.89	3.34	2.49	4.99
04/28/22	2:19:00 PM	4.96	7.32	0.03	5.79	3.40	2.49	4.93
04/28/22	2:20:00 PM	4.98	7.32	0.03	5.77	3.35	2.49	4.95
04/28/22	2:21:00 PM	5.01	7.32	0.03	5.94	3.35	2.49	5.00
04/28/22	2:22:00 PM	5.00	7.33	0.03	5.96	3.56	2.49	4.96
04/28/22	2:23:00 PM	4.98	7.33	0.03	5.77	3.24	2.49	4.95
04/28/22	2:24:00 PM	5.01	7.33	0.03	5.89	3.32	2.49	4.98
04/28/22	2:25:00 PM	4.98	7.33	0.03	6.06	3.39	2.49	4.96
04/28/22	2:26:00 PM	5.00	7.33	0.03	5.66	3.07	2.49	4.99
04/28/22	2:27:00 PM	5.02	7.33	0.03	5.92	3.32	2.49	4.98
04/28/22	2:28:00 PM	5.00	7.34	0.03	5.92	3.24	2.49	4.97
04/28/22	2:29:00 PM	5.00	7.34	0.03	5.94	3.46	2.49	4.98
04/28/22	2:30:00 PM	4.99	7.34	0.03	5.96	3.35	2.49	4.95
04/28/22	2:31:00 PM	4.99	7.34	0.03	5.94	3.30	2.47	4.97
04/28/22	2:32:00 PM	4.97	7.35	0.03	5.70	3.54	2.49	4.93
04/28/22	2:33:00 PM	5.00	7.34	0.03	5.92	3.39	2.49	4.98
04/28/22	2:34:00 PM	5.00	7.34	0.03	5.92	3.55	2.49	4.97
04/28/22	2:35:00 PM	5.00	7.35	0.03	5.96	3.50	2.49	4.98
04/28/22	2:36:00 PM	5.01	7.35	0.03	5.92	3.53	2.49	4.99
04/28/22	2:37:00 PM	5.01	7.35	0.03	5.94	3.56	2.49	4.98
04/28/22	2:38:00 PM	5.02	7.35	0.03	5.92	3.26	2.49	4.98
04/28/22	2:39:00 PM	5.00	7.35	0.03	5.89	3.56	2.49	4.98
04/28/22	2:40:00 PM	5.01	7.35	0.03	5.94	3.54	2.49	4.98
04/28/22	2:41:00 PM	5.01	7.35	0.03	6.03	3.40	2.49	4.98
04/28/22	2:42:00 PM	5.00	7.35	0.03	5.99	3.56	2.49	4.97
04/28/22	2:43:00 PM	5.04	7.35	0.03	6.01	3.65	2.49	4.99
04/28/22	2:44:00 PM	5.01	7.35	0.03	5.91	3.25	2.49	4.98
04/28/22	2:45:00 PM	5.01	7.35	0.03	5.85	3.42	2.49	4.98
04/28/22	2:46:00 PM	4.98	7.36	0.03	5.94	3.55	2.49	4.94
04/28/22	2:47:00 PM	5.00	7.36	0.03	5.87	3.61	2.49	4.97
04/28/22	2:48:00 PM	5.01	7.36	0.03	5.91	3.40	2.49	4.98
04/28/22	2:49:00 PM	4.99	7.36	0.03	5.97	3.27	2.49	4.96
04/28/22	2:50:00 PM	5.00	7.36	0.03	5.87	3.27	2.49	4.98
04/28/22	2:51:00 PM	5.02	7.36	0.03	5.96	3.35	2.49	4.98
04/28/22	2:52:00 PM	4.98	7.36	0.03	6.01	3.55	2.49	4.96
04/28/22	2:53:00 PM	5.02	7.36	0.03	5.87	3.16	2.49	4.98
04/28/22	2:54:00 PM	4.95	7.37	0.03	5.77	3.46	2.49	4.94
04/28/22	2:55:00 PM	5.02	7.36	0.03	5.99	3.31	2.49	4.99
04/28/22	2:56:00 PM	5.01	7.36	0.03	5.99	3.22	2.49	4.98
04/28/22	2:57:00 PM	5.00	7.35	0.03	5.92	3.04	2.49	4.96
04/28/22	2:58:00 PM	5.00	7.36	0.03	5.92	3.40	2.49	4.97
04/28/22	2:59:00 PM	5.00	7.36	0.03	5.96	3.72	2.49	4.97
04/28/22	3:00:00 PM	5.00	7.37	0.03	5.92	3.10	2.49	4.98
04/28/22	3:01:00 PM	5.00	7.37	0.03	5.92	3.35	2.49	4.98
04/28/22	3:02:00 PM	5.01	7.36	0.03	5.92	3.56	2.49	4.98
04/28/22	3:03:00 PM	5.01	7.36	0.03	5.85	3.54	2.49	4.98
04/28/22	3:04:00 PM	5.00	7.37	0.03	6.03	3.30	2.49	4.98
04/28/22	3:05:00 PM	4.98	7.37	0.03	5.94	2.92	2.49	4.95
04/28/22	3:06:00 PM	5.00	7.37	0.03	5.89	2.91	2.49	4.97
04/28/22	3:07:00 PM	5.01	7.37	0.03	6.11	2.89	2.49	4.97
04/28/22	3:08:00 PM	4.99	7.37	0.03	5.91	3.39	2.49	4.96
04/28/22	3:09:00 PM	5.00	7.37	0.03	5.92	3.55	2.49	4.97
04/28/22	3:10:00 PM	5.28	7.33	0.03	6.88	3.30	2.49	5.25
04/28/22	3:11:00 PM	5.30	7.33	0.03	6.94	3.15	2.49	5.27
04/28/22	3:12:00 PM	5.31	7.32	0.03	7.33	3.30	2.49	5.27
04/28/22	3:13:00 PM	5.33	7.32	0.03	7.24	3.11	2.49	5.30
04/28/22	3:14:00 PM	5.27	7.32	0.03	7.06	3.40	2.49	5.24

Woodville DWS May 3, 2022 Test # 22 - Well 2 - Train #1

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/03/22	7:36:00 AM	0.00	8.55	0.04	0.00	3.25	2.36	0.00
05/03/22	7:37:00 AM	0.00	8.55	0.04	0.00	3.26	2.36	0.00
05/03/22	7:38:00 AM	0.00	8.55	0.04	0.00	3.30	2.36	0.00
05/03/22	7:39:00 AM	0.00	8.55	0.04	0.00	3.30	2.36	0.00
05/03/22	7:40:00 AM	0.00	8.55	0.04	0.00	3.34	2.36	0.00
05/03/22	7:41:00 AM	0.00	8.55	0.04	0.00	3.32	2.36	0.00
05/03/22	7:42:00 AM	1.18	8.39	0.05	1.22	3.27	2.36	0.84
05/03/22	7:43:00 AM	5.67	7.91	0.30	8.33	5.00	2.36	5.66
05/03/22	7:44:00 AM	5.50	7.86	0.10	8.62	2.52	2.35	5.48
05/03/22	7:45:00 AM	5.50	7.80	0.03	8.89	1.99	2.36	5.49
05/03/22	7:46:00 AM	5.49	7.76	0.03	8.79	2.07	2.40	5.48
05/03/22	7:47:00 AM	5.54	7.72	0.03	8.96	2.19	2.40	5.51
05/03/22	7:48:00 AM	5.51	7.70	0.03	8.62	2.16	2.40	5.49
05/03/22	7:49:00 AM	5.52	7.67	0.03	8.46	2.21	2.40	5.50
05/03/22	7:50:00 AM	5.50	7.65	0.03	8.57	2.42	2.40	5.49
05/03/22	7:51:00 AM	5.50	7.63	0.03	8.63	2.70	2.40	5.48
05/03/22	7:52:00 AM	5.48	7.62	0.03	8.55	2.79	2.40	5.46
05/03/22	7:53:00 AM	5.49	7.60	0.03	8.60	2.97	2.40	5.48
05/03/22	7:54:00 AM	5.50	7.59	0.03	8.55	2.41	2.40	5.47
05/03/22	7:55:00 AM	5.49	7.57	0.03	8.53	2.81	2.40	5.47
05/03/22	7:56:00 AM	5.51	7.56	0.03	8.69	2.76	2.40	5.50
05/03/22	7:57:00 AM	5.50	7.55	0.03	8.51	2.57	2.40	5.49
05/03/22	7:58:00 AM	5.49	7.54	0.03	8.58	2.57	2.40	5.47
05/03/22	7:59:00 AM	5.51	7.53	0.03	8.60	2.56	2.37	5.48
05/03/22	8:00:00 AM	5.49	7.53	0.03	8.63	2.56	2.37	5.47
05/03/22	8:01:00 AM	5.48	7.52	0.03	8.57	2.51	2.37	5.47
05/03/22	8:02:00 AM	5.49	7.51	0.03	8.53	3.00	2.37	5.47
05/03/22	8:03:00 AM	5.49	7.50	0.03	8.48	2.67	2.37	5.47
05/03/22	8:04:00 AM	5.49	7.50	0.03	8.48	2.74	2.37	5.47
05/03/22	8:05:00 AM	5.50	7.49	0.03	7.71	2.70	2.37	5.45
05/03/22	8:06:00 AM	5.49	7.48	0.03	8.24	2.61	2.37	5.47
05/03/22	8:07:00 AM	5.59	7.46	0.03	8.70	2.14	2.37	5.57
05/03/22	8:08:00 AM	5.49	7.47	0.03	8.50	2.57	2.37	5.47
05/03/22	8:09:00 AM	5.52	7.46	0.03	8.69	2.35	2.37	5.49
05/03/22	8:10:00 AM	5.50	7.46	0.03	8.39	2.46	2.37	5.47
05/03/22	8:11:00 AM	5.49	7.46	0.03	8.55	2.61	2.37	5.47
05/03/22	8:12:00 AM	5.50	7.45	0.03	8.62	2.24	2.37	5.47
05/03/22	8:13:00 AM	5.53	7.44	0.03	8.75	2.59	2.37	5.50
05/03/22	8:14:00 AM	5.49	7.44	0.03	8.51	2.62	2.37	5.46
05/03/22	8:15:00 AM	5.55	7.42	0.03	8.70	3.19	2.38	5.55
05/03/22	8:16:00 AM	5.49	7.43	0.03	8.69	2.37	2.37	5.46
05/03/22	8:17:00 AM	5.50	7.42	0.03	8.57	2.39	2.37	5.48
05/03/22	8:18:00 AM	5.50	7.42	0.03	8.60	2.50	2.40	5.49
05/03/22	8:19:00 AM	5.48	7.42	0.03	8.41	2.59	2.40	5.46
05/03/22	8:20:00 AM	5.50	7.42	0.03	8.58	2.57	2.37	5.49
05/03/22	8:21:00 AM	5.52	7.42	0.03	8.51	2.35	2.37	5.49
05/03/22	8:22:00 AM	5.52	7.41	0.03	8.51	2.67	2.37	5.51
05/03/22	8:23:00 AM	5.51	7.41	0.03	8.55	2.95	2.37	5.48
05/03/22	8:24:00 AM	5.48	7.40	0.03	8.45	2.52	2.37	5.45
05/03/22	8:25:00 AM	5.51	7.40	0.03	8.53	2.76	2.37	5.49
05/03/22	8:26:00 AM	5.48	7.40	0.03	8.53	2.91	2.37	5.47
05/03/22	8:27:00 AM	5.52	7.39	0.03	8.60	3.05	2.37	5.50
05/03/22	8:28:00 AM	5.50	7.39	0.03	8.57	2.49	2.37	5.49
05/03/22	8:29:00 AM	5.48	7.39	0.03	8.43	2.70	2.37	5.46
05/03/22	8:30:00 AM	5.52	7.38	0.03	8.60	2.92	2.37	5.50
05/03/22	8:31:00 AM	5.51	7.38	0.03	8.58	2.30	2.37	5.49
05/03/22	8:32:00 AM	5.47	7.39	0.03	8.34	2.55	2.37	5.44
05/03/22	8:33:00 AM	5.51	7.38	0.03	8.46	2.51	2.37	5.48
05/03/22	8:34:00 AM	5.50	7.38	0.03	8.51	2.59	2.37	5.47
05/03/22	8:35:00 AM	5.49	7.38	0.03	8.48	2.57	2.36	5.47
05/03/22	8:36:00 AM	5.51	7.37	0.03	8.46	2.49	2.36	5.49
05/03/22	8:37:00 AM	5.46	7.38	0.03	8.39	2.62	2.36	5.45
05/03/22	8:38:00 AM	5.51	7.37	0.03	8.53	2.49	2.36	5.48
05/03/22	8:39:00 AM	5.51	7.37	0.03	8.63	2.44	2.36	5.49
05/03/22	8:40:00 AM	5.48	7.37	0.03	8.38	2.57	2.36	5.47
05/03/22	8:41:00 AM	5.52	7.36	0.03	8.60	2.86	2.36	5.50
05/03/22	8:42:00 AM	5.76	7.32	0.03	10.15	3.00	2.36	5.73
05/03/22	8:43:00 AM	5.99	7.28	0.03	10.87	2.82	2.36	5.97
05/03/22	8:44:00 AM	5.99	7.28	0.03	10.61	2.51	2.36	5.96
05/03/22	8:45:00 AM	6.01	7.27	0.03	10.76	2.70	2.36	5.99
05/03/22	8:46:00 AM	6.00	7.26	0.03	10.63	2.59	2.36	5.97

Woodville DWS May 3, 2022 Test # 23 - Well 2 - Train #1

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/03/22	8:36:00 AM	5.51	7.37	0.03	8.46	2.49	2.36	5.49
05/03/22	8:37:00 AM	5.46	7.38	0.03	8.39	2.62	2.36	5.45
05/03/22	8:38:00 AM	5.51	7.37	0.03	8.53	2.49	2.36	5.48
05/03/22	8:39:00 AM	5.51	7.37	0.03	8.63	2.44	2.36	5.49
05/03/22	8:40:00 AM	5.48	7.37	0.03	8.38	2.57	2.36	5.47
05/03/22	8:41:00 AM	5.52	7.36	0.03	8.60	2.86	2.36	5.50
05/03/22	8:42:00 AM	5.76	7.32	0.03	10.15	3.00	2.36	5.73
05/03/22	8:43:00 AM	5.99	7.28	0.03	10.87	2.82	2.36	5.97
05/03/22	8:44:00 AM	5.99	7.28	0.03	10.61	2.51	2.36	5.96
05/03/22	8:45:00 AM	6.01	7.27	0.03	10.76	2.70	2.36	5.99
05/03/22	8:46:00 AM	6.00	7.26	0.03	10.63	2.59	2.36	5.97
05/03/22	8:47:00 AM	6.03	7.26	0.03	10.80	2.86	2.36	6.00
05/03/22	8:48:00 AM	6.01	7.25	0.03	10.68	2.76	2.36	5.98
05/03/22	8:49:00 AM	5.98	7.26	0.03	10.52	2.57	2.37	5.96
05/03/22	8:50:00 AM	6.03	7.25	0.03	10.69	2.76	2.37	6.00
05/03/22	8:51:00 AM	6.01	7.24	0.03	10.76	2.61	2.37	5.99
05/03/22	8:52:00 AM	5.99	7.25	0.03	10.57	2.79	2.36	5.96
05/03/22	8:53:00 AM	6.00	7.24	0.03	10.69	2.51	2.36	5.98
05/03/22	8:54:00 AM	6.03	7.24	0.03	10.78	2.67	2.36	5.99
05/03/22	8:55:00 AM	5.99	7.24	0.03	10.56	3.03	2.36	5.96
05/03/22	8:56:00 AM	6.02	7.23	0.03	10.76	3.03	2.36	6.01
05/03/22	8:57:00 AM	5.99	7.23	0.03	10.61	2.51	2.36	5.96
05/03/22	8:58:00 AM	6.00	7.23	0.03	10.66	2.90	2.36	5.98
05/03/22	8:59:00 AM	6.01	7.23	0.03	10.69	2.62	2.36	5.99
05/03/22	9:00:00 AM	5.98	7.23	0.03	10.54	2.49	2.35	5.97
05/03/22	9:01:00 AM	6.03	7.22	0.03	10.85	2.74	2.35	6.00
05/03/22	9:02:00 AM	5.99	7.22	0.03	10.61	2.61	2.35	5.97
05/03/22	9:03:00 AM	5.99	7.22	0.03	10.57	2.86	2.35	5.98
05/03/22	9:04:00 AM	6.02	7.22	0.03	10.81	2.86	2.36	5.99
05/03/22	9:05:00 AM	5.99	7.22	0.03	10.66	2.90	2.36	5.97
05/03/22	9:06:00 AM	6.02	7.21	0.03	10.92	2.35	2.36	6.01
05/03/22	9:07:00 AM	5.96	7.22	0.03	10.64	2.37	2.36	5.94
05/03/22	9:08:00 AM	6.02	7.21	0.03	10.63	2.54	2.37	6.00
05/03/22	9:09:00 AM	6.00	7.21	0.03	10.63	2.51	2.37	5.97
05/03/22	9:10:00 AM	6.01	7.21	0.03	10.69	2.40	2.40	5.97
05/03/22	9:11:00 AM	6.00	7.21	0.03	10.56	2.59	2.40	5.97
05/03/22	9:12:00 AM	6.03	7.20	0.03	10.76	2.24	2.40	6.01
05/03/22	9:13:00 AM	5.99	7.21	0.03	10.64	2.50	2.40	5.97
05/03/22	9:14:00 AM	6.03	7.20	0.03	10.95	2.50	2.40	5.99
05/03/22	9:15:00 AM	5.99	7.21	0.03	10.64	2.72	2.40	5.97
05/03/22	9:16:00 AM	6.03	7.20	0.03	10.81	2.56	2.40	6.01
05/03/22	9:17:00 AM	5.99	7.20	0.03	10.71	2.84	2.40	5.97
05/03/22	9:18:00 AM	5.99	7.20	0.03	10.63	3.04	2.41	5.96
05/03/22	9:19:00 AM	6.00	7.20	0.03	10.61	2.61	2.41	5.98
05/03/22	9:20:00 AM	6.01	7.20	0.03	10.61	2.42	2.41	5.98
05/03/22	9:21:00 AM	6.03	7.19	0.03	10.76	2.67	2.41	6.01
05/03/22	9:22:00 AM	5.99	7.20	0.03	10.56	2.72	2.41	5.96
05/03/22	9:23:00 AM	5.99	7.19	0.03	10.64	2.71	2.41	5.97
05/03/22	9:24:00 AM	5.99	7.19	0.03	10.63	2.26	2.41	5.97
05/03/22	9:25:00 AM	5.99	7.19	0.03	10.63	2.49	2.41	5.96
05/03/22	9:26:00 AM	6.04	7.18	0.03	10.85	2.85	2.41	6.01
05/03/22	9:27:00 AM	5.99	7.19	0.03	10.45	2.89	2.41	5.97
05/03/22	9:28:00 AM	5.99	7.19	0.03	10.66	2.86	2.41	5.97
05/03/22	9:29:00 AM	6.03	7.18	0.03	10.78	2.59	2.41	6.00
05/03/22	9:30:00 AM	6.00	7.19	0.03	10.56	2.52	2.41	5.98
05/03/22	9:31:00 AM	5.99	7.18	0.03	10.51	3.14	2.42	5.96
05/03/22	9:32:00 AM	6.00	7.18	0.03	10.63	3.11	2.42	5.97
05/03/22	9:33:00 AM	6.01	7.18	0.03	10.64	3.00	2.42	5.97
05/03/22	9:34:00 AM	5.99	7.18	0.03	10.59	2.85	2.42	5.96
05/03/22	9:35:00 AM	6.00	7.18	0.03	10.61	3.00	2.42	5.98
05/03/22	9:36:00 AM	6.00	7.18	0.03	10.76	3.04	2.42	5.96
05/03/22	9:37:00 AM	6.04	7.17	0.03	10.83	3.10	2.42	6.02
05/03/22	9:38:00 AM	5.99	7.18	0.03	10.63	3.16	2.42	5.96
05/03/22	9:39:00 AM	6.00	7.18	0.03	10.61	3.27	2.45	5.97
05/03/22	9:40:00 AM	6.03	7.17	0.03	10.78	2.97	2.45	6.01
05/03/22	9:41:00 AM	5.98	7.18	0.03	10.49	3.15	2.45	5.96
05/03/22	9:42:00 AM	6.29	7.13	0.03	12.36	3.00	2.45	6.24
05/03/22	9:43:00 AM	6.49	7.10	0.03	12.87	2.86	2.45	6.45
05/03/22	9:44:00 AM	6.51	7.09	0.03	12.75	2.70	2.45	6.47
05/03/22	9:45:00 AM	6.50	7.08	0.03	12.93	3.02	2.45	6.46
05/03/22	9:46:00 AM	6.51	7.08	0.03	13.18	3.11	2.45	6.48

Woodville DWS May 3, 2022 Test # 24 - Well 2 - Train #1

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/03/22	9:36:00 AM	6.00	7.18	0.03	10.76	3.04	2.42	5.96
05/03/22	9:37:00 AM	6.04	7.17	0.03	10.83	3.10	2.42	6.02
05/03/22	9:38:00 AM	5.99	7.18	0.03	10.63	3.16	2.42	5.96
05/03/22	9:39:00 AM	6.00	7.18	0.03	10.61	3.27	2.45	5.97
05/03/22	9:40:00 AM	6.03	7.17	0.03	10.78	2.97	2.45	6.01
05/03/22	9:41:00 AM	5.98	7.18	0.03	10.49	3.15	2.45	5.96
05/03/22	9:42:00 AM	6.29	7.13	0.03	12.36	3.00	2.45	6.24
05/03/22	9:43:00 AM	6.49	7.10	0.03	12.87	2.86	2.45	6.45
05/03/22	9:44:00 AM	6.51	7.09	0.03	12.75	2.70	2.45	6.47
05/03/22	9:45:00 AM	6.50	7.08	0.03	12.93	3.02	2.45	6.46
05/03/22	9:46:00 AM	6.51	7.08	0.03	13.18	3.11	2.45	6.48
05/03/22	9:47:00 AM	6.49	7.08	0.03	12.94	3.13	2.45	6.46
05/03/22	9:48:00 AM	6.49	7.07	0.03	12.87	2.81	2.45	6.45
05/03/22	9:49:00 AM	6.49	7.07	0.03	12.82	2.97	2.45	6.45
05/03/22	9:50:00 AM	6.50	7.07	0.03	12.91	3.10	2.45	6.46
05/03/22	9:51:00 AM	6.49	7.07	0.03	12.89	3.07	2.45	6.46
05/03/22	9:52:00 AM	6.50	7.06	0.03	12.89	2.81	2.45	6.47
05/03/22	9:53:00 AM	6.49	7.06	0.03	12.87	3.00	2.45	6.47
05/03/22	9:54:00 AM	6.49	7.06	0.03	12.91	2.95	2.45	6.46
05/03/22	9:55:00 AM	6.49	7.05	0.03	12.84	3.30	2.45	6.47
05/03/22	9:56:00 AM	6.50	7.06	0.03	12.99	3.07	2.45	6.46
05/03/22	9:57:00 AM	6.50	7.05	0.03	13.01	3.26	2.45	6.48
05/03/22	9:58:00 AM	6.51	7.05	0.03	12.91	3.09	2.45	6.47
05/03/22	9:59:00 AM	6.51	7.05	0.03	12.93	2.97	2.45	6.47
05/03/22	10:00:00 AM	6.50	7.05	0.03	12.98	2.96	2.45	6.46
05/03/22	10:01:00 AM	6.51	7.05	0.03	13.01	3.00	2.45	6.47
05/03/22	10:02:00 AM	6.49	7.05	0.03	12.99	2.74	2.45	6.46
05/03/22	10:03:00 AM	6.49	7.05	0.03	12.77	2.96	2.45	6.46
05/03/22	10:04:00 AM	6.49	7.04	0.03	12.96	2.97	2.46	6.47
05/03/22	10:05:00 AM	6.50	7.04	0.03	12.77	3.00	2.45	6.47
05/03/22	10:06:00 AM	6.51	7.04	0.03	12.91	3.19	2.46	6.48
05/03/22	10:07:00 AM	6.49	7.04	0.03	13.08	2.72	2.46	6.47
05/03/22	10:08:00 AM	6.50	7.04	0.03	13.05	2.60	2.46	6.46
05/03/22	10:09:00 AM	6.50	7.04	0.03	12.99	2.66	2.46	6.47
05/03/22	10:10:00 AM	6.49	7.03	0.03	12.99	2.65	2.46	6.46
05/03/22	10:11:00 AM	6.50	7.03	0.03	12.87	2.57	2.46	6.47
05/03/22	10:12:00 AM	6.50	7.03	0.03	12.82	2.72	2.49	6.47
05/03/22	10:13:00 AM	6.49	7.03	0.03	13.10	2.91	2.49	6.47
05/03/22	10:14:00 AM	6.51	7.02	0.03	12.99	3.21	2.49	6.48
05/03/22	10:15:00 AM	6.51	7.02	0.03	13.01	2.60	2.49	6.48
05/03/22	10:16:00 AM	6.49	7.03	0.03	12.93	2.70	2.49	6.46
05/03/22	10:17:00 AM	6.50	7.02	0.03	12.89	2.90	2.49	6.48
05/03/22	10:18:00 AM	6.50	7.02	0.03	12.86	2.74	2.49	6.48
05/03/22	10:19:00 AM	6.52	7.02	0.03	13.17	2.75	2.49	6.51
05/03/22	10:20:00 AM	6.49	7.02	0.03	12.98	2.91	2.49	6.48
05/03/22	10:21:00 AM	6.50	7.02	0.03	12.93	3.00	2.49	6.48
05/03/22	10:22:00 AM	6.49	7.02	0.03	12.93	2.57	2.49	6.48
05/03/22	10:23:00 AM	6.50	7.02	0.03	12.91	2.74	2.49	6.48
05/03/22	10:24:00 AM	6.50	7.02	0.03	13.01	2.91	2.49	6.47
05/03/22	10:25:00 AM	6.52	7.02	0.03	12.75	2.56	2.49	6.48
05/03/22	10:26:00 AM	6.48	7.02	0.03	12.74	2.57	2.49	6.47
05/03/22	10:27:00 AM	6.50	7.02	0.03	12.96	2.79	2.46	6.48
05/03/22	10:28:00 AM	6.52	7.01	0.03	12.77	2.56	2.46	6.49
05/03/22	10:29:00 AM	6.50	7.02	0.03	13.01	2.95	2.46	6.48
05/03/22	10:30:00 AM	6.50	7.01	0.03	12.98	2.76	2.46	6.48
05/03/22	10:31:00 AM	6.49	7.01	0.03	12.91	2.81	2.46	6.47
05/03/22	10:32:00 AM	6.51	7.01	0.03	12.94	2.79	2.46	6.48
05/03/22	10:33:00 AM	6.49	7.01	0.03	13.03	2.86	2.46	6.46
05/03/22	10:34:00 AM	6.51	7.01	0.03	12.94	2.81	2.46	6.47
05/03/22	10:35:00 AM	6.46	7.02	0.03	12.74	2.80	2.46	6.43
05/03/22	10:36:00 AM	6.50	7.01	0.03	12.87	2.81	2.45	6.46
05/03/22	10:37:00 AM	6.50	7.01	0.03	12.93	2.67	2.45	6.47
05/03/22	10:38:00 AM	6.50	7.01	0.03	13.10	2.95	2.45	6.48
05/03/22	10:39:00 AM	6.50	7.01	0.03	12.94	2.57	2.45	6.48
05/03/22	10:40:00 AM	6.49	7.00	0.03	12.89	2.80	2.45	6.46
05/03/22	10:41:00 AM	6.51	7.00	0.03	12.98	2.84	2.45	6.48
05/03/22	10:42:00 AM	6.50	7.00	0.03	12.99	2.55	2.45	6.48
05/03/22	10:43:00 AM	6.78	6.96	0.03	14.25	2.69	2.45	6.75
05/03/22	10:44:00 AM	6.82	6.95	0.03	14.52	3.09	2.45	6.79
05/03/22	10:45:00 AM	6.78	6.95	0.03	14.33	2.76	2.45	6.76
05/03/22	10:46:00 AM	6.80	6.94	0.03	14.52	2.91	2.45	6.78

Woodville DWS May 3, 2022 Test # 25 - Well 2 - Train #1

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/03/22	10:36:00 AM	6.50	7.01	0.03	12.87	2.81	2.45	6.46
05/03/22	10:37:00 AM	6.50	7.01	0.03	12.93	2.67	2.45	6.47
05/03/22	10:38:00 AM	6.50	7.01	0.03	13.10	2.95	2.45	6.48
05/03/22	10:39:00 AM	6.50	7.01	0.03	12.94	2.57	2.45	6.48
05/03/22	10:40:00 AM	6.49	7.00	0.03	12.89	2.80	2.45	6.46
05/03/22	10:41:00 AM	6.51	7.00	0.03	12.98	2.84	2.45	6.48
05/03/22	10:42:00 AM	6.50	7.00	0.03	12.99	2.55	2.45	6.48
05/03/22	10:43:00 AM	6.78	6.96	0.03	14.25	2.69	2.45	6.75
05/03/22	10:44:00 AM	6.82	6.95	0.03	14.52	3.09	2.45	6.79
05/03/22	10:45:00 AM	6.78	6.95	0.03	14.33	2.76	2.45	6.76
05/03/22	10:46:00 AM	6.80	6.94	0.03	14.52	2.91	2.45	6.78
05/03/22	10:47:00 AM	6.78	6.94	0.03	14.44	3.04	2.45	6.77
05/03/22	10:48:00 AM	6.79	6.94	0.03	14.42	2.89	2.45	6.77
05/03/22	10:49:00 AM	6.79	6.93	0.03	14.47	2.81	2.45	6.78
05/03/22	10:50:00 AM	6.81	6.93	0.03	14.37	2.86	2.45	6.78
05/03/22	10:51:00 AM	6.82	6.92	0.03	14.42	2.67	2.46	6.79
05/03/22	10:52:00 AM	6.80	6.92	0.03	14.23	2.49	2.46	6.78
05/03/22	10:53:00 AM	6.83	6.92	0.03	14.56	2.39	2.46	6.80
05/03/22	10:54:00 AM	6.79	6.92	0.03	14.35	2.91	2.46	6.76
05/03/22	10:55:00 AM	6.80	6.92	0.03	14.40	3.00	2.46	6.78
05/03/22	10:56:00 AM	6.79	6.92	0.03	14.37	2.70	2.46	6.77
05/03/22	10:57:00 AM	6.80	6.92	0.03	14.23	2.70	2.46	6.76
05/03/22	10:58:00 AM	6.80	6.92	0.03	14.47	2.86	2.46	6.76
05/03/22	10:59:00 AM	6.79	6.92	0.03	14.39	2.56	2.46	6.77
05/03/22	11:00:00 AM	6.78	6.92	0.03	14.28	2.57	2.46	6.76
05/03/22	11:01:00 AM	6.81	6.91	0.03	14.40	2.59	2.46	6.79
05/03/22	11:02:00 AM	6.79	6.91	0.03	14.40	2.50	2.46	6.77
05/03/22	11:03:00 AM	6.83	6.91	0.03	14.40	2.57	2.46	6.79
05/03/22	11:04:00 AM	6.80	6.91	0.03	14.37	2.74	2.49	6.77
05/03/22	11:05:00 AM	6.82	6.90	0.03	14.51	2.76	2.46	6.81
05/03/22	11:06:00 AM	6.79	6.91	0.03	14.30	2.91	2.49	6.77
05/03/22	11:07:00 AM	6.78	6.91	0.03	14.42	3.10	2.49	6.77
05/03/22	11:08:00 AM	6.78	6.90	0.03	14.32	3.07	2.49	6.76
05/03/22	11:09:00 AM	6.82	6.90	0.03	14.39	2.80	2.49	6.79
05/03/22	11:10:00 AM	6.79	6.90	0.03	14.20	3.00	2.49	6.77
05/03/22	11:11:00 AM	6.83	6.90	0.03	14.42	2.65	2.49	6.81
05/03/22	11:12:00 AM	6.79	6.90	0.03	14.33	2.73	2.49	6.75
05/03/22	11:13:00 AM	6.82	6.89	0.03	14.57	2.61	2.49	6.79
05/03/22	11:14:00 AM	6.79	6.90	0.03	14.37	2.81	2.49	6.77
05/03/22	11:15:00 AM	6.83	6.89	0.03	14.32	2.85	2.49	6.81
05/03/22	11:16:00 AM	6.81	6.89	0.03	14.35	2.96	2.49	6.78
05/03/22	11:17:00 AM	6.81	6.89	0.03	14.23	2.89	2.49	6.79
05/03/22	11:18:00 AM	6.80	6.89	0.03	14.40	2.79	2.49	6.78
05/03/22	11:19:00 AM	6.80	6.89	0.03	14.25	2.65	2.49	6.77
05/03/22	11:20:00 AM	6.79	6.89	0.03	14.40	2.83	2.49	6.77
05/03/22	11:21:00 AM	6.83	6.89	0.03	14.49	3.00	2.49	6.80
05/03/22	11:22:00 AM	6.80	6.89	0.03	14.44	2.77	2.49	6.76
05/03/22	11:23:00 AM	6.80	6.89	0.03	14.35	3.05	2.49	6.77
05/03/22	11:24:00 AM	6.78	6.89	0.03	14.44	2.70	2.49	6.76
05/03/22	11:25:00 AM	6.80	6.89	0.03	14.42	2.84	2.49	6.76
05/03/22	11:26:00 AM	6.80	6.89	0.03	14.44	3.00	2.49	6.76
05/03/22	11:27:00 AM	6.80	6.88	0.03	14.32	2.90	2.49	6.77
05/03/22	11:28:00 AM	6.81	6.88	0.03	14.45	2.59	2.49	6.77
05/03/22	11:29:00 AM	6.83	6.88	0.03	14.56	2.75	2.49	6.80
05/03/22	11:30:00 AM	6.79	6.88	0.03	14.42	2.99	2.49	6.77
05/03/22	11:31:00 AM	6.79	6.88	0.03	14.39	2.75	2.49	6.76
05/03/22	11:32:00 AM	6.79	6.88	0.03	14.39	2.86	2.49	6.76
05/03/22	11:33:00 AM	6.79	6.88	0.03	14.32	3.00	2.49	6.75
05/03/22	11:34:00 AM	6.83	6.87	0.03	14.56	2.65	2.49	6.80
05/03/22	11:35:00 AM	6.78	6.88	0.03	14.35	2.62	2.49	6.77
05/03/22	11:36:00 AM	6.84	6.87	0.03	14.56	2.90	2.49	6.81
05/03/22	11:37:00 AM	6.80	6.88	0.03	14.49	2.57	2.49	6.77
05/03/22	11:38:00 AM	6.79	6.88	0.03	14.42	2.86	2.49	6.76
05/03/22	11:39:00 AM	6.81	6.87	0.03	14.35	2.65	2.49	6.77
05/03/22	11:40:00 AM	6.80	6.87	0.03	14.42	2.65	2.49	6.77
05/03/22	11:41:00 AM	6.79	6.87	0.03	14.32	2.70	2.49	6.76
05/03/22	11:42:00 AM	6.80	6.87	0.03	14.42	2.91	2.49	6.78
05/03/22	11:43:00 AM	2.63	7.59	0.03	6.52	2.96	2.49	5.42
05/03/22	11:44:00 AM	2.51	7.64	0.03	6.87	2.92	2.49	5.02
05/03/22	11:45:00 AM	2.45	7.66	0.03	6.30	3.05	2.49	4.90
05/03/22	11:46:00 AM	2.45	7.66	0.03	6.66	2.65	2.49	4.94

Woodville DWS May 3, 2022 Test # 26 - Well 1 & 2 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/03/22	11:36:00 AM	0.00	1.08	6.84	6.87	0.03	14.56	2.90	2.49	6.81
05/03/22	11:37:00 AM	0.00	1.08	6.80	6.88	0.03	14.49	2.57	2.49	6.77
05/03/22	11:38:00 AM	0.00	1.08	6.79	6.88	0.03	14.42	2.86	2.49	6.76
05/03/22	11:39:00 AM	0.00	1.08	6.81	6.87	0.03	14.35	2.65	2.49	6.77
05/03/22	11:40:00 AM	0.00	1.08	6.80	6.87	0.03	14.42	2.65	2.49	6.77
05/03/22	11:41:00 AM	0.00	1.08	6.79	6.87	0.03	14.32	2.70	2.49	6.76
05/03/22	11:42:00 AM	0.00	1.07	6.80	6.87	0.03	14.42	2.91	2.49	6.78
05/03/22	11:43:00 AM	2.90	1.65	2.63	7.59	0.03	6.52	2.96	2.49	5.42
05/03/22	11:44:00 AM	2.51	1.69	2.51	7.64	0.03	6.87	2.92	2.49	5.02
05/03/22	11:45:00 AM	2.48	1.69	2.45	7.66	0.03	6.30	3.05	2.49	4.90
05/03/22	11:46:00 AM	2.53	1.74	2.45	7.66	0.03	6.66	2.65	2.49	4.94
05/03/22	11:47:00 AM	2.48	1.70	2.51	7.70	0.03	6.85	2.44	2.49	4.99
05/03/22	11:48:00 AM	2.48	1.74	2.53	7.68	0.03	6.63	2.88	2.49	4.99
05/03/22	11:49:00 AM	2.53	1.75	2.48	7.71	0.03	6.52	2.84	2.49	4.96
05/03/22	11:50:00 AM	2.48	1.76	2.50	7.71	0.03	6.64	3.00	2.49	4.96
05/03/22	11:51:00 AM	2.48	1.78	2.49	7.70	0.03	6.51	2.59	2.49	4.92
05/03/22	11:52:00 AM	2.52	1.72	2.52	7.70	0.03	6.80	2.74	2.49	5.00
05/03/22	11:53:00 AM	2.48	1.77	2.50	7.72	0.03	6.56	2.55	2.49	4.96
05/03/22	11:54:00 AM	2.50	1.74	2.49	7.71	0.03	6.59	2.49	2.49	4.97
05/03/22	11:55:00 AM	2.51	1.77	2.45	7.73	0.03	6.90	2.81	2.49	4.96
05/03/22	11:56:00 AM	2.49	1.81	2.48	7.71	0.03	6.52	2.46	2.49	4.94
05/03/22	11:57:00 AM	2.54	1.74	2.49	7.74	0.03	6.75	3.07	2.49	5.00
05/03/22	11:58:00 AM	2.48	1.78	2.54	7.72	0.03	6.51	3.00	2.49	5.02
05/03/22	11:59:00 AM	2.52	1.75	2.52	7.74	0.03	6.87	2.80	2.49	5.01
05/03/22	12:00:00 PM	2.49	1.81	2.49	7.73	0.03	6.42	2.49	2.49	4.95
05/03/22	12:01:00 PM	2.49	1.83	2.52	7.75	0.03	6.49	2.29	2.49	5.00
05/03/22	12:02:00 PM	2.49	1.80	2.50	7.75	0.03	6.57	2.67	2.49	4.95
05/03/22	12:03:00 PM	2.49	1.76	2.49	7.73	0.03	6.52	3.14	2.49	4.95
05/03/22	12:04:00 PM	2.51	1.80	2.49	7.73	0.03	6.52	3.19	2.49	4.96
05/03/22	12:05:00 PM	2.49	1.84	2.50	7.75	0.03	6.54	2.85	2.49	4.97
05/03/22	12:06:00 PM	2.50	1.81	2.47	7.73	0.03	6.49	3.15	2.49	4.95
05/03/22	12:07:00 PM	2.49	1.78	2.49	7.75	0.03	6.75	3.14	2.49	4.97
05/03/22	12:08:00 PM	2.49	1.81	2.49	7.76	0.03	6.42	3.07	2.49	4.95
05/03/22	12:09:00 PM	2.54	1.82	2.52	7.75	0.03	6.57	3.13	2.49	5.01
05/03/22	12:10:00 PM	2.50	1.77	2.51	7.74	0.03	6.54	3.26	2.49	4.97
05/03/22	12:11:00 PM	2.49	1.82	2.50	7.74	0.03	6.59	2.89	2.49	4.96
05/03/22	12:12:00 PM	2.50	1.84	2.50	7.76	0.03	6.64	2.57	2.49	4.97
05/03/22	12:13:00 PM	2.50	1.80	2.49	7.74	0.03	6.54	2.72	2.49	4.95
05/03/22	12:14:00 PM	2.50	1.77	2.50	7.76	0.03	6.59	3.30	2.49	4.97
05/03/22	12:15:00 PM	2.50	1.75	2.51	7.76	0.03	6.75	3.07	2.49	4.99
05/03/22	12:16:00 PM	2.50	1.82	2.50	7.77	0.03	6.61	3.04	2.49	4.99
05/03/22	12:17:00 PM	2.50	1.85	2.51	7.74	0.03	6.69	3.14	2.49	4.97
05/03/22	12:18:00 PM	2.51	1.82	2.51	7.76	0.03	6.63	3.24	2.49	4.98
05/03/22	12:19:00 PM	2.50	1.77	2.49	7.74	0.03	6.68	3.27	2.49	4.97
05/03/22	12:20:00 PM	2.50	1.82	2.50	7.77	0.03	6.59	3.27	2.49	4.98
05/03/22	12:21:00 PM	2.51	1.80	2.51	7.78	0.03	6.68	3.27	2.49	4.99
05/03/22	12:22:00 PM	2.50	1.79	2.50	7.79	0.03	6.61	3.51	2.49	4.98
05/03/22	12:23:00 PM	2.50	1.81	2.50	7.77	0.03	6.61	3.43	2.49	4.98
05/03/22	12:24:00 PM	2.50	1.82	2.50	7.77	0.03	6.63	3.14	2.49	4.98
05/03/22	12:25:00 PM	2.51	1.79	2.51	7.79	0.03	6.64	3.19	2.49	4.99
05/03/22	12:26:00 PM	2.51	1.80	2.47	7.78	0.03	6.32	3.19	2.49	4.97
05/03/22	12:27:00 PM	2.50	1.80	2.50	7.75	0.03	6.71	2.97	2.49	4.97
05/03/22	12:28:00 PM	2.50	1.76	2.50	7.76	0.03	6.64	2.97	2.49	4.98
05/03/22	12:29:00 PM	2.51	1.80	2.51	7.76	0.03	6.64	3.10	2.49	5.00
05/03/22	12:30:00 PM	2.46	1.84	2.52	7.76	0.03	6.52	3.07	2.49	4.94
05/03/22	12:31:00 PM	2.50	1.88	2.51	7.76	0.03	6.68	3.49	2.49	4.98
05/03/22	12:32:00 PM	2.50	1.83	2.51	7.78	0.03	6.68	3.10	2.49	4.99
05/03/22	12:33:00 PM	2.51	1.79	2.53	7.75	0.03	6.69	3.46	2.49	5.00
05/03/22	12:34:00 PM	2.51	1.82	2.52	7.76	0.03	6.57	3.03	2.49	4.99
05/03/22	12:35:00 PM	2.50	1.86	2.48	7.77	0.03	6.75	3.14	2.49	4.95
05/03/22	12:36:00 PM	2.51	1.82	2.50	7.75	0.03	6.51	2.96	2.49	4.99
05/03/22	12:37:00 PM	2.46	1.83	2.51	7.77	0.03	6.33	3.14	2.49	4.94
05/03/22	12:38:00 PM	2.51	1.79	2.48	7.77	0.03	6.63	2.86	2.49	4.96
05/03/22	12:39:00 PM	2.47	1.81	2.52	7.74	0.03	6.49	2.62	2.49	4.95
05/03/22	12:40:00 PM	2.51	1.84	2.51	7.75	0.03	6.75	2.84	2.49	5.00
05/03/22	12:41:00 PM	2.36	1.81	2.19	7.81	0.03	5.77	3.01	2.49	4.47
05/03/22	12:42:00 PM	2.70	1.83	2.77	7.74	0.03	8.89	3.41	2.49	5.49
05/03/22	12:43:00 PM	2.74	1.77	2.74	7.74	0.03	8.34	3.07	2.49	5.43
05/03/22	12:44:00 PM	2.76	1.79	2.74	7.74	0.03	8.57	2.96	2.49	5.48
05/03/22	12:45:00 PM	2.73	1.75	2.74	7.72	0.03	8.82	2.92	2.49	5.46
05/03/22	12:46:00 PM	2.75	1.80	2.75	7.73	0.03	8.48	2.85	2.49	5.47

Woodville DWS May 3, 2022 Test # 27 - Well 1 & 2 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/03/22	12:36:00 PM	2.51	1.82	2.50	7.75	0.03	6.51	2.96	2.49	4.99
05/03/22	12:37:00 PM	2.46	1.83	2.51	7.77	0.03	6.33	3.14	2.49	4.94
05/03/22	12:38:00 PM	2.51	1.79	2.48	7.77	0.03	6.63	2.86	2.49	4.96
05/03/22	12:39:00 PM	2.47	1.81	2.52	7.74	0.03	6.49	2.62	2.49	4.95
05/03/22	12:40:00 PM	2.51	1.84	2.51	7.75	0.03	6.75	2.84	2.49	5.00
05/03/22	12:41:00 PM	2.36	1.81	2.19	7.81	0.03	5.77	3.01	2.49	4.47
05/03/22	12:42:00 PM	2.70	1.83	2.77	7.74	0.03	8.89	3.41	2.49	5.49
05/03/22	12:43:00 PM	2.74	1.77	2.74	7.74	0.03	8.34	3.07	2.49	5.43
05/03/22	12:44:00 PM	2.76	1.79	2.74	7.74	0.03	8.57	2.96	2.49	5.48
05/03/22	12:45:00 PM	2.73	1.75	2.74	7.72	0.03	8.82	2.92	2.49	5.46
05/03/22	12:46:00 PM	2.75	1.80	2.75	7.73	0.03	8.48	2.85	2.49	5.47
05/03/22	12:47:00 PM	2.77	1.80	2.74	7.72	0.03	8.82	2.92	2.49	5.50
05/03/22	12:48:00 PM	2.72	1.77	2.77	7.72	0.03	8.69	3.10	2.49	5.48
05/03/22	12:49:00 PM	2.76	1.83	2.74	7.73	0.03	8.77	3.11	2.49	5.47
05/03/22	12:50:00 PM	2.73	1.79	2.77	7.71	0.03	8.65	2.65	2.49	5.47
05/03/22	12:51:00 PM	2.77	1.80	2.74	7.72	0.03	8.91	3.00	2.49	5.49
05/03/22	12:52:00 PM	2.72	1.81	2.75	7.71	0.03	8.48	2.70	2.49	5.43
05/03/22	12:53:00 PM	2.76	1.81	2.73	7.72	0.03	8.74	2.79	2.49	5.48
05/03/22	12:54:00 PM	2.76	1.78	2.72	7.73	0.03	8.62	2.57	2.49	5.46
05/03/22	12:55:00 PM	2.75	1.75	2.73	7.71	0.03	8.81	3.04	2.49	5.48
05/03/22	12:56:00 PM	2.75	1.76	2.72	7.73	0.03	8.69	3.00	2.49	5.44
05/03/22	12:57:00 PM	2.76	1.75	2.78	7.71	0.03	8.75	2.92	2.49	5.52
05/03/22	12:58:00 PM	2.72	1.77	2.76	7.71	0.03	8.46	3.10	2.49	5.45
05/03/22	12:59:00 PM	2.76	1.75	2.73	7.72	0.03	8.65	3.05	2.49	5.45
05/03/22	1:00:00 PM	2.76	1.77	2.76	7.72	0.03	8.86	3.00	2.49	5.51
05/03/22	1:01:00 PM	2.75	1.73	2.73	7.70	0.03	8.75	3.05	2.49	5.45
05/03/22	1:02:00 PM	2.75	1.74	2.72	7.70	0.03	8.58	3.00	2.49	5.45
05/03/22	1:03:00 PM	2.72	1.77	2.74	7.71	0.03	8.50	2.75	2.49	5.43
05/03/22	1:04:00 PM	2.74	1.75	2.77	7.70	0.03	9.10	3.25	2.49	5.50
05/03/22	1:05:00 PM	2.75	1.76	2.72	7.71	0.03	8.57	2.81	2.49	5.45
05/03/22	1:06:00 PM	2.76	1.76	2.76	7.71	0.03	8.70	2.70	2.49	5.48
05/03/22	1:07:00 PM	2.75	1.73	2.79	7.71	0.03	8.86	2.50	2.49	5.50
05/03/22	1:08:00 PM	2.75	1.76	2.76	7.69	0.03	8.88	3.04	2.49	5.47
05/03/22	1:09:00 PM	2.76	1.76	2.73	7.70	0.03	8.72	3.04	2.50	5.46
05/03/22	1:10:00 PM	2.75	1.76	2.72	7.70	0.03	8.75	3.45	2.50	5.45
05/03/22	1:11:00 PM	2.75	1.73	2.73	7.71	0.03	8.62	3.15	2.50	5.45
05/03/22	1:12:00 PM	2.73	1.77	2.77	7.69	0.03	8.67	2.66	2.50	5.47
05/03/22	1:13:00 PM	2.74	1.76	2.71	7.71	0.03	8.57	2.97	2.50	5.42
05/03/22	1:14:00 PM	2.75	1.74	2.76	7.70	0.03	8.88	3.04	2.50	5.48
05/03/22	1:15:00 PM	2.74	1.74	2.77	7.70	0.03	8.94	3.02	2.50	5.50
05/03/22	1:16:00 PM	2.76	1.71	2.78	7.71	0.03	8.89	3.07	2.50	5.50
05/03/22	1:17:00 PM	2.75	1.77	2.73	7.70	0.03	8.89	3.00	2.50	5.46
05/03/22	1:18:00 PM	2.75	1.78	2.71	7.71	0.03	8.75	3.04	2.50	5.45
05/03/22	1:19:00 PM	2.74	1.74	2.71	7.70	0.03	8.48	3.01	2.50	5.42
05/03/22	1:20:00 PM	2.79	1.73	2.70	7.70	0.03	8.65	3.00	2.50	5.47
05/03/22	1:21:00 PM	2.76	1.72	2.72	7.70	0.03	8.62	3.25	2.50	5.45
05/03/22	1:22:00 PM	2.75	1.76	2.72	7.70	0.03	8.51	3.07	2.50	5.44
05/03/22	1:23:00 PM	2.75	1.75	2.72	7.69	0.03	8.93	2.89	2.50	5.45
05/03/22	1:24:00 PM	2.75	1.71	2.72	7.71	0.03	8.53	2.72	2.50	5.44
05/03/22	1:25:00 PM	2.75	1.75	2.75	7.69	0.03	8.72	3.00	2.50	5.48
05/03/22	1:26:00 PM	2.75	1.72	2.74	7.70	0.03	8.72	3.25	2.50	5.47
05/03/22	1:27:00 PM	2.74	1.72	2.79	7.68	0.03	9.12	3.27	2.50	5.53
05/03/22	1:28:00 PM	2.78	1.74	2.77	7.69	0.03	9.00	3.06	2.50	5.51
05/03/22	1:29:00 PM	2.75	1.74	2.79	7.70	0.03	8.89	2.65	2.50	5.51
05/03/22	1:30:00 PM	2.74	1.75	2.77	7.71	0.03	8.75	3.02	2.50	5.48
05/03/22	1:31:00 PM	2.74	1.73	2.78	7.69	0.03	9.06	3.07	2.50	5.50
05/03/22	1:32:00 PM	2.75	1.72	2.73	7.69	0.03	8.91	2.97	2.50	5.45
05/03/22	1:33:00 PM	2.76	1.76	2.73	7.69	0.03	8.70	3.12	2.50	5.45
05/03/22	1:34:00 PM	2.73	1.77	2.76	7.70	0.03	8.86	2.91	2.50	5.48
05/03/22	1:35:00 PM	2.75	1.71	2.78	7.69	0.03	9.06	2.90	2.50	5.51
05/03/22	1:36:00 PM	2.78	1.71	2.74	7.70	0.03	8.69	2.91	2.50	5.48
05/03/22	1:37:00 PM	2.74	1.75	2.76	7.69	0.03	8.69	2.96	2.50	5.49
05/03/22	1:38:00 PM	2.78	1.70	2.75	7.69	0.03	8.74	3.11	2.50	5.52
05/03/22	1:39:00 PM	2.74	1.73	2.77	7.69	0.03	8.69	3.30	2.50	5.49
05/03/22	1:40:00 PM	2.75	1.72	2.76	7.68	0.03	9.13	2.62	2.50	5.51
05/03/22	1:41:00 PM	2.74	1.71	2.77	7.68	0.03	8.93	3.02	2.50	5.49
05/03/22	1:42:00 PM	2.90	1.74	2.90	7.69	0.03	10.92	3.04	2.50	5.80
05/03/22	1:43:00 PM	3.01	1.74	3.00	7.66	0.03	10.95	3.10	2.50	5.94
05/03/22	1:44:00 PM	2.99	1.74	3.01	7.66	0.03	11.07	3.09	2.50	5.97
05/03/22	1:45:00 PM	3.00	1.73	3.00	7.67	0.03	10.80	3.02	2.50	5.96
05/03/22	1:46:00 PM	3.01	1.72	2.99	7.65	0.03	11.12	3.04	2.50	5.97

Woodville DWS May 3, 2022 Test # 28 - Well 1 & 2 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/03/22	1:36:00 PM	2.78	1.71	2.74	7.70	0.03	8.69	2.91	2.50	5.48
05/03/22	1:37:00 PM	2.74	1.75	2.76	7.69	0.03	8.69	2.96	2.50	5.49
05/03/22	1:38:00 PM	2.78	1.70	2.75	7.69	0.03	8.74	3.11	2.50	5.52
05/03/22	1:39:00 PM	2.74	1.73	2.77	7.69	0.03	8.69	3.30	2.50	5.49
05/03/22	1:40:00 PM	2.75	1.72	2.76	7.68	0.03	9.13	2.62	2.50	5.51
05/03/22	1:41:00 PM	2.74	1.71	2.77	7.68	0.03	8.93	3.02	2.50	5.49
05/03/22	1:42:00 PM	2.90	1.74	2.90	7.69	0.03	10.92	3.04	2.50	5.80
05/03/22	1:43:00 PM	3.01	1.74	3.00	7.66	0.03	10.95	3.10	2.50	5.94
05/03/22	1:44:00 PM	2.99	1.74	3.01	7.66	0.03	11.07	3.09	2.50	5.97
05/03/22	1:45:00 PM	3.00	1.73	3.00	7.67	0.03	10.80	3.02	2.50	5.96
05/03/22	1:46:00 PM	3.01	1.72	2.99	7.65	0.03	11.12	3.04	2.50	5.97
05/03/22	1:47:00 PM	2.98	1.68	2.99	7.65	0.03	10.97	3.12	2.50	5.93
05/03/22	1:48:00 PM	3.03	1.67	3.04	7.63	0.03	11.36	2.92	2.50	6.05
05/03/22	1:49:00 PM	2.99	1.71	3.00	7.65	0.03	11.12	3.00	2.50	5.96
05/03/22	1:50:00 PM	3.02	1.70	2.98	7.65	0.03	11.21	2.95	2.50	5.98
05/03/22	1:51:00 PM	2.98	1.76	2.99	7.65	0.03	10.97	2.66	2.50	5.94
05/03/22	1:52:00 PM	3.01	1.68	2.98	7.64	0.03	11.09	2.89	2.50	5.99
05/03/22	1:53:00 PM	2.99	1.65	3.00	7.63	0.03	11.18	3.24	2.50	5.96
05/03/22	1:54:00 PM	3.02	1.69	3.02	7.62	0.03	11.11	2.84	2.50	6.02
05/03/22	1:55:00 PM	2.98	1.69	2.99	7.62	0.03	10.97	2.96	2.50	5.94
05/03/22	1:56:00 PM	2.99	1.72	3.00	7.64	0.03	10.88	2.97	2.50	5.95
05/03/22	1:57:00 PM	3.00	1.74	2.97	7.64	0.03	11.19	3.00	2.50	5.94
05/03/22	1:58:00 PM	2.98	1.68	2.98	7.63	0.03	10.99	2.86	2.50	5.94
05/03/22	1:59:00 PM	3.02	1.70	2.97	7.67	0.03	11.06	3.00	2.50	5.96
05/03/22	2:00:00 PM	2.98	1.66	2.98	7.65	0.03	10.93	2.72	2.50	5.92
05/03/22	2:01:00 PM	2.99	1.74	2.97	7.62	0.03	10.87	2.62	2.50	5.91
05/03/22	2:02:00 PM	3.01	1.72	3.04	7.66	0.03	11.21	2.74	2.50	6.02
05/03/22	2:03:00 PM	2.98	1.69	3.06	7.62	0.03	11.18	2.91	2.49	6.00
05/03/22	2:04:00 PM	2.97	1.70	3.02	7.64	0.03	11.16	3.16	2.49	5.96
05/03/22	2:05:00 PM	3.02	1.67	3.01	7.62	0.03	11.40	3.11	2.49	6.00
05/03/22	2:06:00 PM	2.98	1.64	2.99	7.65	0.03	10.90	3.00	2.49	5.93
05/03/22	2:07:00 PM	3.02	1.65	2.99	7.63	0.03	10.83	3.04	2.49	5.98
05/03/22	2:08:00 PM	3.00	1.68	3.00	7.62	0.03	11.18	3.07	2.49	5.96
05/03/22	2:09:00 PM	2.98	1.67	3.00	7.62	0.03	11.19	3.06	2.49	5.93
05/03/22	2:10:00 PM	3.02	1.67	3.01	7.62	0.03	11.21	3.11	2.49	5.98
05/03/22	2:11:00 PM	3.00	1.65	2.99	7.66	0.03	11.21	2.96	2.49	5.97
05/03/22	2:12:00 PM	3.01	1.66	2.98	7.65	0.03	10.97	3.16	2.50	5.94
05/03/22	2:13:00 PM	3.02	1.68	3.02	7.63	0.03	11.23	3.07	2.50	6.02
05/03/22	2:14:00 PM	2.97	1.65	2.97	7.61	0.03	10.88	2.97	2.50	5.91
05/03/22	2:15:00 PM	3.02	1.68	2.96	7.62	0.03	11.14	2.57	2.50	5.96
05/03/22	2:16:00 PM	2.97	1.70	2.98	7.65	0.03	11.02	2.66	2.50	5.91
05/03/22	2:17:00 PM	3.00	1.70	3.04	7.60	0.03	11.19	2.65	2.50	5.99
05/03/22	2:18:00 PM	3.01	1.66	3.01	7.63	0.03	11.54	2.74	2.50	6.00
05/03/22	2:19:00 PM	2.98	1.71	2.97	7.64	0.03	10.88	2.79	2.50	5.91
05/03/22	2:20:00 PM	3.01	1.70	3.02	7.62	0.03	11.30	2.56	2.50	6.00
05/03/22	2:21:00 PM	2.96	1.71	3.02	7.63	0.03	11.16	2.95	2.50	5.94
05/03/22	2:22:00 PM	3.01	1.70	3.03	7.63	0.03	11.14	3.04	2.50	6.01
05/03/22	2:23:00 PM	3.00	1.70	3.01	7.62	0.03	11.28	2.78	2.50	5.97
05/03/22	2:24:00 PM	3.01	1.66	2.98	7.63	0.03	11.43	2.51	2.50	5.96
05/03/22	2:25:00 PM	2.98	1.69	2.99	7.64	0.03	10.97	3.01	2.50	5.93
05/03/22	2:26:00 PM	3.01	1.72	3.03	7.64	0.03	11.50	2.90	2.50	6.00
05/03/22	2:27:00 PM	2.97	1.67	3.03	7.64	0.03	11.07	2.80	2.50	5.96
05/03/22	2:28:00 PM	3.01	1.69	3.00	7.62	0.03	11.26	2.81	2.50	5.99
05/03/22	2:29:00 PM	3.00	1.64	3.02	7.66	0.03	11.40	2.80	2.50	5.99
05/03/22	2:30:00 PM	2.97	1.68	3.02	7.64	0.03	11.19	3.05	2.50	5.96
05/03/22	2:31:00 PM	3.01	1.69	2.98	7.64	0.03	11.35	2.62	2.50	5.97
05/03/22	2:32:00 PM	2.98	1.66	3.00	7.63	0.03	11.11	2.61	2.50	5.96
05/03/22	2:33:00 PM	3.02	1.63	3.02	7.63	0.03	11.24	2.75	2.50	6.02
05/03/22	2:34:00 PM	3.00	1.67	3.01	7.62	0.03	11.19	3.01	2.50	5.98
05/03/22	2:35:00 PM	3.00	1.70	2.99	7.63	0.03	11.35	2.90	2.50	5.95
05/03/22	2:36:00 PM	3.00	1.64	3.00	7.61	0.03	11.31	2.96	2.50	5.97
05/03/22	2:37:00 PM	2.99	1.66	2.99	7.65	0.03	11.48	2.65	2.50	5.97
05/03/22	2:38:00 PM	3.01	1.67	2.94	7.64	0.03	11.04	2.84	2.50	5.91
05/03/22	2:39:00 PM	2.99	1.72	3.01	7.65	0.03	11.36	2.85	2.50	5.97
05/03/22	2:40:00 PM	3.00	1.71	3.02	7.64	0.03	11.35	2.62	2.50	5.99
05/03/22	2:41:00 PM	3.00	1.65	3.00	7.62	0.03	11.23	2.52	2.50	5.97
05/03/22	2:42:00 PM	3.00	1.68	3.00	7.64	0.03	11.36	2.72	2.50	5.97
05/03/22	2:43:00 PM	2.99	1.70	2.99	7.61	0.03	11.30	3.27	2.50	5.96
05/03/22	2:44:00 PM	3.03	1.70	3.00	7.63	0.03	11.47	2.67	2.50	5.99
05/03/22	2:45:00 PM	0.00	1.24	5.29	7.25	0.03	6.76	3.09	2.50	5.19
05/03/22	2:46:00 PM	0.00	1.23	5.30	7.23	0.13	8.07	2.95	2.49	5.27

Woodville DWS May 4, 2022 Test # 29 - Well 1 & 2 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/04/22	6:51:00 AM	0.00	1.87	5.32	7.78	0.03	8.36	2.57	2.41	5.30
05/04/22	6:52:00 AM	0.00	1.84	5.33	7.76	0.03	8.62	2.65	2.41	5.31
05/04/22	6:53:00 AM	0.00	1.82	5.30	7.74	0.03	8.19	2.56	2.41	5.28
05/04/22	6:54:00 AM	0.00	1.80	5.33	7.73	0.03	8.50	2.97	2.41	5.30
05/04/22	6:55:00 AM	0.00	1.78	5.31	7.71	0.03	8.34	3.00	2.41	5.28
05/04/22	6:56:00 AM	3.10	2.20	2.88	8.12	0.03	19.21	2.85	2.41	6.72
05/04/22	6:57:00 AM	3.20	2.10	3.25	8.03	0.03	13.39	2.91	2.41	6.40
05/04/22	6:58:00 AM	3.26	2.09	3.24	8.02	0.03	13.89	3.02	2.41	6.49
05/04/22	6:59:00 AM	3.23	2.12	3.23	8.01	0.03	13.70	2.79	2.41	6.46
05/04/22	7:00:00 AM	3.28	2.07	3.27	7.97	0.03	13.84	3.02	2.41	6.53
05/04/22	7:01:00 AM	3.24	2.05	3.25	7.94	0.03	13.87	2.84	2.41	6.49
05/04/22	7:02:00 AM	3.26	2.00	3.25	7.94	0.03	14.16	2.89	2.40	6.49
05/04/22	7:03:00 AM	3.23	2.04	3.25	7.91	0.03	13.48	2.72	2.40	6.43
05/04/22	7:04:00 AM	3.26	1.98	3.23	7.90	0.03	13.80	2.90	2.40	6.49
05/04/22	7:05:00 AM	3.25	1.95	3.27	7.88	0.03	14.02	2.81	2.40	6.49
05/04/22	7:06:00 AM	3.25	1.93	3.27	7.86	0.03	14.02	2.70	2.40	6.50
05/04/22	7:07:00 AM	3.20	1.96	3.24	7.87	0.03	13.78	2.86	2.40	6.41
05/04/22	7:08:00 AM	3.25	1.95	3.22	7.87	0.03	13.72	2.89	2.40	6.45
05/04/22	7:09:00 AM	3.27	1.99	3.29	7.86	0.03	13.92	2.75	2.40	6.53
05/04/22	7:10:00 AM	3.25	1.97	3.25	7.88	0.03	13.75	2.95	2.40	6.46
05/04/22	7:11:00 AM	3.26	1.98	3.22	7.84	0.03	13.82	3.02	2.40	6.47
05/04/22	7:12:00 AM	3.25	1.95	3.28	7.85	0.03	13.72	3.04	2.40	6.49
05/04/22	7:13:00 AM	3.25	1.96	3.26	7.83	0.03	13.96	3.02	2.40	6.48
05/04/22	7:14:00 AM	3.24	1.92	3.26	7.82	0.03	13.56	3.00	2.40	6.47
05/04/22	7:15:00 AM	3.24	1.94	3.25	7.85	0.03	13.56	2.72	2.40	6.47
05/04/22	7:16:00 AM	3.27	1.94	3.26	7.83	0.03	13.82	2.84	2.40	6.51
05/04/22	7:17:00 AM	3.24	1.89	3.24	7.80	0.03	14.01	2.82	2.40	6.47
05/04/22	7:18:00 AM	3.24	1.93	3.25	7.81	0.03	13.65	2.80	2.40	6.46
05/04/22	7:19:00 AM	3.25	1.95	3.25	7.81	0.03	13.72	3.14	2.40	6.46
05/04/22	7:20:00 AM	3.24	1.88	3.26	7.78	0.03	13.66	3.14	2.40	6.46
05/04/22	7:21:00 AM	3.27	1.82	3.27	7.77	0.03	13.65	2.86	2.40	6.50
05/04/22	7:22:00 AM	3.23	1.85	3.25	7.79	0.03	13.84	2.75	2.40	6.46
05/04/22	7:23:00 AM	3.28	1.88	3.26	7.79	0.03	14.06	3.00	2.40	6.51
05/04/22	7:24:00 AM	3.24	1.82	3.28	7.78	0.03	13.89	3.09	2.40	6.49
05/04/22	7:25:00 AM	3.27	1.85	3.25	7.75	0.03	13.80	3.00	2.40	6.49
05/04/22	7:26:00 AM	3.24	1.88	3.27	7.79	0.03	13.85	3.35	2.40	6.49
05/04/22	7:27:00 AM	3.26	1.85	3.26	7.74	0.03	13.73	2.96	2.40	6.49
05/04/22	7:28:00 AM	3.23	1.90	3.24	7.76	0.03	13.80	3.15	2.40	6.44
05/04/22	7:29:00 AM	3.24	1.83	3.25	7.78	0.03	13.80	2.97	2.40	6.44
05/04/22	7:30:00 AM	3.28	1.83	3.25	7.76	0.03	13.96	2.84	2.40	6.50
05/04/22	7:31:00 AM	3.23	1.82	3.24	7.73	0.03	13.84	3.22	2.40	6.45
05/04/22	7:32:00 AM	3.25	1.85	3.25	7.76	0.03	13.75	3.07	2.40	6.45
05/04/22	7:33:00 AM	3.26	1.86	3.25	7.75	0.03	13.84	2.85	2.40	6.48
05/04/22	7:34:00 AM	3.23	1.82	3.24	7.73	0.03	13.72	2.75	2.40	6.44
05/04/22	7:35:00 AM	3.26	1.82	3.23	7.75	0.03	13.90	3.00	2.40	6.47
05/04/22	7:36:00 AM	3.25	1.80	3.24	7.73	0.03	13.94	3.07	2.40	6.46
05/04/22	7:37:00 AM	3.23	1.79	3.25	7.72	0.03	13.87	3.07	2.40	6.46
05/04/22	7:38:00 AM	3.27	1.81	3.24	7.73	0.03	13.97	2.80	2.40	6.49
05/04/22	7:39:00 AM	3.22	1.81	3.30	7.71	0.03	14.01	2.76	2.40	6.49
05/04/22	7:40:00 AM	3.25	1.80	3.25	7.74	0.03	13.73	2.80	2.40	6.46
05/04/22	7:41:00 AM	3.26	1.80	3.24	7.74	0.03	13.97	3.25	2.40	6.47
05/04/22	7:42:00 AM	3.22	1.77	3.25	7.70	0.03	13.77	3.00	2.40	6.44
05/04/22	7:43:00 AM	3.27	1.77	3.28	7.76	0.03	14.23	2.90	2.40	6.52
05/04/22	7:44:00 AM	3.26	1.85	3.22	7.73	0.03	13.99	2.95	2.40	6.46
05/04/22	7:45:00 AM	3.23	1.81	3.25	7.72	0.03	13.72	3.00	2.40	6.44
05/04/22	7:46:00 AM	3.26	1.83	3.27	7.71	0.03	14.20	2.57	2.40	6.51
05/04/22	7:47:00 AM	3.24	1.80	3.25	7.71	0.03	13.73	2.78	2.40	6.46
05/04/22	7:48:00 AM	3.27	1.81	3.24	7.72	0.03	13.99	3.05	2.40	6.49
05/04/22	7:49:00 AM	3.23	1.82	3.27	7.70	0.03	14.30	3.15	2.40	6.48
05/04/22	7:50:00 AM	3.27	1.82	3.23	7.72	0.03	13.87	2.90	2.40	6.47
05/04/22	7:51:00 AM	3.27	1.81	3.23	7.71	0.03	14.06	3.05	2.40	6.47
05/04/22	7:52:00 AM	3.22	1.74	3.21	7.73	0.03	13.63	3.35	2.40	6.39
05/04/22	7:53:00 AM	3.26	1.75	3.26	7.70	0.03	14.15	2.92	2.40	6.48
05/04/22	7:54:00 AM	3.22	1.81	3.30	7.69	0.03	13.96	3.10	2.40	6.49
05/04/22	7:55:00 AM	3.26	1.84	3.27	7.73	0.03	14.06	2.62	2.40	6.50
05/04/22	7:56:00 AM	3.22	1.80	3.27	7.69	0.03	14.04	2.78	2.37	6.45
05/04/22	7:57:00 AM	3.32	1.76	3.28	7.70	0.03	14.75	3.07	2.37	6.59
05/04/22	7:58:00 AM	3.42	1.76	3.40	7.66	0.03	15.42	3.07	2.37	6.78
05/04/22	7:59:00 AM	3.40	1.73	3.45	7.67	0.03	15.74	2.96	2.37	6.82
05/04/22	8:00:00 AM	3.51	1.74	3.69	7.62	0.03	21.22	3.20	2.37	7.23
05/04/22	8:01:00 AM	3.55	1.73	3.80	7.64	0.03	18.54	2.49	2.37	7.44

Woodville DWS May 4, 2022 Test # 30 - Well 1 & 2 - Train #1

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/04/22	7:51:00 AM	3.27	1.81	3.23	7.71	0.03	14.06	3.05	2.40	6.47
05/04/22	7:52:00 AM	3.22	1.74	3.21	7.73	0.03	13.63	3.35	2.40	6.39
05/04/22	7:53:00 AM	3.26	1.75	3.26	7.70	0.03	14.15	2.92	2.40	6.48
05/04/22	7:54:00 AM	3.22	1.81	3.30	7.69	0.03	13.96	3.10	2.40	6.49
05/04/22	7:55:00 AM	3.26	1.84	3.27	7.73	0.03	14.06	2.62	2.40	6.50
05/04/22	7:56:00 AM	3.22	1.80	3.27	7.69	0.03	14.04	2.78	2.37	6.45
05/04/22	7:57:00 AM	3.32	1.76	3.28	7.70	0.03	14.75	3.07	2.37	6.59
05/04/22	7:58:00 AM	3.42	1.76	3.40	7.66	0.03	15.42	3.07	2.37	6.78
05/04/22	7:59:00 AM	3.40	1.73	3.45	7.67	0.03	15.74	2.96	2.37	6.82
05/04/22	8:00:00 AM	3.51	1.74	3.69	7.62	0.03	21.22	3.20	2.37	7.23
05/04/22	8:01:00 AM	3.55	1.73	3.80	7.64	0.03	18.54	2.49	2.37	7.44
05/04/22	8:02:00 AM	3.41	1.71	3.46	7.64	0.03	15.09	3.04	2.37	6.87
05/04/22	8:03:00 AM	3.41	1.70	3.38	7.63	0.03	15.02	2.70	2.37	6.76
05/04/22	8:04:00 AM	3.42	1.73	3.40	7.66	0.03	14.95	2.65	2.37	6.79
05/04/22	8:05:00 AM	3.41	1.70	3.41	7.64	0.03	15.05	3.11	2.37	6.79
05/04/22	8:06:00 AM	3.42	1.72	3.39	7.64	0.03	14.71	3.14	2.37	6.77
05/04/22	8:07:00 AM	3.42	1.70	3.42	7.63	0.03	15.12	3.00	2.37	6.81
05/04/22	8:08:00 AM	3.38	1.76	3.41	7.64	0.03	14.95	2.95	2.37	6.75
05/04/22	8:09:00 AM	3.42	1.74	3.38	7.66	0.03	14.99	3.02	2.37	6.77
05/04/22	8:10:00 AM	3.37	1.71	3.41	7.62	0.03	14.87	3.00	2.36	6.76
05/04/22	8:11:00 AM	3.42	1.73	3.38	7.62	0.03	14.97	3.09	2.37	6.78
05/04/22	8:12:00 AM	3.41	1.71	3.38	7.64	0.03	15.07	2.97	2.36	6.76
05/04/22	8:13:00 AM	3.41	1.73	3.46	7.63	0.03	15.35	3.00	2.36	6.84
05/04/22	8:14:00 AM	3.41	1.72	3.38	7.64	0.03	15.00	3.31	2.36	6.76
05/04/22	8:15:00 AM	3.38	1.73	3.39	7.63	0.03	15.02	3.40	2.36	6.73
05/04/22	8:16:00 AM	3.41	1.70	3.38	7.61	0.03	14.99	3.05	2.36	6.78
05/04/22	8:17:00 AM	3.39	1.67	3.40	7.63	0.03	14.93	2.86	2.36	6.75
05/04/22	8:18:00 AM	3.41	1.69	3.43	7.62	0.03	15.35	2.96	2.36	6.82
05/04/22	8:19:00 AM	3.38	1.67	3.39	7.61	0.03	15.00	2.84	2.36	6.75
05/04/22	8:20:00 AM	3.41	1.67	3.36	7.62	0.03	15.00	3.11	2.36	6.75
05/04/22	8:21:00 AM	3.42	1.69	3.38	7.63	0.03	15.09	2.61	2.36	6.78
05/04/22	8:22:00 AM	3.38	1.66	3.44	7.60	0.03	15.18	2.70	2.36	6.79
05/04/22	8:23:00 AM	3.41	1.70	3.38	7.61	0.03	15.11	2.72	2.36	6.78
05/04/22	8:24:00 AM	3.38	1.69	3.41	7.60	0.03	15.12	3.05	2.36	6.76
05/04/22	8:25:00 AM	3.41	1.72	3.39	7.59	0.03	15.12	2.81	2.36	6.79
05/04/22	8:26:00 AM	3.38	1.67	3.39	7.63	0.03	15.07	2.86	2.36	6.74
05/04/22	8:27:00 AM	3.42	1.69	3.40	7.60	0.03	15.30	2.76	2.36	6.80
05/04/22	8:28:00 AM	3.40	1.65	3.38	7.61	0.03	15.16	2.79	2.36	6.76
05/04/22	8:29:00 AM	3.42	1.67	3.39	7.60	0.03	15.24	2.70	2.36	6.80
05/04/22	8:30:00 AM	3.40	1.73	3.37	7.61	0.03	14.93	3.05	2.36	6.77
05/04/22	8:31:00 AM	3.39	1.70	3.40	7.62	0.03	14.97	2.89	2.36	6.76
05/04/22	8:32:00 AM	3.41	1.73	3.40	7.65	0.03	15.14	2.76	2.36	6.79
05/04/22	8:33:00 AM	3.37	1.66	3.40	7.60	0.03	15.07	2.62	2.37	6.74
05/04/22	8:34:00 AM	3.42	1.75	3.39	7.63	0.03	15.33	2.65	2.36	6.80
05/04/22	8:35:00 AM	3.38	1.67	3.41	7.61	0.03	15.23	2.86	2.36	6.76
05/04/22	8:36:00 AM	3.42	1.69	3.39	7.60	0.03	14.99	2.80	2.37	6.78
05/04/22	8:37:00 AM	3.41	1.69	3.38	7.63	0.03	15.16	2.76	2.37	6.77
05/04/22	8:38:00 AM	3.38	1.71	3.41	7.61	0.03	14.85	2.57	2.37	6.77
05/04/22	8:39:00 AM	3.42	1.68	3.39	7.61	0.03	15.42	2.65	2.37	6.81
05/04/22	8:40:00 AM	3.37	1.68	3.39	7.59	0.03	15.24	2.80	2.37	6.76
05/04/22	8:41:00 AM	3.42	1.69	3.39	7.58	0.03	15.16	2.97	2.37	6.79
05/04/22	8:42:00 AM	3.39	1.67	3.39	7.58	0.03	15.12	2.76	2.37	6.78
05/04/22	8:43:00 AM	3.42	1.68	3.40	7.62	0.03	15.23	2.67	2.37	6.80
05/04/22	8:44:00 AM	3.40	1.65	3.38	7.58	0.03	15.26	2.70	2.37	6.76
05/04/22	8:45:00 AM	3.40	1.70	3.44	7.61	0.03	15.18	3.00	2.37	6.81
05/04/22	8:46:00 AM	3.41	1.69	3.39	7.60	0.03	15.26	2.85	2.37	6.79
05/04/22	8:47:00 AM	3.37	1.67	3.41	7.62	0.03	15.31	3.14	2.37	6.77
05/04/22	8:48:00 AM	3.42	1.67	3.40	7.61	0.03	15.18	2.90	2.37	6.79
05/04/22	8:49:00 AM	3.41	1.72	3.39	7.58	0.03	15.19	2.79	2.37	6.79
05/04/22	8:50:00 AM	3.40	1.70	3.40	7.59	0.03	15.07	2.97	2.37	6.77
05/04/22	8:51:00 AM	3.41	1.67	3.38	7.61	0.03	15.21	2.79	2.37	6.77
05/04/22	8:52:00 AM	3.37	1.66	3.40	7.61	0.03	14.97	3.02	2.37	6.74
05/04/22	8:53:00 AM	3.42	1.64	3.39	7.60	0.03	14.99	2.80	2.37	6.77
05/04/22	8:54:00 AM	3.41	1.73	3.39	7.62	0.03	15.28	2.91	2.37	6.79
05/04/22	8:55:00 AM	3.38	1.67	3.40	7.59	0.03	15.00	2.62	2.37	6.75
05/04/22	8:56:00 AM	3.42	1.66	3.40	7.57	0.03	15.21	2.97	2.37	6.81
05/04/22	8:57:00 AM	3.38	1.66	3.39	7.59	0.03	14.85	2.91	2.37	6.75
05/04/22	8:58:00 AM	0.00	1.35	0.00	7.74	0.03	0.00	2.97	2.37	0.00
05/04/22	8:59:00 AM	5.32	1.88	0.00	8.03	0.03	12.05	3.19	2.37	6.06
05/04/22	9:00:00 AM	5.02	1.80	0.00	7.96	0.08	7.02	4.25	2.37	4.98
05/04/22	9:01:00 AM	4.99	1.79	0.00	7.98	0.05	3.00	2.75	2.37	4.95

Woodville DWS May 4, 2022 Test # 31 - Well 1 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/04/22	9:43:00 AM	4.98	1.87	0.03	6.94	0.23	0.12	2.46	2.40	4.98
05/04/22	9:44:00 AM	4.99	1.86	0.03	6.94	0.23	0.12	2.57	2.40	5.00
05/04/22	9:45:00 AM	4.97	1.87	0.03	6.95	0.23	0.12	2.50	2.40	4.98
05/04/22	9:46:00 AM	5.01	1.87	0.03	4.41	0.38	12.21	3.04	2.40	5.04
05/04/22	9:47:00 AM	4.99	1.87	0.03	4.58	0.38	12.29	2.92	2.40	4.99
05/04/22	9:48:00 AM	5.00	1.87	0.03	4.63	0.21	12.46	2.55	2.40	5.01
05/04/22	9:49:00 AM	4.99	1.87	0.03	4.67	0.15	12.46	2.44	2.40	5.01
05/04/22	9:50:00 AM	4.99	1.87	0.03	4.63	0.12	12.50	2.76	2.40	5.00
05/04/22	9:51:00 AM	5.00	1.88	0.03	4.70	0.11	12.57	2.61	2.40	5.01
05/04/22	9:52:00 AM	5.01	1.86	0.03	4.67	0.10	12.53	2.65	2.40	5.01
05/04/22	9:53:00 AM	4.99	1.86	0.03	4.72	0.10	12.48	2.59	2.40	4.99
05/04/22	9:54:00 AM	4.99	1.86	0.03	4.77	0.10	12.58	2.59	2.40	5.01
05/04/22	9:55:00 AM	4.99	1.86	0.03	4.74	0.10	12.46	2.42	2.40	5.00
05/04/22	9:56:00 AM	4.99	1.86	0.03	4.65	0.10	12.55	2.61	2.40	5.00
05/04/22	9:57:00 AM	5.00	1.86	0.03	4.72	0.10	12.55	2.49	2.40	5.00
05/04/22	9:58:00 AM	4.99	1.86	0.03	4.76	0.10	12.60	2.57	2.40	5.01
05/04/22	9:59:00 AM	5.00	1.86	0.03	4.79	0.10	12.62	2.52	2.40	5.01
05/04/22	10:00:00 AM	4.98	1.84	0.03	4.74	0.10	12.58	2.42	2.40	5.00
05/04/22	10:01:00 AM	5.00	1.86	0.03	4.72	0.10	12.48	2.61	2.40	4.99
05/04/22	10:02:00 AM	5.00	1.86	0.03	4.76	0.10	12.60	2.40	2.40	5.01
05/04/22	10:03:00 AM	4.99	1.87	0.03	4.76	0.10	12.58	2.49	2.40	5.00
05/04/22	10:04:00 AM	5.00	1.86	0.03	4.77	0.10	12.62	2.49	2.40	5.01
05/04/22	10:05:00 AM	5.00	1.86	0.03	4.81	0.10	12.63	2.57	2.40	5.01
05/04/22	10:06:00 AM	5.01	1.86	0.03	4.70	0.10	12.63	2.57	2.40	5.01
05/04/22	10:07:00 AM	5.00	1.85	0.03	4.77	0.10	12.63	2.49	2.40	5.01
05/04/22	10:08:00 AM	4.99	1.86	0.03	4.72	0.10	12.58	2.55	2.40	5.00
05/04/22	10:09:00 AM	5.00	1.87	0.03	4.84	0.10	12.60	2.30	2.40	5.01
05/04/22	10:10:00 AM	4.99	1.85	0.03	4.82	0.10	12.60	2.15	2.40	5.00
05/04/22	10:11:00 AM	5.00	1.86	0.03	4.74	0.10	12.67	2.44	2.40	5.01
05/04/22	10:12:00 AM	5.00	1.85	0.03	4.84	0.10	12.67	2.25	2.40	5.01
05/04/22	10:13:00 AM	5.00	1.85	0.03	4.70	0.10	12.63	2.54	2.40	5.00
05/04/22	10:14:00 AM	5.00	1.84	0.03	4.77	0.10	12.63	2.30	2.40	5.01
05/04/22	10:15:00 AM	4.99	1.85	0.03	4.84	0.10	12.67	2.51	2.40	5.00
05/04/22	10:16:00 AM	4.99	1.85	0.03	4.77	0.10	12.67	2.42	2.40	5.00
05/04/22	10:17:00 AM	5.00	1.85	0.03	4.91	0.10	12.70	2.39	2.40	5.01
05/04/22	10:18:00 AM	5.00	1.85	0.03	4.89	0.10	12.70	2.19	2.40	5.00
05/04/22	10:19:00 AM	5.00	1.85	0.03	4.81	0.10	12.60	2.52	2.40	5.00
05/04/22	10:20:00 AM	5.01	1.86	0.03	4.89	0.10	12.75	2.49	2.40	5.02
05/04/22	10:21:00 AM	4.99	1.85	0.03	4.81	0.10	12.72	2.35	2.40	5.02
05/04/22	10:22:00 AM	5.00	1.85	0.03	4.89	0.10	12.70	2.54	2.40	5.01
05/04/22	10:23:00 AM	5.00	1.86	0.03	4.88	0.10	12.70	2.44	2.40	5.01
05/04/22	10:24:00 AM	5.00	1.85	0.03	4.91	0.10	12.70	2.57	2.40	5.01
05/04/22	10:25:00 AM	5.00	1.86	0.03	4.91	0.10	12.74	2.32	2.40	5.01
05/04/22	10:26:00 AM	5.00	1.86	0.03	4.82	0.10	12.75	2.29	2.40	5.02
05/04/22	10:27:00 AM	5.00	1.86	0.03	4.84	0.10	12.70	2.40	2.40	5.01
05/04/22	10:28:00 AM	5.00	1.85	0.03	4.88	0.10	12.74	2.54	2.40	5.01
05/04/22	10:29:00 AM	5.00	1.85	0.03	4.94	0.10	12.79	2.57	2.40	5.02
05/04/22	10:30:00 AM	5.00	1.85	0.03	4.94	0.10	12.75	2.55	2.40	5.02
05/04/22	10:31:00 AM	5.00	1.83	0.03	4.91	0.10	12.72	2.51	2.40	5.01
05/04/22	10:32:00 AM	5.01	1.85	0.03	4.91	0.10	12.81	2.37	2.40	5.02
05/04/22	10:33:00 AM	5.00	1.84	0.03	4.88	0.10	12.79	2.56	2.40	5.01
05/04/22	10:34:00 AM	5.01	1.86	0.03	4.98	0.10	12.82	2.37	2.40	5.02
05/04/22	10:35:00 AM	5.01	1.84	0.03	4.96	0.10	12.82	2.51	2.40	5.02
05/04/22	10:36:00 AM	5.00	1.84	0.03	4.93	0.10	12.82	2.57	2.40	5.01
05/04/22	10:37:00 AM	5.01	1.83	0.03	4.88	0.10	12.75	2.55	2.40	5.02
05/04/22	10:38:00 AM	5.00	1.84	0.03	4.93	0.10	12.79	2.40	2.40	5.02
05/04/22	10:39:00 AM	5.00	1.84	0.03	5.12	0.10	12.72	2.49	2.40	5.00
05/04/22	10:40:00 AM	5.01	1.85	0.03	5.00	0.10	12.94	2.59	2.40	5.03
05/04/22	10:41:00 AM	5.00	1.85	0.03	4.94	0.10	12.82	2.40	2.40	5.02
05/04/22	10:42:00 AM	5.01	1.84	0.03	4.91	0.10	12.81	2.27	2.40	5.01
05/04/22	10:43:00 AM	5.01	1.84	0.03	4.88	0.10	12.74	2.29	2.40	5.00
05/04/22	10:44:00 AM	5.01	1.86	0.03	4.93	0.10	12.82	2.60	2.40	5.02
05/04/22	10:45:00 AM	5.01	1.85	0.03	4.94	0.10	12.82	2.62	2.40	5.01
05/04/22	10:46:00 AM	5.01	1.84	0.03	4.89	0.10	12.82	2.57	2.40	5.03
05/04/22	10:47:00 AM	5.01	1.85	0.03	4.91	0.10	12.84	2.52	2.40	5.02
05/04/22	10:48:00 AM	5.02	1.84	0.03	4.94	0.10	12.82	2.57	2.40	5.03
05/04/22	10:49:00 AM	5.01	1.84	0.03	4.89	0.10	12.82	2.64	2.40	5.02
05/04/22	10:50:00 AM	5.51	1.83	0.03	6.69	0.10	14.68	2.70	2.40	5.52
05/04/22	10:51:00 AM	5.50	1.79	0.03	6.61	0.10	14.61	2.35	2.40	5.50
05/04/22	10:52:00 AM	5.51	1.80	0.03	6.47	0.10	14.63	2.42	2.40	5.51
05/04/22	10:53:00 AM	5.51	1.79	0.03	6.61	0.10	14.63	2.46	2.40	5.52

Woodville DWS May 4, 2022 Test # 32 - Well 1 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/04/22	10:44:00 AM	5.01	1.86	0.03	4.93	0.10	12.82	2.60	2.40	5.02
05/04/22	10:45:00 AM	5.01	1.85	0.03	4.94	0.10	12.82	2.62	2.40	5.01
05/04/22	10:46:00 AM	5.01	1.84	0.03	4.89	0.10	12.82	2.57	2.40	5.03
05/04/22	10:47:00 AM	5.01	1.85	0.03	4.91	0.10	12.84	2.52	2.40	5.02
05/04/22	10:48:00 AM	5.02	1.84	0.03	4.94	0.10	12.82	2.57	2.40	5.03
05/04/22	10:49:00 AM	5.01	1.84	0.03	4.89	0.10	12.82	2.64	2.40	5.02
05/04/22	10:50:00 AM	5.51	1.83	0.03	6.69	0.10	14.68	2.70	2.40	5.52
05/04/22	10:51:00 AM	5.50	1.79	0.03	6.61	0.10	14.61	2.35	2.40	5.50
05/04/22	10:52:00 AM	5.51	1.80	0.03	6.47	0.10	14.63	2.42	2.40	5.51
05/04/22	10:53:00 AM	5.51	1.79	0.03	6.61	0.10	14.63	2.46	2.40	5.52
05/04/22	10:54:00 AM	5.51	1.78	0.03	6.57	0.10	14.66	2.58	2.40	5.52
05/04/22	10:55:00 AM	5.51	1.78	0.03	6.52	0.10	14.66	2.61	2.40	5.51
05/04/22	10:56:00 AM	5.51	1.78	0.03	6.71	0.10	14.66	2.67	2.40	5.52
05/04/22	10:57:00 AM	5.51	1.78	0.03	6.63	0.10	14.69	2.42	2.40	5.51
05/04/22	10:58:00 AM	5.51	1.78	0.03	6.57	0.10	14.69	2.19	2.40	5.51
05/04/22	10:59:00 AM	5.51	1.78	0.03	6.61	0.10	14.71	2.35	2.40	5.53
05/04/22	11:00:00 AM	5.51	1.79	0.03	6.78	0.10	14.75	2.57	2.40	5.52
05/04/22	11:01:00 AM	5.51	1.77	0.03	6.59	0.10	14.59	2.44	2.40	5.51
05/04/22	11:02:00 AM	5.51	1.79	0.03	6.59	0.10	14.66	2.51	2.40	5.51
05/04/22	11:03:00 AM	5.50	1.77	0.03	6.64	0.10	14.66	2.16	2.40	5.51
05/04/22	11:04:00 AM	5.50	1.79	0.03	6.68	0.10	14.73	2.29	2.40	5.51
05/04/22	11:05:00 AM	5.51	1.78	0.03	6.73	0.10	14.68	2.51	2.40	5.51
05/04/22	11:06:00 AM	5.51	1.76	0.03	6.64	0.10	14.71	2.37	2.40	5.51
05/04/22	11:07:00 AM	5.52	1.77	0.03	6.68	0.10	14.71	2.30	2.40	5.51
05/04/22	11:08:00 AM	5.51	1.77	0.03	6.69	0.10	14.75	2.45	2.40	5.51
05/04/22	11:09:00 AM	5.50	1.76	0.03	6.76	0.10	14.80	2.56	2.40	5.52
05/04/22	11:10:00 AM	5.50	1.77	0.03	6.75	0.10	14.78	2.59	2.40	5.52
05/04/22	11:11:00 AM	5.51	1.77	0.03	6.73	0.10	14.83	2.56	2.40	5.53
05/04/22	11:12:00 AM	5.51	1.78	0.03	6.56	0.10	14.81	2.32	2.40	5.52
05/04/22	11:13:00 AM	5.51	1.76	0.03	6.76	0.10	14.78	2.57	2.40	5.51
05/04/22	11:14:00 AM	5.51	1.78	0.03	6.83	0.10	14.88	2.46	2.40	5.53
05/04/22	11:15:00 AM	5.51	1.77	0.03	6.73	0.10	14.83	2.42	2.40	5.51
05/04/22	11:16:00 AM	5.51	1.76	0.03	6.78	0.10	14.93	2.42	2.40	5.53
05/04/22	11:17:00 AM	5.51	1.77	0.03	6.75	0.10	14.83	2.37	2.40	5.52
05/04/22	11:18:00 AM	5.51	1.77	0.03	6.82	0.10	14.90	2.61	2.40	5.52
05/04/22	11:19:00 AM	5.51	1.76	0.03	6.76	0.10	14.83	2.65	2.40	5.51
05/04/22	11:20:00 AM	5.52	1.78	0.03	6.88	0.10	14.99	2.40	2.40	5.53
05/04/22	11:21:00 AM	5.51	1.77	0.03	6.82	0.10	14.90	2.40	2.40	5.51
05/04/22	11:22:00 AM	5.52	1.75	0.03	6.85	0.10	14.90	2.22	2.40	5.52
05/04/22	11:23:00 AM	5.51	1.75	0.03	6.87	0.10	14.93	2.44	2.40	5.51
05/04/22	11:24:00 AM	5.51	1.76	0.03	6.87	0.10	14.90	2.25	2.40	5.51
05/04/22	11:25:00 AM	5.51	1.76	0.03	6.83	0.10	14.95	2.42	2.40	5.52
05/04/22	11:26:00 AM	5.51	1.76	0.03	6.85	0.10	14.95	2.35	2.40	5.52
05/04/22	11:27:00 AM	5.50	1.76	0.03	6.92	0.10	15.00	2.49	2.40	5.52
05/04/22	11:28:00 AM	5.51	1.75	0.03	6.87	0.10	14.93	2.62	2.40	5.51
05/04/22	11:29:00 AM	5.52	1.75	0.03	6.94	0.10	15.05	2.30	2.40	5.53
05/04/22	11:30:00 AM	5.52	1.77	0.03	7.00	0.10	15.02	2.34	2.40	5.52
05/04/22	11:31:00 AM	5.51	1.77	0.03	6.83	0.10	14.93	2.24	2.40	5.52
05/04/22	11:32:00 AM	5.51	1.77	0.03	6.88	0.10	14.93	2.32	2.40	5.52
05/04/22	11:33:00 AM	5.51	1.76	0.03	6.95	0.10	15.02	2.25	2.40	5.50
05/04/22	11:34:00 AM	5.51	1.75	0.03	6.95	0.10	14.99	2.32	2.40	5.51
05/04/22	11:35:00 AM	5.51	1.77	0.03	6.97	0.10	15.05	2.51	2.40	5.52
05/04/22	11:36:00 AM	5.51	1.75	0.03	6.95	0.10	15.12	2.14	2.40	5.53
05/04/22	11:37:00 AM	5.51	1.76	0.03	7.04	0.10	15.09	2.29	2.40	5.53
05/04/22	11:38:00 AM	5.50	1.75	0.03	7.07	0.10	15.09	2.45	2.40	5.51
05/04/22	11:39:00 AM	5.51	1.75	0.03	7.09	0.10	15.12	2.51	2.40	5.53
05/04/22	11:40:00 AM	5.52	1.74	0.03	7.07	0.10	15.11	2.56	2.40	5.53
05/04/22	11:41:00 AM	5.51	1.76	0.03	7.04	0.10	15.12	2.14	2.40	5.52
05/04/22	11:42:00 AM	5.51	1.74	0.03	7.11	0.10	15.23	2.40	2.40	5.53
05/04/22	11:43:00 AM	5.51	1.74	0.03	7.11	0.10	15.21	2.35	2.40	5.53
05/04/22	11:44:00 AM	5.51	1.73	0.03	7.16	0.10	15.14	2.29	2.40	5.52
05/04/22	11:45:00 AM	5.52	1.74	0.03	7.11	0.10	15.23	2.45	2.40	5.53
05/04/22	11:46:00 AM	5.52	1.74	0.03	7.24	0.10	15.26	2.61	2.40	5.53
05/04/22	11:47:00 AM	5.51	1.74	0.03	7.11	0.10	15.21	2.46	2.40	5.52
05/04/22	11:48:00 AM	5.52	1.73	0.03	7.19	0.10	15.24	2.57	2.40	5.53
05/04/22	11:49:00 AM	5.52	1.76	0.03	7.21	0.10	15.28	2.34	2.40	5.53
05/04/22	11:50:00 AM	6.11	1.86	0.03	9.39	0.10	17.34	2.25	2.40	6.10
05/04/22	11:51:00 AM	6.03	1.80	0.03	9.00	0.10	17.34	2.52	2.40	6.05
05/04/22	11:52:00 AM	6.02	1.79	0.03	9.00	0.10	17.10	2.35	2.40	6.01
05/04/22	11:53:00 AM	6.02	1.78	0.03	8.94	0.10	17.18	2.22	2.40	6.03
05/04/22	11:54:00 AM	6.01	1.76	0.03	8.94	0.10	17.22	2.30	2.40	6.01

Woodville DWS May 4, 2022 Test # 33 - Well 1 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/04/22	11:46:00 AM	5.52	1.74	0.03	7.24	0.10	15.26	2.61	2.40	5.53
05/04/22	11:47:00 AM	5.51	1.74	0.03	7.11	0.10	15.21	2.46	2.40	5.52
05/04/22	11:48:00 AM	5.52	1.73	0.03	7.19	0.10	15.24	2.57	2.40	5.53
05/04/22	11:49:00 AM	5.52	1.76	0.03	7.21	0.10	15.28	2.34	2.40	5.53
05/04/22	11:50:00 AM	6.11	1.86	0.03	9.39	0.10	17.34	2.25	2.40	6.10
05/04/22	11:51:00 AM	6.03	1.80	0.03	9.00	0.10	17.34	2.52	2.40	6.05
05/04/22	11:52:00 AM	6.02	1.79	0.03	9.00	0.10	17.10	2.35	2.40	6.01
05/04/22	11:53:00 AM	6.02	1.78	0.03	8.94	0.10	17.18	2.22	2.40	6.03
05/04/22	11:54:00 AM	6.01	1.76	0.03	8.94	0.10	17.22	2.30	2.40	6.01
05/04/22	11:55:00 AM	6.00	1.78	0.03	9.06	0.10	17.18	2.44	2.40	6.02
05/04/22	11:56:00 AM	6.00	1.77	0.03	9.01	0.10	17.18	2.51	2.40	6.01
05/04/22	11:57:00 AM	6.01	1.75	0.03	9.01	0.10	17.17	2.39	2.40	6.01
05/04/22	11:58:00 AM	6.01	1.76	0.03	9.08	0.10	17.22	2.26	2.40	6.02
05/04/22	11:59:00 AM	6.00	1.77	0.03	9.12	0.10	17.22	2.44	2.40	6.00
05/04/22	12:00:00 PM	6.01	1.77	0.03	9.01	0.10	17.25	2.15	2.40	6.01
05/04/22	12:01:00 PM	5.99	1.74	0.03	9.15	0.10	17.20	2.29	2.40	6.00
05/04/22	12:02:00 PM	6.00	1.76	0.03	9.22	0.10	17.30	2.35	2.40	6.00
05/04/22	12:03:00 PM	6.00	1.76	0.03	9.27	0.10	17.37	2.32	2.40	6.01
05/04/22	12:04:00 PM	6.00	1.75	0.03	9.08	0.10	17.32	2.24	2.40	6.01
05/04/22	12:05:00 PM	6.01	1.74	0.03	9.17	0.10	17.41	2.27	2.40	6.02
05/04/22	12:06:00 PM	6.00	1.76	0.03	9.13	0.10	17.34	2.19	2.40	6.01
05/04/22	12:07:00 PM	6.00	1.75	0.03	9.25	0.10	17.37	2.35	2.40	6.00
05/04/22	12:08:00 PM	6.00	1.78	0.03	9.22	0.10	17.30	2.51	2.40	6.00
05/04/22	12:09:00 PM	6.01	1.76	0.03	9.24	0.10	17.51	2.55	2.40	6.02
05/04/22	12:10:00 PM	6.00	1.75	0.03	9.13	0.10	17.48	2.55	2.40	6.00
05/04/22	12:11:00 PM	6.00	1.76	0.03	9.25	0.10	17.41	2.57	2.40	5.99
05/04/22	12:12:00 PM	6.01	1.74	0.03	9.25	0.10	17.58	2.65	2.40	6.01
05/04/22	12:13:00 PM	6.01	1.74	0.03	9.27	0.10	17.58	2.57	2.40	6.02
05/04/22	12:14:00 PM	6.01	1.76	0.03	9.34	0.10	17.68	2.35	2.40	6.02
05/04/22	12:15:00 PM	6.01	1.76	0.03	9.56	0.10	17.68	2.35	2.40	6.01
05/04/22	12:16:00 PM	6.00	1.75	0.03	9.48	0.10	17.61	2.22	2.40	6.00
05/04/22	12:17:00 PM	6.00	1.74	0.03	9.46	0.10	17.68	2.37	2.40	6.01
05/04/22	12:18:00 PM	6.00	1.74	0.03	9.51	0.10	17.73	2.72	2.40	6.01
05/04/22	12:19:00 PM	6.00	1.75	0.03	9.49	0.10	17.73	2.61	2.40	6.01
05/04/22	12:20:00 PM	5.99	1.75	0.03	9.87	0.10	17.92	2.39	2.40	6.01
05/04/22	12:21:00 PM	6.01	1.75	0.03	9.39	0.10	17.68	2.35	2.40	6.01
05/04/22	12:22:00 PM	6.01	1.75	0.03	9.53	0.10	17.92	2.42	2.40	6.02
05/04/22	12:23:00 PM	6.00	1.75	0.03	9.73	0.10	17.84	2.63	2.40	6.00
05/04/22	12:24:00 PM	6.00	1.74	0.03	9.68	0.10	18.01	2.57	2.40	6.01
05/04/22	12:25:00 PM	6.00	1.76	0.03	9.72	0.10	17.90	2.37	2.40	6.00
05/04/22	12:26:00 PM	6.00	1.73	0.03	9.72	0.10	17.97	2.42	2.40	6.02
05/04/22	12:27:00 PM	5.99	1.75	0.03	9.87	0.10	17.85	2.49	2.40	5.98
05/04/22	12:28:00 PM	6.01	1.74	0.03	9.82	0.10	17.99	2.35	2.40	6.00
05/04/22	12:29:00 PM	6.01	1.73	0.03	9.78	0.10	18.01	2.49	2.40	6.01
05/04/22	12:30:00 PM	6.00	1.73	0.03	9.87	0.10	18.14	2.44	2.40	6.01
05/04/22	12:31:00 PM	6.01	1.75	0.03	9.94	0.10	18.14	2.80	2.40	6.01
05/04/22	12:32:00 PM	6.00	1.73	0.03	10.01	0.10	18.08	2.56	2.40	6.01
05/04/22	12:33:00 PM	6.00	1.75	0.03	9.99	0.10	18.18	2.40	2.40	6.00
05/04/22	12:34:00 PM	6.01	1.72	0.03	10.01	0.10	18.27	2.44	2.40	6.01
05/04/22	12:35:00 PM	6.00	1.73	0.03	9.99	0.10	18.23	2.37	2.40	6.01
05/04/22	12:36:00 PM	6.00	1.75	0.03	10.09	0.10	18.27	2.44	2.40	6.00
05/04/22	12:37:00 PM	6.00	1.73	0.03	10.08	0.10	18.20	2.49	2.40	5.99
05/04/22	12:38:00 PM	6.00	1.73	0.03	10.15	0.10	18.44	2.62	2.40	6.02
05/04/22	12:39:00 PM	6.00	1.72	0.03	10.13	0.10	18.28	2.65	2.40	5.99
05/04/22	12:40:00 PM	6.00	1.73	0.03	10.23	0.10	18.40	2.64	2.40	6.01
05/04/22	12:41:00 PM	6.01	1.74	0.03	10.21	0.10	18.45	2.62	2.40	6.01
05/04/22	12:42:00 PM	6.00	1.73	0.03	10.33	0.10	18.52	2.35	2.40	6.02
05/04/22	12:43:00 PM	5.99	1.74	0.03	10.23	0.10	18.47	2.19	2.40	6.00
05/04/22	12:44:00 PM	6.00	1.73	0.03	10.32	0.10	18.59	2.38	2.40	6.02
05/04/22	12:45:00 PM	5.99	1.72	0.03	10.42	0.10	18.56	2.51	2.40	6.00
05/04/22	12:46:00 PM	6.00	1.73	0.03	10.42	0.10	18.61	2.57	2.40	6.01
05/04/22	12:47:00 PM	6.00	1.74	0.03	10.42	0.10	18.66	2.45	2.40	6.01
05/04/22	12:48:00 PM	6.00	1.73	0.03	10.47	0.10	18.63	2.44	2.40	6.00
05/04/22	12:49:00 PM	5.99	1.71	0.03	10.37	0.10	18.69	2.49	2.40	6.00
05/04/22	12:50:00 PM	6.01	1.72	0.03	10.45	0.10	18.71	2.39	2.40	6.01
05/04/22	12:51:00 PM	6.00	1.73	0.03	10.45	0.10	18.78	2.42	2.40	6.00
05/04/22	12:52:00 PM	6.33	1.86	0.03	11.96	0.10	20.50	2.25	2.40	6.38
05/04/22	12:53:00 PM	6.42	1.86	0.03	12.14	0.10	20.60	2.29	2.40	6.43
05/04/22	12:54:00 PM	6.49	1.89	0.03	12.65	0.10	21.05	2.44	2.40	6.51
05/04/22	12:55:00 PM	6.51	1.86	0.03	12.67	0.10	20.94	2.55	2.40	6.51
05/04/22	12:56:00 PM	6.51	1.84	0.03	12.67	0.10	21.11	2.64	2.40	6.52

Woodville DWS May 4, 2022 Test # 34 - Well 1 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/04/22	12:48:00 PM	6.00	1.73	0.03	10.47	0.10	18.63	2.44	2.40	6.00
05/04/22	12:49:00 PM	5.99	1.71	0.03	10.37	0.10	18.69	2.49	2.40	6.00
05/04/22	12:50:00 PM	6.01	1.72	0.03	10.45	0.10	18.71	2.39	2.40	6.01
05/04/22	12:51:00 PM	6.00	1.73	0.03	10.45	0.10	18.78	2.42	2.40	6.00
05/04/22	12:52:00 PM	6.33	1.86	0.03	11.96	0.10	20.50	2.25	2.40	6.38
05/04/22	12:53:00 PM	6.42	1.86	0.03	12.14	0.10	20.60	2.29	2.40	6.43
05/04/22	12:54:00 PM	6.49	1.89	0.03	12.65	0.10	21.05	2.44	2.40	6.51
05/04/22	12:55:00 PM	6.51	1.86	0.03	12.67	0.10	20.94	2.55	2.40	6.51
05/04/22	12:56:00 PM	6.51	1.84	0.03	12.67	0.10	21.11	2.64	2.40	6.52
05/04/22	12:57:00 PM	6.51	1.86	0.03	12.82	0.10	21.10	2.52	2.40	6.51
05/04/22	12:58:00 PM	6.51	1.85	0.03	12.77	0.10	21.22	2.70	2.40	6.53
05/04/22	12:59:00 PM	6.50	1.87	0.03	12.87	0.10	21.22	2.46	2.40	6.51
05/04/22	1:00:00 PM	6.51	1.84	0.03	12.84	0.10	21.13	2.27	2.40	6.51
05/04/22	1:01:00 PM	6.51	1.83	0.03	12.89	0.10	21.25	2.46	2.40	6.51
05/04/22	1:02:00 PM	6.51	1.85	0.03	12.93	0.10	21.36	2.64	2.40	6.53
05/04/22	1:03:00 PM	6.51	1.87	0.03	12.91	0.10	21.29	2.44	2.40	6.51
05/04/22	1:04:00 PM	6.51	1.82	0.03	12.93	0.10	21.37	2.52	2.40	6.52
05/04/22	1:05:00 PM	6.50	1.84	0.03	13.08	0.10	21.37	2.32	2.40	6.52
05/04/22	1:06:00 PM	6.51	1.85	0.03	12.89	0.10	21.37	2.40	2.40	6.51
05/04/22	1:07:00 PM	6.51	1.84	0.03	12.99	0.10	21.37	2.46	2.37	6.52
05/04/22	1:08:00 PM	6.51	1.82	0.03	13.06	0.10	21.42	2.34	2.40	6.51
05/04/22	1:09:00 PM	6.51	1.84	0.03	13.05	0.10	21.41	2.52	2.40	6.51
05/04/22	1:10:00 PM	6.51	1.82	0.03	13.12	0.10	21.44	2.69	2.37	6.51
05/04/22	1:11:00 PM	6.51	1.84	0.03	13.18	0.10	21.53	2.55	2.37	6.51
05/04/22	1:12:00 PM	6.50	1.83	0.03	13.17	0.10	21.48	2.65	2.37	6.51
05/04/22	1:13:00 PM	6.50	1.83	0.03	13.08	0.10	21.56	2.34	2.37	6.51
05/04/22	1:14:00 PM	6.51	1.83	0.03	13.12	0.10	21.53	2.59	2.37	6.51
05/04/22	1:15:00 PM	6.51	1.84	0.03	13.20	0.10	21.53	2.55	2.37	6.51
05/04/22	1:16:00 PM	6.51	1.82	0.03	13.22	0.10	21.60	2.57	2.37	6.51
05/04/22	1:17:00 PM	6.51	1.82	0.03	13.29	0.10	21.56	2.49	2.37	6.50
05/04/22	1:18:00 PM	6.51	1.82	0.03	13.06	0.10	21.61	2.51	2.37	6.52
05/04/22	1:19:00 PM	6.50	1.83	0.03	13.24	0.10	21.65	2.57	2.37	6.52
05/04/22	1:20:00 PM	6.51	1.83	0.03	13.22	0.10	21.60	2.57	2.37	6.51
05/04/22	1:21:00 PM	6.51	1.81	0.03	12.94	0.10	21.60	2.79	2.37	6.51
05/04/22	1:22:00 PM	6.51	1.81	0.03	13.17	0.10	21.77	2.45	2.37	6.52
05/04/22	1:23:00 PM	6.49	1.82	0.03	13.13	0.10	21.66	2.44	2.37	6.50
05/04/22	1:24:00 PM	6.50	1.84	0.03	13.18	0.10	21.61	2.58	2.37	6.50
05/04/22	1:25:00 PM	6.51	1.83	0.03	13.34	0.10	21.75	2.42	2.37	6.52
05/04/22	1:26:00 PM	6.50	1.83	0.03	13.27	0.10	21.60	2.46	2.37	6.50
05/04/22	1:27:00 PM	6.50	1.84	0.03	13.46	0.10	21.80	2.40	2.37	6.52
05/04/22	1:28:00 PM	6.50	1.83	0.03	13.30	0.10	21.58	2.55	2.37	6.49
05/04/22	1:29:00 PM	6.50	1.84	0.03	13.25	0.10	21.60	2.62	2.37	6.49
05/04/22	1:30:00 PM	6.49	1.84	0.03	13.41	0.10	21.70	2.62	2.37	6.50
05/04/22	1:31:00 PM	6.50	1.82	0.03	13.48	0.10	21.77	2.62	2.37	6.51
05/04/22	1:32:00 PM	6.51	1.85	0.03	13.41	0.10	21.84	2.57	2.37	6.51
05/04/22	1:33:00 PM	6.50	1.81	0.03	13.37	0.10	21.72	2.46	2.37	6.51
05/04/22	1:34:00 PM	6.51	1.82	0.03	13.42	0.10	21.82	2.65	2.37	6.51
05/04/22	1:35:00 PM	6.50	1.82	0.03	13.37	0.10	21.75	2.52	2.37	6.50
05/04/22	1:36:00 PM	6.51	1.84	0.03	13.36	0.10	21.77	2.52	2.37	6.51
05/04/22	1:37:00 PM	6.50	1.84	0.03	13.51	0.10	21.87	2.57	2.37	6.50
05/04/22	1:38:00 PM	6.50	1.83	0.03	13.51	0.10	21.89	2.42	2.37	6.52
05/04/22	1:39:00 PM	6.51	1.82	0.03	13.41	0.10	21.87	2.50	2.37	6.52
05/04/22	1:40:00 PM	6.50	1.82	0.03	13.36	0.10	21.89	2.53	2.37	6.52
05/04/22	1:41:00 PM	6.51	1.81	0.03	13.39	0.10	21.78	2.39	2.36	6.50
05/04/22	1:42:00 PM	6.50	1.81	0.03	13.44	0.10	21.96	2.39	2.36	6.52
05/04/22	1:43:00 PM	6.51	1.82	0.03	13.48	0.10	21.90	2.40	2.36	6.52
05/04/22	1:44:00 PM	6.51	1.83	0.03	13.46	0.10	21.87	2.27	2.36	6.52
05/04/22	1:45:00 PM	6.50	1.80	0.03	13.41	0.10	21.85	2.57	2.36	6.50
05/04/22	1:46:00 PM	6.50	1.81	0.03	13.49	0.10	21.89	2.56	2.36	6.51
05/04/22	1:47:00 PM	6.51	1.81	0.03	13.49	0.10	21.89	2.57	2.36	6.51
05/04/22	1:48:00 PM	6.50	1.81	0.03	13.58	0.10	21.96	2.65	2.36	6.52
05/04/22	1:49:00 PM	6.51	1.80	0.03	13.46	0.10	21.90	2.61	2.36	6.50
05/04/22	1:50:00 PM	6.50	1.84	0.03	13.53	0.10	21.92	2.45	2.36	6.51
05/04/22	1:51:00 PM	6.50	1.82	0.03	13.56	0.10	21.96	2.46	2.36	6.51
05/04/22	1:52:00 PM	6.51	1.81	0.03	13.58	0.10	21.99	2.55	2.36	6.51
05/04/22	1:53:00 PM	6.50	1.81	0.03	13.61	0.10	21.99	2.75	2.36	6.52
05/04/22	1:54:00 PM	6.35	1.82	0.03	12.53	0.10	18.59	2.46	2.36	6.13
05/04/22	1:55:00 PM	6.43	1.81	0.03	13.18	0.10	21.18	2.57	2.36	6.41
05/04/22	1:56:00 PM	6.41	1.82	0.03	13.68	0.10	21.53	2.30	2.36	6.42
05/04/22	1:57:00 PM	6.69	1.80	0.03	14.81	0.10	22.68	2.37	2.36	6.67
05/04/22	1:58:00 PM	6.80	1.76	0.03	15.31	0.10	23.33	2.52	2.36	6.81

Woodville DWS May 4, 2022 Test # 35 - Well 1 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/04/22	1:52:00 PM	6.51	1.81	0.03	13.58	0.10	21.99	2.55	2.36	6.51
05/04/22	1:53:00 PM	6.50	1.81	0.03	13.61	0.10	21.99	2.75	2.36	6.52
05/04/22	1:54:00 PM	6.35	1.82	0.03	12.53	0.10	18.59	2.46	2.36	6.13
05/04/22	1:55:00 PM	6.43	1.81	0.03	13.18	0.10	21.18	2.57	2.36	6.41
05/04/22	1:56:00 PM	6.41	1.82	0.03	13.68	0.10	21.53	2.30	2.36	6.42
05/04/22	1:57:00 PM	6.69	1.80	0.03	14.81	0.10	22.68	2.37	2.36	6.67
05/04/22	1:58:00 PM	6.80	1.76	0.03	15.31	0.10	23.33	2.52	2.36	6.81
05/04/22	1:59:00 PM	6.81	1.75	0.03	15.26	0.10	23.36	2.70	2.36	6.82
05/04/22	2:00:00 PM	6.80	1.77	0.03	15.26	0.10	23.33	2.67	2.36	6.82
05/04/22	2:01:00 PM	6.80	1.75	0.03	15.26	0.10	23.24	2.45	2.36	6.79
05/04/22	2:02:00 PM	6.80	1.76	0.03	15.26	0.10	23.31	2.56	2.36	6.80
05/04/22	2:03:00 PM	6.80	1.73	0.03	15.33	0.10	23.33	2.52	2.36	6.81
05/04/22	2:04:00 PM	6.79	1.71	0.03	15.45	0.10	23.33	2.46	2.36	6.79
05/04/22	2:05:00 PM	6.80	1.69	0.03	15.35	0.10	23.33	2.61	2.36	6.80
05/04/22	2:06:00 PM	6.80	1.71	0.03	15.28	0.10	23.29	2.56	2.36	6.80
05/04/22	2:07:00 PM	6.80	1.69	0.03	15.33	0.10	23.36	2.40	2.36	6.80
05/04/22	2:08:00 PM	6.79	1.71	0.03	15.33	0.10	23.33	2.44	2.36	6.79
05/04/22	2:09:00 PM	6.78	1.70	0.03	15.31	0.10	23.33	2.32	2.36	6.79
05/04/22	2:10:00 PM	6.80	1.71	0.03	15.31	0.10	23.35	2.74	2.36	6.81
05/04/22	2:11:00 PM	6.79	1.69	0.03	15.57	0.10	23.36	2.67	2.37	6.80
05/04/22	2:12:00 PM	6.79	1.69	0.03	15.45	0.10	23.45	2.70	2.37	6.80
05/04/22	2:13:00 PM	6.79	1.69	0.03	15.38	0.10	23.54	2.74	2.37	6.82
05/04/22	2:14:00 PM	6.79	1.70	0.03	15.55	0.10	23.48	2.72	2.37	6.80
05/04/22	2:15:00 PM	6.79	1.68	0.03	15.40	0.10	23.36	2.37	2.37	6.79
05/04/22	2:16:00 PM	6.79	1.72	0.03	15.55	0.10	23.48	2.61	2.37	6.80
05/04/22	2:17:00 PM	6.79	1.69	0.03	15.47	0.10	23.41	2.37	2.37	6.79
05/04/22	2:18:00 PM	6.79	1.69	0.03	15.48	0.10	23.47	2.49	2.37	6.79
05/04/22	2:19:00 PM	6.79	1.68	0.03	15.60	0.10	23.57	2.57	2.37	6.80
05/04/22	2:20:00 PM	6.79	1.70	0.03	15.64	0.10	23.52	2.96	2.37	6.79
05/04/22	2:21:00 PM	6.79	1.68	0.03	15.54	0.10	23.57	2.66	2.37	6.79
05/04/22	2:22:00 PM	6.78	1.70	0.03	15.67	0.10	23.55	2.67	2.40	6.79
05/04/22	2:23:00 PM	6.78	1.72	0.03	15.54	0.10	23.47	2.49	2.40	6.78
05/04/22	2:24:00 PM	6.78	1.69	0.03	15.76	0.10	23.64	2.56	2.40	6.79
05/04/22	2:25:00 PM	6.79	1.69	0.03	15.66	0.10	23.64	2.72	2.40	6.80
05/04/22	2:26:00 PM	6.79	1.72	0.03	15.78	0.10	23.64	2.65	2.40	6.80
05/04/22	2:27:00 PM	6.80	1.69	0.03	15.83	0.10	23.76	2.69	2.40	6.81
05/04/22	2:28:00 PM	6.79	1.71	0.03	15.84	0.10	23.71	2.65	2.41	6.79
05/04/22	2:29:00 PM	6.79	1.68	0.03	15.66	0.10	23.69	2.37	2.41	6.79
05/04/22	2:30:00 PM	6.79	1.72	0.03	15.81	0.10	23.79	2.49	2.41	6.80
05/04/22	2:31:00 PM	6.79	1.69	0.03	15.74	0.10	23.72	2.62	2.41	6.80
05/04/22	2:32:00 PM	6.79	1.68	0.03	15.83	0.10	23.84	2.59	2.41	6.81
05/04/22	2:33:00 PM	6.80	1.71	0.03	15.74	0.10	23.79	2.69	2.42	6.80
05/04/22	2:34:00 PM	6.79	1.68	0.03	15.83	0.10	23.79	2.46	2.42	6.79
05/04/22	2:35:00 PM	6.77	1.70	0.03	15.74	0.10	23.72	2.56	2.42	6.78
05/04/22	2:36:00 PM	6.78	1.70	0.03	15.79	0.10	23.79	2.70	2.42	6.79
05/04/22	2:37:00 PM	6.79	1.68	0.03	15.90	0.10	23.79	2.54	2.41	6.78
05/04/22	2:38:00 PM	6.78	1.72	0.03	15.88	0.10	23.84	2.70	2.41	6.78
05/04/22	2:39:00 PM	6.78	1.69	0.03	15.93	0.10	23.79	2.57	2.41	6.79
05/04/22	2:40:00 PM	6.78	1.67	0.03	15.90	0.10	23.71	2.65	2.42	6.77
05/04/22	2:41:00 PM	6.78	1.69	0.03	15.95	0.10	23.83	2.59	2.42	6.79
05/04/22	2:42:00 PM	6.79	1.70	0.03	15.90	0.10	23.79	2.61	2.42	6.78
05/04/22	2:43:00 PM	6.78	1.68	0.03	15.90	0.10	23.84	2.45	2.45	6.78
05/04/22	2:44:00 PM	6.78	1.67	0.03	15.95	0.10	23.96	2.51	2.45	6.80
05/04/22	2:45:00 PM	6.78	1.67	0.03	15.93	0.10	23.96	2.92	2.45	6.79
05/04/22	2:46:00 PM	6.78	1.68	0.03	16.05	0.10	23.88	2.79	2.46	6.78
05/04/22	2:47:00 PM	6.78	1.69	0.03	16.02	0.10	23.95	2.75	2.46	6.79
05/04/22	2:48:00 PM	6.78	1.69	0.03	16.03	0.10	23.96	2.40	2.46	6.79
05/04/22	2:49:00 PM	6.78	1.67	0.03	15.98	0.10	24.00	2.51	2.46	6.79
05/04/22	2:50:00 PM	6.78	1.69	0.03	16.21	0.10	23.84	2.65	2.46	6.77
05/04/22	2:51:00 PM	6.78	1.68	0.03	16.03	0.10	24.08	2.59	2.46	6.79
05/04/22	2:52:00 PM	6.78	1.69	0.03	16.07	0.10	24.10	2.42	2.46	6.80
05/04/22	2:53:00 PM	6.79	1.68	0.03	16.14	0.10	24.10	2.41	2.46	6.80
05/04/22	2:54:00 PM	6.78	1.69	0.03	16.19	0.10	24.15	2.74	2.46	6.79
05/04/22	2:55:00 PM	6.78	1.70	0.03	16.15	0.10	24.12	2.40	2.46	6.78
05/04/22	2:56:00 PM	6.78	1.69	0.03	16.22	0.10	24.12	2.45	2.46	6.78
05/04/22	2:57:00 PM	6.79	1.70	0.03	16.29	0.10	24.26	2.70	2.47	6.80
05/04/22	2:58:00 PM	6.78	1.68	0.03	16.33	0.10	24.19	2.49	2.49	6.78
05/04/22	2:59:00 PM	6.77	1.69	0.03	21.01	0.09	1.17	2.74	2.49	6.76
05/04/22	3:00:00 PM	6.76	1.70	0.03	21.03	0.10	0.12	2.70	2.49	6.76
05/04/22	3:01:00 PM	3.19	1.11	0.03	0.00	0.09	0.14	2.76	2.49	1.73
05/04/22	3:02:00 PM	0.00	1.24	0.03	14.66	0.09	0.15	2.94	2.49	5.00

Woodville DWS May 5, 2022 Test # 36 - Well 2 - Train #1 & #2

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/05/22	7:52:00 AM	0.00	7.94	0.05	0.00	0.02	40.56	3.00	2.17	1.04
05/05/22	7:53:00 AM	4.48	7.65	0.05	0.00	0.04	100.44	3.15	2.17	4.39
05/05/22	7:54:00 AM	4.52	7.62	0.05	0.00	0.07	108.47	3.81	2.17	4.49
05/05/22	7:55:00 AM	5.29	7.52	0.20	8.03	0.03	15.43	2.84	2.17	5.25
05/05/22	7:56:00 AM	4.93	7.54	0.27	7.14	0.04	14.63	2.61	2.17	4.91
05/05/22	7:57:00 AM	4.98	7.53	0.06	7.23	0.03	14.75	2.67	2.17	4.97
05/05/22	7:58:00 AM	5.00	7.52	0.04	7.35	0.03	14.80	2.39	2.17	4.99
05/05/22	7:59:00 AM	5.00	7.52	0.04	7.33	0.03	14.75	2.24	2.17	4.99
05/05/22	8:00:00 AM	5.00	7.51	0.03	7.40	0.03	14.93	2.07	2.17	4.99
05/05/22	8:01:00 AM	5.01	7.51	0.03	7.26	0.03	14.68	1.99	2.17	4.99
05/05/22	8:02:00 AM	4.99	7.51	0.03	7.31	0.03	14.75	2.30	2.17	4.98
05/05/22	8:03:00 AM	5.00	7.51	0.03	7.38	0.03	14.83	2.09	2.17	4.98
05/05/22	8:04:00 AM	4.97	7.51	0.03	7.26	0.03	14.59	2.15	2.17	4.95
05/05/22	8:05:00 AM	5.00	7.50	0.03	7.36	0.03	14.87	1.92	2.17	4.99
05/05/22	8:06:00 AM	5.00	7.50	0.03	7.57	0.03	14.88	2.35	2.17	4.99
05/05/22	8:07:00 AM	4.99	7.50	0.03	7.38	0.03	14.85	2.16	2.17	4.98
05/05/22	8:08:00 AM	5.00	7.50	0.03	7.33	0.03	14.75	1.94	2.17	4.97
05/05/22	8:09:00 AM	5.01	7.50	0.03	7.38	0.03	14.83	2.24	2.17	4.98
05/05/22	8:10:00 AM	5.01	7.49	0.03	7.40	0.03	14.81	2.11	2.17	4.98
05/05/22	8:11:00 AM	5.01	7.49	0.03	7.36	0.03	14.87	2.21	2.17	4.98
05/05/22	8:12:00 AM	5.00	7.49	0.03	7.40	0.03	14.78	2.32	2.17	4.97
05/05/22	8:13:00 AM	5.01	7.49	0.03	7.31	0.03	14.71	2.24	2.17	4.98
05/05/22	8:14:00 AM	5.00	7.49	0.03	7.40	0.03	14.81	2.04	2.17	4.98
05/05/22	8:15:00 AM	5.00	7.49	0.03	7.36	0.03	14.76	2.46	2.17	4.97
05/05/22	8:16:00 AM	4.99	7.48	0.03	7.38	0.03	14.87	2.16	2.17	4.98
05/05/22	8:17:00 AM	5.00	7.48	0.03	7.45	0.03	14.85	2.67	2.17	4.97
05/05/22	8:18:00 AM	4.99	7.48	0.03	7.42	0.03	14.80	2.41	2.17	4.97
05/05/22	8:19:00 AM	4.99	7.48	0.03	7.33	0.03	14.78	2.45	2.17	4.96
05/05/22	8:20:00 AM	5.00	7.47	0.03	7.33	0.03	14.83	2.24	2.17	4.98
05/05/22	8:21:00 AM	5.00	7.47	0.03	7.36	0.03	14.80	1.97	2.17	4.98
05/05/22	8:22:00 AM	4.98	7.48	0.03	7.31	0.03	14.71	2.39	2.17	4.96
05/05/22	8:23:00 AM	4.99	7.47	0.03	7.38	0.03	14.87	2.57	2.17	4.98
05/05/22	8:24:00 AM	4.99	7.47	0.03	7.43	0.03	14.81	2.31	2.17	4.97
05/05/22	8:25:00 AM	4.99	7.45	0.03	7.36	0.03	14.90	2.10	2.17	4.98
05/05/22	8:26:00 AM	5.00	7.46	0.03	7.38	0.03	14.81	2.16	2.17	4.97
05/05/22	8:27:00 AM	5.02	7.46	0.03	7.40	0.03	14.99	2.07	2.17	5.00
05/05/22	8:28:00 AM	4.99	7.46	0.03	7.50	0.03	14.87	2.37	2.17	4.97
05/05/22	8:29:00 AM	5.01	7.46	0.03	7.36	0.02	14.88	2.69	2.17	4.99
05/05/22	8:30:00 AM	5.00	7.46	0.03	7.33	0.02	14.81	2.72	2.17	4.98
05/05/22	8:31:00 AM	4.99	7.46	0.03	7.36	0.02	14.78	2.47	2.17	4.97
05/05/22	8:32:00 AM	5.00	7.46	0.03	7.43	0.02	14.93	1.92	2.17	4.98
05/05/22	8:33:00 AM	4.98	7.45	0.03	7.31	0.02	14.69	2.20	2.17	4.96
05/05/22	8:34:00 AM	4.99	7.45	0.03	7.40	0.02	14.81	2.19	2.17	4.97
05/05/22	8:35:00 AM	5.00	7.44	0.03	7.35	0.02	14.78	2.04	2.17	4.97
05/05/22	8:36:00 AM	5.01	7.44	0.03	7.36	0.02	14.87	2.05	2.17	4.99
05/05/22	8:37:00 AM	5.00	7.44	0.03	7.35	0.02	14.81	2.10	2.17	4.98
05/05/22	8:38:00 AM	4.99	7.45	0.03	7.42	0.02	14.83	2.27	2.17	4.96
05/05/22	8:39:00 AM	5.00	7.44	0.03	7.43	0.02	14.87	2.24	2.17	4.97
05/05/22	8:40:00 AM	4.99	7.44	0.03	7.42	0.02	14.87	1.99	2.17	4.97
05/05/22	8:41:00 AM	5.00	7.44	0.03	7.38	0.02	14.80	2.22	2.17	4.97
05/05/22	8:42:00 AM	5.00	7.44	0.03	7.33	0.02	14.80	2.46	2.17	4.96
05/05/22	8:43:00 AM	4.99	7.44	0.03	7.50	0.02	14.90	2.07	2.17	4.96
05/05/22	8:44:00 AM	4.99	7.43	0.03	7.45	0.02	14.87	2.09	2.17	4.97
05/05/22	8:45:00 AM	5.00	7.43	0.03	7.36	0.02	14.83	1.99	2.17	4.97
05/05/22	8:46:00 AM	4.99	7.43	0.03	7.43	0.02	14.81	2.34	2.17	4.97
05/05/22	8:47:00 AM	5.00	7.43	0.03	7.38	0.02	14.83	2.30	2.17	4.97
05/05/22	8:48:00 AM	4.98	7.43	0.03	7.47	0.02	14.87	1.95	2.17	4.96
05/05/22	8:49:00 AM	4.98	7.44	0.03	7.47	0.02	14.83	1.86	2.17	4.96
05/05/22	8:50:00 AM	4.99	7.44	0.03	7.38	0.02	14.83	2.04	2.17	4.97
05/05/22	8:51:00 AM	4.99	7.44	0.03	7.47	0.02	14.85	2.11	2.17	4.98
05/05/22	8:52:00 AM	5.00	7.44	0.03	7.43	0.02	14.90	1.95	2.17	4.98
05/05/22	8:53:00 AM	4.99	7.44	0.03	7.50	0.02	14.95	2.02	2.17	4.98
05/05/22	8:54:00 AM	4.99	7.43	0.03	7.42	0.02	14.83	2.10	2.17	4.97
05/05/22	8:55:00 AM	5.00	7.43	0.03	7.47	0.02	14.92	1.91	2.16	4.98
05/05/22	8:56:00 AM	4.98	7.43	0.03	7.50	0.02	14.87	1.78	2.16	4.96
05/05/22	8:57:00 AM	4.98	7.43	0.03	7.47	0.02	14.87	2.27	2.16	4.96
05/05/22	8:58:00 AM	4.99	7.43	0.03	7.48	0.02	14.93	2.18	2.16	4.98
05/05/22	8:59:00 AM	5.50	7.36	0.03	9.39	0.02	16.94	2.05	2.16	5.49
05/05/22	9:00:00 AM	5.49	7.35	0.03	9.37	0.03	16.89	2.22	2.16	5.48
05/05/22	9:01:00 AM	5.50	7.34	0.03	9.29	0.02	16.81	2.44	2.16	5.48
05/05/22	9:02:00 AM	5.50	7.34	0.03	9.37	0.02	16.96	2.27	2.16	5.48

Woodville DWS May 5, 2022 Test # 37 - Well 2 - Train #1 & #2

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/05/22	8:53:00 AM	4.99	7.44	0.03	7.50	0.02	14.95	2.02	2.17	4.98
05/05/22	8:54:00 AM	4.99	7.43	0.03	7.42	0.02	14.83	2.10	2.17	4.97
05/05/22	8:55:00 AM	5.00	7.43	0.03	7.47	0.02	14.92	1.91	2.16	4.98
05/05/22	8:56:00 AM	4.98	7.43	0.03	7.50	0.02	14.87	1.78	2.16	4.96
05/05/22	8:57:00 AM	4.98	7.43	0.03	7.47	0.02	14.87	2.27	2.16	4.96
05/05/22	8:58:00 AM	4.99	7.43	0.03	7.48	0.02	14.93	2.18	2.16	4.98
05/05/22	8:59:00 AM	5.50	7.36	0.03	9.39	0.02	16.94	2.05	2.16	5.49
05/05/22	9:00:00 AM	5.49	7.35	0.03	9.37	0.03	16.89	2.22	2.16	5.48
05/05/22	9:01:00 AM	5.50	7.34	0.03	9.29	0.02	16.81	2.44	2.16	5.48
05/05/22	9:02:00 AM	5.50	7.34	0.03	9.37	0.02	16.96	2.27	2.16	5.48
05/05/22	9:03:00 AM	5.50	7.33	0.03	9.24	0.02	16.86	2.11	2.16	5.47
05/05/22	9:04:00 AM	5.52	7.33	0.03	9.32	0.02	16.93	2.19	2.16	5.49
05/05/22	9:05:00 AM	5.51	7.33	0.03	9.51	0.02	16.96	2.19	2.16	5.49
05/05/22	9:06:00 AM	5.51	7.33	0.03	9.34	0.02	16.94	2.22	2.16	5.49
05/05/22	9:07:00 AM	5.49	7.33	0.03	9.34	0.02	16.89	2.15	2.16	5.47
05/05/22	9:08:00 AM	5.50	7.32	0.03	9.32	0.02	16.94	2.11	2.16	5.48
05/05/22	9:09:00 AM	5.51	7.32	0.03	9.36	0.02	16.91	2.16	2.16	5.48
05/05/22	9:10:00 AM	5.51	7.32	0.03	9.37	0.02	16.91	2.62	2.16	5.48
05/05/22	9:11:00 AM	5.50	7.32	0.03	9.32	0.02	16.89	2.40	2.16	5.49
05/05/22	9:12:00 AM	5.52	7.32	0.03	9.32	0.02	16.94	2.24	2.16	5.49
05/05/22	9:13:00 AM	5.49	7.32	0.03	9.41	0.02	16.93	2.32	2.16	5.48
05/05/22	9:14:00 AM	5.49	7.32	0.03	9.37	0.02	16.86	2.25	2.16	5.46
05/05/22	9:15:00 AM	5.49	7.31	0.03	9.30	0.02	16.89	2.56	2.16	5.48
05/05/22	9:16:00 AM	5.51	7.31	0.03	9.29	0.02	16.98	2.44	2.16	5.50
05/05/22	9:17:00 AM	5.50	7.31	0.03	9.34	0.02	17.03	2.07	2.16	5.49
05/05/22	9:18:00 AM	5.49	7.31	0.03	9.36	0.02	16.93	2.35	2.16	5.47
05/05/22	9:19:00 AM	5.51	7.31	0.03	9.27	0.02	16.82	2.70	2.16	5.47
05/05/22	9:20:00 AM	5.50	7.31	0.03	9.41	0.02	16.98	2.16	2.16	5.48
05/05/22	9:21:00 AM	5.49	7.31	0.03	9.37	0.02	16.89	2.19	2.16	5.47
05/05/22	9:22:00 AM	5.51	7.31	0.03	9.37	0.02	16.94	2.65	2.16	5.48
05/05/22	9:23:00 AM	5.50	7.30	0.03	9.30	0.02	16.98	2.32	2.16	5.48
05/05/22	9:24:00 AM	5.50	7.31	0.03	9.37	0.02	16.98	2.59	2.16	5.48
05/05/22	9:25:00 AM	5.50	7.31	0.03	9.36	0.02	16.91	2.37	2.16	5.47
05/05/22	9:26:00 AM	5.46	7.31	0.03	9.41	0.02	16.79	2.49	2.16	5.44
05/05/22	9:27:00 AM	5.50	7.30	0.03	9.42	0.02	17.06	2.39	2.16	5.49
05/05/22	9:28:00 AM	5.49	7.30	0.03	9.41	0.02	16.98	2.29	2.16	5.47
05/05/22	9:29:00 AM	5.51	7.30	0.03	9.37	0.02	16.98	2.57	2.16	5.49
05/05/22	9:30:00 AM	5.50	7.30	0.03	9.36	0.02	17.01	2.44	2.16	5.49
05/05/22	9:31:00 AM	5.48	7.30	0.03	9.36	0.02	16.94	2.40	2.16	5.46
05/05/22	9:32:00 AM	5.49	7.30	0.03	9.37	0.02	16.94	2.67	2.16	5.48
05/05/22	9:33:00 AM	5.49	7.30	0.03	9.36	0.02	16.91	2.55	2.16	5.47
05/05/22	9:34:00 AM	5.50	7.30	0.03	9.39	0.02	16.98	2.40	2.16	5.48
05/05/22	9:35:00 AM	5.47	7.30	0.03	9.46	0.02	17.03	2.49	2.16	5.47
05/05/22	9:36:00 AM	5.49	7.29	0.03	9.32	0.02	16.86	2.30	2.16	5.46
05/05/22	9:37:00 AM	5.49	7.30	0.03	9.36	0.02	16.89	2.49	2.17	5.46
05/05/22	9:38:00 AM	5.51	7.29	0.03	9.37	0.02	16.98	2.59	2.17	5.48
05/05/22	9:39:00 AM	5.51	7.29	0.03	9.39	0.02	17.06	2.35	2.17	5.49
05/05/22	9:40:00 AM	5.50	7.29	0.03	9.34	0.02	17.01	2.19	2.17	5.48
05/05/22	9:41:00 AM	5.49	7.29	0.03	9.36	0.02	16.94	2.21	2.17	5.46
05/05/22	9:42:00 AM	5.49	7.29	0.03	9.36	0.02	16.91	2.16	2.17	5.47
05/05/22	9:43:00 AM	5.48	7.29	0.03	9.30	0.02	16.86	2.46	2.17	5.46
05/05/22	9:44:00 AM	5.50	7.29	0.03	9.46	0.02	17.01	2.46	2.17	5.48
05/05/22	9:45:00 AM	5.51	7.29	0.03	9.36	0.02	16.99	2.46	2.17	5.48
05/05/22	9:46:00 AM	5.50	7.29	0.03	9.37	0.02	16.94	2.11	2.17	5.47
05/05/22	9:47:00 AM	5.51	7.29	0.03	9.41	0.02	16.98	2.40	2.19	5.48
05/05/22	9:48:00 AM	5.50	7.29	0.03	9.34	0.02	17.01	2.57	2.19	5.48
05/05/22	9:49:00 AM	5.49	7.29	0.03	9.42	0.02	16.99	2.49	2.19	5.48
05/05/22	9:50:00 AM	5.51	7.29	0.03	9.48	0.02	17.10	2.42	2.19	5.49
05/05/22	9:51:00 AM	5.50	7.29	0.03	9.34	0.02	17.03	2.09	2.19	5.48
05/05/22	9:52:00 AM	5.50	7.29	0.03	9.39	0.02	16.96	2.35	2.19	5.48
05/05/22	9:53:00 AM	5.50	7.29	0.03	9.37	0.02	17.01	2.49	2.19	5.48
05/05/22	9:54:00 AM	5.50	7.28	0.03	9.37	0.02	16.98	2.49	2.19	5.48
05/05/22	9:55:00 AM	5.51	7.28	0.03	9.39	0.02	17.10	2.36	2.19	5.49
05/05/22	9:56:00 AM	5.49	7.28	0.03	9.41	0.02	16.94	2.44	2.19	5.47
05/05/22	9:57:00 AM	5.51	7.28	0.03	9.51	0.02	16.91	2.40	2.20	5.47
05/05/22	9:58:00 AM	5.49	7.28	0.03	9.34	0.02	16.98	2.85	2.20	5.47
05/05/22	9:59:00 AM	5.98	7.21	0.03	11.30	0.02	18.87	2.14	2.19	5.94
05/05/22	10:00:00 AM	6.01	7.20	0.03	11.42	0.02	19.14	2.37	2.19	5.98
05/05/22	10:01:00 AM	6.02	7.19	0.03	11.19	0.02	19.11	2.38	2.19	5.99
05/05/22	10:02:00 AM	6.02	7.19	0.03	11.36	0.02	19.09	2.25	2.19	5.99
05/05/22	10:03:00 AM	6.01	7.18	0.03	11.38	0.02	19.09	2.09	2.19	5.99

Woodville DWS May 5, 2022 Test # 38 - Well 2 - Train #1 & #2

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/05/22	9:54:00 AM	5.50	7.28	0.03	9.37	0.02	16.98	2.49	2.19	5.48
05/05/22	9:55:00 AM	5.51	7.28	0.03	9.39	0.02	17.10	2.36	2.19	5.49
05/05/22	9:56:00 AM	5.49	7.28	0.03	9.41	0.02	16.94	2.44	2.19	5.47
05/05/22	9:57:00 AM	5.51	7.28	0.03	9.51	0.02	16.91	2.40	2.20	5.47
05/05/22	9:58:00 AM	5.49	7.28	0.03	9.34	0.02	16.98	2.85	2.20	5.47
05/05/22	9:59:00 AM	5.98	7.21	0.03	11.30	0.02	18.87	2.14	2.19	5.94
05/05/22	10:00:00 AM	6.01	7.20	0.03	11.42	0.02	19.14	2.37	2.19	5.98
05/05/22	10:01:00 AM	6.02	7.19	0.03	11.19	0.02	19.11	2.38	2.19	5.99
05/05/22	10:02:00 AM	6.02	7.19	0.03	11.36	0.02	19.09	2.25	2.19	5.99
05/05/22	10:03:00 AM	6.01	7.18	0.03	11.38	0.02	19.09	2.09	2.19	5.99
05/05/22	10:04:00 AM	6.00	7.18	0.03	11.33	0.02	19.11	2.41	2.19	5.98
05/05/22	10:05:00 AM	6.01	7.18	0.03	11.35	0.02	19.02	2.32	2.19	5.97
05/05/22	10:06:00 AM	6.01	7.18	0.03	11.43	0.02	19.14	2.19	2.20	5.98
05/05/22	10:07:00 AM	6.02	7.18	0.03	11.48	0.02	19.21	2.46	2.20	6.00
05/05/22	10:08:00 AM	6.05	7.17	0.03	11.33	0.02	19.33	2.22	2.20	6.02
05/05/22	10:09:00 AM	6.02	7.17	0.03	11.36	0.02	19.17	2.59	2.20	5.99
05/05/22	10:10:00 AM	6.01	7.17	0.03	11.38	0.02	19.07	2.45	2.20	5.99
05/05/22	10:11:00 AM	6.02	7.16	0.03	11.42	0.02	19.24	2.29	2.20	6.00
05/05/22	10:12:00 AM	6.00	7.16	0.03	11.43	0.02	19.23	2.32	2.20	6.00
05/05/22	10:13:00 AM	6.02	7.16	0.03	11.45	0.02	19.17	2.15	2.20	5.98
05/05/22	10:14:00 AM	6.03	7.16	0.03	11.35	0.02	19.21	2.89	2.20	6.00
05/05/22	10:15:00 AM	6.02	7.16	0.03	11.33	0.02	19.26	2.24	2.20	5.99
05/05/22	10:16:00 AM	6.01	7.16	0.03	11.36	0.02	19.11	1.94	2.20	5.98
05/05/22	10:17:00 AM	6.03	7.16	0.03	11.35	0.02	19.11	2.27	2.20	5.99
05/05/22	10:18:00 AM	6.01	7.16	0.03	11.30	0.02	18.99	2.56	2.20	5.97
05/05/22	10:19:00 AM	6.02	7.16	0.03	11.40	0.02	19.26	2.49	2.20	6.00
05/05/22	10:20:00 AM	6.00	7.16	0.03	11.40	0.02	19.11	2.52	2.20	5.97
05/05/22	10:21:00 AM	6.01	7.16	0.03	11.42	0.02	19.14	2.21	2.20	5.99
05/05/22	10:22:00 AM	6.01	7.15	0.03	11.42	0.02	19.05	2.70	2.20	5.98
05/05/22	10:23:00 AM	6.02	7.15	0.03	11.26	0.02	19.17	2.70	2.20	5.99
05/05/22	10:24:00 AM	6.03	7.15	0.03	11.33	0.02	19.09	2.51	2.20	5.98
05/05/22	10:25:00 AM	6.01	7.15	0.03	11.48	0.02	19.28	2.69	2.20	6.00
05/05/22	10:26:00 AM	6.02	7.15	0.03	11.38	0.02	19.14	2.49	2.20	5.98
05/05/22	10:27:00 AM	6.02	7.15	0.03	11.26	0.02	19.14	2.45	2.20	5.99
05/05/22	10:28:00 AM	6.02	7.15	0.03	11.42	0.02	19.17	2.61	2.20	5.98
05/05/22	10:29:00 AM	6.00	7.15	0.03	11.42	0.02	19.02	2.30	2.21	5.97
05/05/22	10:30:00 AM	6.02	7.15	0.03	11.36	0.02	19.11	2.27	2.21	5.97
05/05/22	10:31:00 AM	6.01	7.15	0.03	11.33	0.02	19.11	2.25	2.21	5.98
05/05/22	10:32:00 AM	6.01	7.15	0.03	11.33	0.02	19.11	2.34	2.21	5.98
05/05/22	10:33:00 AM	6.03	7.15	0.03	11.33	0.02	19.21	2.32	2.21	6.00
05/05/22	10:34:00 AM	6.02	7.14	0.03	11.31	0.02	19.21	2.22	2.21	5.99
05/05/22	10:35:00 AM	6.01	7.15	0.03	11.43	0.02	19.17	2.57	2.21	5.98
05/05/22	10:36:00 AM	6.02	7.14	0.03	11.38	0.02	19.33	2.30	2.21	6.00
05/05/22	10:37:00 AM	6.01	7.14	0.03	11.35	0.02	19.17	2.24	2.22	5.98
05/05/22	10:38:00 AM	6.02	7.14	0.03	11.31	0.02	19.17	2.57	2.22	6.00
05/05/22	10:39:00 AM	6.02	7.14	0.03	11.40	0.02	19.21	2.49	2.22	6.00
05/05/22	10:40:00 AM	6.00	7.14	0.03	11.38	0.02	19.09	2.36	2.22	5.98
05/05/22	10:41:00 AM	6.01	7.14	0.03	11.38	0.02	19.24	2.40	2.22	5.99
05/05/22	10:42:00 AM	5.99	7.14	0.03	11.38	0.02	19.11	2.10	2.22	5.98
05/05/22	10:43:00 AM	6.00	7.14	0.03	11.42	0.02	19.21	2.22	2.21	5.98
05/05/22	10:44:00 AM	6.00	7.14	0.03	11.33	0.02	19.17	2.29	2.21	5.98
05/05/22	10:45:00 AM	6.02	7.14	0.03	11.38	0.02	19.26	2.34	2.21	6.00
05/05/22	10:46:00 AM	6.01	7.14	0.03	11.35	0.02	19.21	2.46	2.21	5.99
05/05/22	10:47:00 AM	6.01	7.14	0.03	11.43	0.02	19.17	2.34	2.21	5.98
05/05/22	10:48:00 AM	6.01	7.13	0.03	11.36	0.02	19.09	2.22	2.21	5.97
05/05/22	10:49:00 AM	6.01	7.13	0.03	11.35	0.02	19.17	2.56	2.22	5.98
05/05/22	10:50:00 AM	5.98	7.14	0.03	11.36	0.02	19.16	2.32	2.22	5.97
05/05/22	10:51:00 AM	6.01	7.13	0.03	11.42	0.02	19.17	2.50	2.22	5.99
05/05/22	10:52:00 AM	6.01	7.12	0.03	11.35	0.02	19.21	2.14	2.22	5.97
05/05/22	10:53:00 AM	5.98	7.13	0.03	11.38	0.02	19.09	2.17	2.22	5.96
05/05/22	10:54:00 AM	6.01	7.13	0.03	11.24	0.02	19.11	2.46	2.22	5.98
05/05/22	10:55:00 AM	6.00	7.13	0.03	11.42	0.02	19.11	2.39	2.22	5.97
05/05/22	10:56:00 AM	6.02	7.13	0.03	11.35	0.02	19.23	2.65	2.22	5.99
05/05/22	10:57:00 AM	6.01	7.13	0.03	11.31	0.02	19.14	2.44	2.22	5.98
05/05/22	10:58:00 AM	6.01	7.13	0.03	11.36	0.02	19.17	2.37	2.22	5.99
05/05/22	10:59:00 AM	6.01	7.13	0.03	11.31	0.02	19.11	2.32	2.22	5.98
05/05/22	11:00:00 AM	6.48	7.06	0.03	13.15	0.02	21.17	2.50	2.22	6.46
05/05/22	11:01:00 AM	6.49	7.05	0.03	13.32	0.02	21.29	2.37	2.22	6.46
05/05/22	11:02:00 AM	6.51	7.04	0.03	13.34	0.02	21.32	2.62	2.22	6.47
05/05/22	11:03:00 AM	6.50	7.03	0.03	13.29	0.02	21.32	2.75	2.22	6.48
05/05/22	11:04:00 AM	6.52	7.03	0.03	13.22	0.02	21.41	2.44	2.22	6.48

Woodville DWS May 5, 2022 Test # 39 - Well 2 - Train #1 & #2

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/05/22	10:55:00 AM	6.00	7.13	0.03	11.42	0.02	19.11	2.39	2.22	5.97
05/05/22	10:56:00 AM	6.02	7.13	0.03	11.35	0.02	19.23	2.65	2.22	5.99
05/05/22	10:57:00 AM	6.01	7.13	0.03	11.31	0.02	19.14	2.44	2.22	5.98
05/05/22	10:58:00 AM	6.01	7.13	0.03	11.36	0.02	19.17	2.37	2.22	5.99
05/05/22	10:59:00 AM	6.01	7.13	0.03	11.31	0.02	19.11	2.32	2.22	5.98
05/05/22	11:00:00 AM	6.48	7.06	0.03	13.15	0.02	21.17	2.50	2.22	6.46
05/05/22	11:01:00 AM	6.49	7.05	0.03	13.32	0.02	21.29	2.37	2.22	6.46
05/05/22	11:02:00 AM	6.51	7.04	0.03	13.34	0.02	21.32	2.62	2.22	6.47
05/05/22	11:03:00 AM	6.50	7.03	0.03	13.29	0.02	21.32	2.75	2.22	6.48
05/05/22	11:04:00 AM	6.52	7.03	0.03	13.22	0.02	21.41	2.44	2.22	6.48
05/05/22	11:05:00 AM	6.51	7.03	0.03	13.18	0.02	21.36	2.62	2.22	6.49
05/05/22	11:06:00 AM	6.50	7.03	0.03	13.13	0.02	21.20	2.81	2.22	6.47
05/05/22	11:07:00 AM	6.50	7.02	0.03	13.17	0.02	21.29	2.57	2.22	6.47
05/05/22	11:08:00 AM	6.51	7.02	0.03	13.34	0.02	21.36	2.65	2.22	6.49
05/05/22	11:09:00 AM	6.50	7.01	0.03	13.25	0.02	21.25	2.36	2.21	6.47
05/05/22	11:10:00 AM	6.50	7.01	0.03	13.17	0.02	21.29	2.61	2.21	6.47
05/05/22	11:11:00 AM	6.52	7.01	0.03	13.20	0.02	21.36	2.42	2.21	6.49
05/05/22	11:12:00 AM	6.49	7.01	0.03	13.32	0.02	21.37	2.09	2.21	6.48
05/05/22	11:13:00 AM	6.50	7.01	0.03	13.34	0.02	21.36	2.02	2.21	6.48
05/05/22	11:14:00 AM	6.51	7.01	0.03	13.18	0.02	21.37	2.10	2.21	6.49
05/05/22	11:15:00 AM	6.50	7.01	0.03	13.39	0.02	21.34	2.42	2.21	6.48
05/05/22	11:16:00 AM	6.50	7.01	0.03	13.25	0.02	21.29	2.09	2.22	6.47
05/05/22	11:17:00 AM	6.49	7.01	0.03	13.30	0.02	21.32	2.67	2.22	6.47
05/05/22	11:18:00 AM	6.50	7.01	0.03	13.25	0.02	21.29	2.45	2.22	6.47
05/05/22	11:19:00 AM	6.49	7.00	0.03	13.27	0.02	21.32	2.57	2.24	6.48
05/05/22	11:20:00 AM	6.51	7.00	0.03	13.25	0.02	21.37	2.33	2.25	6.49
05/05/22	11:21:00 AM	6.50	7.00	0.03	13.29	0.02	21.39	2.57	2.25	6.48
05/05/22	11:22:00 AM	6.50	7.00	0.03	13.29	0.02	21.34	2.56	2.25	6.48
05/05/22	11:23:00 AM	6.51	7.00	0.03	13.22	0.02	21.36	2.52	2.25	6.48
05/05/22	11:24:00 AM	6.50	7.00	0.03	13.34	0.02	21.32	2.61	2.25	6.46
05/05/22	11:25:00 AM	6.50	7.00	0.03	13.27	0.02	21.29	2.70	2.25	6.48
05/05/22	11:26:00 AM	6.52	6.99	0.03	13.27	0.02	21.32	2.51	2.25	6.48
05/05/22	11:27:00 AM	6.51	6.99	0.03	13.20	0.02	21.30	2.57	2.25	6.48
05/05/22	11:28:00 AM	6.50	6.99	0.03	13.27	0.02	21.32	2.73	2.25	6.47
05/05/22	11:29:00 AM	6.51	6.99	0.03	13.18	0.02	21.32	2.72	2.25	6.48
05/05/22	11:30:00 AM	6.50	6.99	0.03	13.22	0.02	21.39	3.00	2.25	6.48
05/05/22	11:31:00 AM	6.51	6.99	0.03	13.32	0.02	21.34	2.55	2.24	6.48
05/05/22	11:32:00 AM	6.51	6.99	0.03	13.27	0.02	21.44	2.40	2.24	6.48
05/05/22	11:33:00 AM	6.51	6.99	0.03	13.37	0.02	21.44	2.39	2.24	6.49
05/05/22	11:34:00 AM	6.51	6.99	0.03	13.22	0.02	21.34	2.51	2.24	6.48
05/05/22	11:35:00 AM	6.50	6.99	0.03	13.32	0.02	21.29	2.57	2.22	6.47
05/05/22	11:36:00 AM	6.50	6.99	0.03	13.30	0.02	21.29	2.67	2.22	6.46
05/05/22	11:37:00 AM	6.50	6.98	0.03	13.27	0.02	21.22	2.62	2.22	6.46
05/05/22	11:38:00 AM	6.50	6.98	0.03	13.37	0.02	21.36	2.49	2.22	6.48
05/05/22	11:39:00 AM	6.50	6.98	0.03	13.32	0.02	21.34	2.30	2.22	6.47
05/05/22	11:40:00 AM	6.50	6.98	0.03	13.32	0.02	21.25	2.59	2.24	6.46
05/05/22	11:41:00 AM	6.50	6.98	0.03	13.22	0.02	21.15	2.15	2.25	6.46
05/05/22	11:42:00 AM	6.51	6.98	0.03	13.25	0.02	21.32	2.46	2.25	6.47
05/05/22	11:43:00 AM	6.50	6.98	0.03	13.29	0.02	21.34	2.37	2.25	6.48
05/05/22	11:44:00 AM	6.50	6.98	0.03	13.36	0.02	21.32	2.24	2.26	6.48
05/05/22	11:45:00 AM	6.51	6.97	0.03	13.27	0.02	21.34	2.65	2.26	6.48
05/05/22	11:46:00 AM	6.49	6.98	0.03	13.36	0.02	21.29	2.50	2.27	6.46
05/05/22	11:47:00 AM	6.50	6.98	0.03	13.30	0.02	21.29	2.80	2.27	6.47
05/05/22	11:48:00 AM	6.50	6.97	0.03	13.34	0.02	21.34	2.62	2.27	6.48
05/05/22	11:49:00 AM	6.49	6.98	0.03	13.29	0.02	21.22	2.70	2.26	6.46
05/05/22	11:50:00 AM	6.51	6.97	0.03	13.22	0.02	21.25	2.57	2.26	6.47
05/05/22	11:51:00 AM	6.50	6.97	0.03	13.24	0.02	21.29	2.72	2.26	6.48
05/05/22	11:52:00 AM	6.50	6.97	0.03	13.27	0.02	21.29	2.49	2.26	6.46
05/05/22	11:53:00 AM	6.49	6.97	0.03	13.25	0.02	21.20	2.44	2.26	6.46
05/05/22	11:54:00 AM	6.51	6.97	0.03	13.34	0.02	21.39	2.60	2.25	6.48
05/05/22	11:55:00 AM	6.50	6.97	0.03	13.27	0.02	21.36	2.72	2.25	6.47
05/05/22	11:56:00 AM	6.51	6.97	0.03	13.32	0.02	21.34	2.57	2.24	6.48
05/05/22	11:57:00 AM	6.50	6.97	0.03	13.29	0.02	21.25	2.52	2.24	6.47
05/05/22	11:58:00 AM	6.49	6.97	0.03	13.27	0.02	21.22	2.57	2.24	6.46
05/05/22	11:59:00 AM	6.50	6.96	0.03	13.36	0.02	21.36	2.40	2.24	6.47
05/05/22	12:00:00 PM	6.50	6.96	0.03	13.29	0.02	21.36	2.50	2.24	6.48
05/05/22	12:01:00 PM	6.76	6.92	0.03	14.57	0.02	22.54	2.50	2.25	6.72
05/05/22	12:02:00 PM	6.80	6.91	0.03	14.51	0.02	22.64	2.57	2.25	6.76
05/05/22	12:03:00 PM	6.79	6.91	0.03	14.64	0.02	22.68	2.48	2.25	6.77
05/05/22	12:04:00 PM	6.80	6.90	0.03	14.57	0.02	22.76	2.49	2.25	6.78
05/05/22	12:05:00 PM	6.80	6.90	0.03	14.61	0.02	22.68	2.57	2.26	6.77

Woodville DWS May 5, 2022 Test # 40 - Well 2 - Train #1 & #2

Date	Time	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/05/22	11:57:00 AM	6.50	6.97	0.03	13.29	0.02	21.25	2.52	2.24	6.47
05/05/22	11:58:00 AM	6.49	6.97	0.03	13.27	0.02	21.22	2.57	2.24	6.46
05/05/22	11:59:00 AM	6.50	6.96	0.03	13.36	0.02	21.36	2.40	2.24	6.47
05/05/22	12:00:00 PM	6.50	6.96	0.03	13.29	0.02	21.36	2.50	2.24	6.48
05/05/22	12:01:00 PM	6.76	6.92	0.03	14.57	0.02	22.54	2.50	2.25	6.72
05/05/22	12:02:00 PM	6.80	6.91	0.03	14.51	0.02	22.64	2.57	2.25	6.76
05/05/22	12:03:00 PM	6.79	6.91	0.03	14.64	0.02	22.68	2.48	2.25	6.77
05/05/22	12:04:00 PM	6.80	6.90	0.03	14.57	0.02	22.76	2.49	2.25	6.78
05/05/22	12:05:00 PM	6.80	6.90	0.03	14.61	0.02	22.68	2.57	2.26	6.77
05/05/22	12:06:00 PM	6.79	6.90	0.03	14.52	0.02	22.51	2.56	2.26	6.75
05/05/22	12:07:00 PM	6.80	6.90	0.03	14.56	0.02	22.63	2.72	2.26	6.76
05/05/22	12:08:00 PM	6.79	6.89	0.03	14.63	0.02	22.66	2.91	2.26	6.77
05/05/22	12:09:00 PM	6.80	6.89	0.03	14.51	0.02	22.69	2.60	2.26	6.77
05/05/22	12:10:00 PM	6.80	6.89	0.03	14.57	0.02	22.63	2.61	2.26	6.78
05/05/22	12:11:00 PM	6.80	6.89	0.03	14.64	0.02	22.66	2.49	2.26	6.77
05/05/22	12:12:00 PM	6.80	6.89	0.03	14.47	0.02	22.78	2.44	2.26	6.78
05/05/22	12:13:00 PM	6.80	6.89	0.03	14.57	0.02	22.59	2.76	2.26	6.77
05/05/22	12:14:00 PM	6.80	6.88	0.03	14.61	0.02	22.66	2.51	2.26	6.76
05/05/22	12:15:00 PM	6.79	6.88	0.03	14.57	0.02	22.66	2.35	2.26	6.77
05/05/22	12:16:00 PM	6.80	6.88	0.03	14.56	0.02	22.78	2.61	2.26	6.79
05/05/22	12:17:00 PM	6.78	6.88	0.03	14.54	0.02	22.54	2.85	2.26	6.75
05/05/22	12:18:00 PM	6.79	6.88	0.03	14.61	0.02	22.73	2.72	2.26	6.78
05/05/22	12:19:00 PM	6.79	6.88	0.03	14.59	0.02	22.63	2.65	2.26	6.76
05/05/22	12:20:00 PM	6.79	6.88	0.03	14.61	0.02	22.59	2.51	2.26	6.76
05/05/22	12:21:00 PM	6.79	6.88	0.03	14.68	0.02	22.66	2.55	2.26	6.76
05/05/22	12:22:00 PM	6.80	6.87	0.03	14.61	0.02	22.66	2.51	2.26	6.76
05/05/22	12:23:00 PM	6.80	6.87	0.03	14.69	0.02	22.68	2.57	2.26	6.77
05/05/22	12:24:00 PM	6.80	6.87	0.03	14.61	0.02	22.75	2.55	2.26	6.78
05/05/22	12:25:00 PM	6.80	6.87	0.03	14.59	0.02	22.64	2.34	2.26	6.77
05/05/22	12:26:00 PM	6.78	6.87	0.03	14.61	0.02	22.69	2.61	2.26	6.76
05/05/22	12:27:00 PM	6.80	6.87	0.03	14.57	0.02	22.69	2.61	2.26	6.77
05/05/22	12:28:00 PM	6.78	6.87	0.03	14.64	0.02	22.66	2.74	2.26	6.77
05/05/22	12:29:00 PM	6.79	6.86	0.03	14.59	0.02	22.63	2.85	2.26	6.76
05/05/22	12:30:00 PM	6.78	6.86	0.03	14.61	0.02	22.63	2.74	2.26	6.77
05/05/22	12:31:00 PM	6.80	6.86	0.03	14.59	0.02	22.66	2.91	2.26	6.76
05/05/22	12:32:00 PM	6.79	6.86	0.03	14.63	0.02	22.66	2.52	2.26	6.77
05/05/22	12:33:00 PM	6.76	6.86	0.03	14.42	0.02	22.49	2.52	2.26	6.75
05/05/22	12:34:00 PM	6.79	6.86	0.03	14.71	0.02	22.64	2.39	2.26	6.75
05/05/22	12:35:00 PM	6.79	6.86	0.03	14.59	0.02	22.68	2.72	2.26	6.76
05/05/22	12:36:00 PM	6.80	6.86	0.03	14.59	0.02	22.69	2.51	2.26	6.77
05/05/22	12:37:00 PM	6.80	6.86	0.03	14.71	0.02	22.78	2.52	2.26	6.78
05/05/22	12:38:00 PM	6.79	6.86	0.03	14.83	0.02	22.75	2.20	2.26	6.76
05/05/22	12:39:00 PM	6.79	6.86	0.03	14.68	0.02	22.66	2.46	2.26	6.76
05/05/22	12:40:00 PM	6.79	6.86	0.03	14.85	0.02	22.69	2.57	2.26	6.76
05/05/22	12:41:00 PM	6.79	6.86	0.03	14.66	0.02	22.63	2.65	2.26	6.77
05/05/22	12:42:00 PM	6.78	6.86	0.03	14.75	0.02	22.69	2.37	2.26	6.75
05/05/22	12:43:00 PM	6.80	6.86	0.03	14.73	0.02	22.71	2.76	2.26	6.77
05/05/22	12:44:00 PM	6.80	6.85	0.03	14.78	0.02	22.85	2.40	2.26	6.78
05/05/22	12:45:00 PM	6.77	6.86	0.03	14.47	0.02	22.52	2.67	2.26	6.74
05/05/22	12:46:00 PM	6.79	6.85	0.03	14.64	0.02	22.75	2.65	2.26	6.77
05/05/22	12:47:00 PM	6.78	6.85	0.03	14.69	0.02	22.71	2.70	2.26	6.77
05/05/22	12:48:00 PM	6.79	6.85	0.03	14.83	0.02	22.83	2.42	2.27	6.77
05/05/22	12:49:00 PM	6.79	6.85	0.03	14.66	0.02	22.68	2.46	2.26	6.77
05/05/22	12:50:00 PM	6.78	6.85	0.03	14.63	0.02	22.63	2.65	2.27	6.75
05/05/22	12:51:00 PM	6.79	6.85	0.03	14.59	0.02	22.63	2.57	2.27	6.76
05/05/22	12:52:00 PM	6.79	6.85	0.03	14.76	0.02	22.71	3.27	2.27	6.77
05/05/22	12:53:00 PM	6.78	6.85	0.03	14.73	0.02	22.78	2.88	2.26	6.77
05/05/22	12:54:00 PM	6.79	6.85	0.03	14.69	0.02	22.66	2.57	2.27	6.76
05/05/22	12:55:00 PM	6.79	6.85	0.03	14.68	0.02	22.73	2.70	2.26	6.76
05/05/22	12:56:00 PM	6.80	6.85	0.03	14.80	0.02	22.93	2.67	2.27	6.79
05/05/22	12:57:00 PM	6.81	6.84	0.03	14.73	0.02	22.78	2.45	2.27	6.78
05/05/22	12:58:00 PM	6.80	6.84	0.03	14.68	0.02	22.78	2.65	2.27	6.78
05/05/22	12:59:00 PM	6.79	6.85	0.03	14.83	0.02	22.71	2.46	2.27	6.75
05/05/22	1:00:00 PM	6.79	6.85	0.03	14.76	0.02	22.66	2.50	2.26	6.76
05/05/22	1:01:00 PM	6.78	6.85	0.03	14.81	0.02	22.75	2.44	2.27	6.76
05/05/22	1:02:00 PM	6.80	6.84	0.03	14.75	0.02	22.75	2.32	2.27	6.76
05/05/22	1:03:00 PM	0.93	7.43	0.03	0.00	0.02	2.15	2.70	2.27	0.63
05/05/22	1:04:00 PM	0.28	7.73	0.04	0.00	0.02	5.51	2.77	2.27	2.60
05/05/22	1:05:00 PM	2.68	7.62	0.17	9.68	0.12	16.74	3.55	2.27	5.40
05/05/22	1:06:00 PM	2.54	7.63	0.04	8.12	0.07	15.60	2.07	2.27	5.16
05/05/22	1:07:00 PM	2.47	7.63	0.03	7.60	0.04	15.05	2.06	2.27	5.01

Woodville DWS May 5, 2022 Test # 41 - Well 1 & 2 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/05/22	1:03:00 PM	0.00	1.24	0.93	7.43	0.03	0.00	0.02	2.15	2.70	2.27	0.63
05/05/22	1:04:00 PM	2.40	1.76	0.28	7.73	0.04	0.00	0.02	5.51	2.77	2.27	2.60
05/05/22	1:05:00 PM	2.60	1.81	2.68	7.62	0.17	9.68	0.12	16.74	3.55	2.27	5.40
05/05/22	1:06:00 PM	2.65	1.75	2.54	7.63	0.04	8.12	0.07	15.60	2.07	2.27	5.16
05/05/22	1:07:00 PM	2.56	1.77	2.47	7.63	0.03	7.60	0.04	15.05	2.06	2.27	5.01
05/05/22	1:08:00 PM	2.52	1.77	2.46	7.64	0.03	7.66	0.03	14.90	2.07	2.26	4.97
05/05/22	1:09:00 PM	2.50	1.77	2.51	7.64	0.03	7.67	0.03	15.05	2.00	2.26	4.99
05/05/22	1:10:00 PM	2.51	1.78	2.52	7.63	0.03	7.71	0.03	14.99	1.92	2.26	5.01
05/05/22	1:11:00 PM	2.50	1.81	2.48	7.67	0.03	7.71	0.03	14.95	2.09	2.27	4.96
05/05/22	1:12:00 PM	2.50	1.81	2.52	7.65	0.03	7.86	0.03	15.24	2.25	2.27	5.01
05/05/22	1:13:00 PM	2.49	1.80	2.48	7.67	0.03	7.62	0.03	14.90	1.92	2.27	4.95
05/05/22	1:14:00 PM	2.50	1.80	2.50	7.67	0.03	7.83	0.03	15.14	1.99	2.27	4.99
05/05/22	1:15:00 PM	2.50	1.78	2.51	7.66	0.03	7.76	0.02	15.07	2.14	2.27	4.98
05/05/22	1:16:00 PM	2.51	1.77	2.52	7.68	0.03	7.79	0.02	15.18	1.91	2.27	5.01
05/05/22	1:17:00 PM	2.50	1.83	2.50	7.68	0.03	7.83	0.02	15.12	2.30	2.27	4.98
05/05/22	1:18:00 PM	2.50	1.82	2.50	7.67	0.03	7.72	0.02	15.07	2.20	2.27	4.98
05/05/22	1:19:00 PM	2.50	1.83	2.50	7.69	0.03	7.76	0.02	15.05	2.37	2.27	4.98
05/05/22	1:20:00 PM	2.50	1.83	2.50	7.68	0.03	7.69	0.02	15.02	1.97	2.27	4.98
05/05/22	1:21:00 PM	2.51	1.83	2.52	7.69	0.03	7.86	0.02	15.26	1.69	2.27	5.02
05/05/22	1:22:00 PM	2.51	1.77	2.54	7.68	0.03	7.71	0.02	15.21	2.09	2.27	5.03
05/05/22	1:23:00 PM	2.51	1.81	2.51	7.69	0.03	7.71	0.02	15.05	2.25	2.27	4.99
05/05/22	1:24:00 PM	2.51	1.81	2.53	7.68	0.03	7.81	0.02	15.24	1.89	2.26	5.03
05/05/22	1:25:00 PM	2.50	1.81	2.50	7.69	0.03	7.67	0.02	14.93	2.22	2.26	4.97
05/05/22	1:26:00 PM	2.50	1.82	2.51	7.68	0.03	7.72	0.02	15.12	2.22	2.26	5.00
05/05/22	1:27:00 PM	2.51	1.80	2.53	7.69	0.03	7.60	0.02	15.07	2.27	2.26	5.01
05/05/22	1:28:00 PM	2.51	1.78	2.51	7.69	0.03	7.74	0.02	15.09	2.11	2.26	4.99
05/05/22	1:29:00 PM	2.50	1.80	2.50	7.70	0.03	7.83	0.02	15.12	2.40	2.26	4.98
05/05/22	1:30:00 PM	2.51	1.86	2.51	7.72	0.03	7.76	0.02	15.14	2.22	2.26	5.00
05/05/22	1:31:00 PM	2.51	1.80	2.53	7.70	0.03	7.91	0.02	15.23	1.97	2.26	5.01
05/05/22	1:32:00 PM	2.50	1.83	2.50	7.70	0.03	7.81	0.02	15.11	2.10	2.26	4.99
05/05/22	1:33:00 PM	2.51	1.81	2.51	7.72	0.03	7.78	0.02	15.19	2.02	2.26	5.00
05/05/22	1:34:00 PM	2.50	1.83	2.51	7.71	0.03	7.95	0.02	15.21	2.02	2.26	5.00
05/05/22	1:35:00 PM	2.50	1.82	2.51	7.71	0.03	7.85	0.02	15.16	1.81	2.26	5.00
05/05/22	1:36:00 PM	2.50	1.82	2.50	7.71	0.03	7.72	0.02	15.05	2.42	2.26	4.98
05/05/22	1:37:00 PM	2.51	1.82	2.53	7.70	0.03	7.83	0.02	15.23	2.15	2.26	5.03
05/05/22	1:38:00 PM	2.50	1.83	2.51	7.70	0.03	7.88	0.02	15.18	2.51	2.26	4.99
05/05/22	1:39:00 PM	2.51	1.83	2.52	7.72	0.03	7.81	0.02	15.21	2.56	2.26	5.01
05/05/22	1:40:00 PM	2.50	1.84	2.52	7.70	0.03	7.91	0.02	15.16	2.20	2.26	5.00
05/05/22	1:41:00 PM	2.50	1.88	2.50	7.73	0.03	7.81	0.02	15.09	2.09	2.26	4.98
05/05/22	1:42:00 PM	2.51	1.82	2.53	7.72	0.03	8.00	0.02	15.36	2.21	2.26	5.02
05/05/22	1:43:00 PM	2.51	1.83	2.53	7.72	0.03	7.93	0.02	15.31	2.05	2.26	5.03
05/05/22	1:44:00 PM	2.50	1.83	2.51	7.71	0.03	7.95	0.02	15.19	2.14	2.26	4.99
05/05/22	1:45:00 PM	2.50	1.85	2.51	7.71	0.03	7.76	0.02	15.12	1.93	2.26	4.99
05/05/22	1:46:00 PM	2.51	1.89	2.52	7.71	0.03	8.17	0.02	15.36	2.09	2.26	5.01
05/05/22	1:47:00 PM	2.50	1.81	2.50	7.72	0.03	7.86	0.02	15.16	2.44	2.26	4.98
05/05/22	1:48:00 PM	2.50	1.81	2.51	7.70	0.03	7.93	0.02	15.28	2.07	2.26	4.99
05/05/22	1:49:00 PM	2.51	1.82	2.52	7.72	0.03	7.88	0.02	15.24	1.95	2.26	5.00
05/05/22	1:50:00 PM	2.51	1.83	2.53	7.72	0.03	7.90	0.02	15.33	1.99	2.26	5.02
05/05/22	1:51:00 PM	2.51	1.91	2.52	7.72	0.03	8.00	0.02	15.36	2.16	2.26	5.00
05/05/22	1:52:00 PM	2.51	1.82	2.51	7.72	0.03	7.85	0.02	15.18	2.21	2.26	5.00
05/05/22	1:53:00 PM	2.51	1.81	2.51	7.72	0.03	7.86	0.02	15.19	2.45	2.26	5.00
05/05/22	1:54:00 PM	2.50	1.83	2.51	7.72	0.03	7.90	0.02	15.24	2.35	2.26	5.00
05/05/22	1:55:00 PM	2.51	1.83	2.52	7.71	0.03	7.98	0.02	15.33	1.84	2.26	5.01
05/05/22	1:56:00 PM	2.50	1.88	2.51	7.73	0.03	7.83	0.02	15.12	2.29	2.26	4.99
05/05/22	1:57:00 PM	2.50	1.83	2.51	7.71	0.03	7.86	0.02	15.18	2.16	2.26	4.99
05/05/22	1:58:00 PM	2.50	1.83	2.50	7.72	0.03	7.90	0.02	15.16	2.65	2.26	4.97
05/05/22	1:59:00 PM	2.51	1.87	2.52	7.73	0.03	7.98	0.02	15.28	2.27	2.26	5.00
05/05/22	2:00:00 PM	2.51	1.85	2.52	7.73	0.03	8.02	0.02	15.30	2.19	2.26	5.01
05/05/22	2:01:00 PM	2.50	1.82	2.50	7.72	0.03	8.00	0.02	15.18	2.52	2.26	4.97
05/05/22	2:02:00 PM	2.51	1.82	2.53	7.73	0.03	8.12	0.02	15.45	2.14	2.26	5.03
05/05/22	2:03:00 PM	2.51	1.84	2.52	7.72	0.03	8.00	0.02	15.35	2.30	2.26	5.00
05/05/22	2:04:00 PM	2.51	1.87	2.51	7.72	0.03	8.03	0.02	15.33	2.29	2.26	4.99
05/05/22	2:05:00 PM	2.50	1.84	2.51	7.73	0.03	7.97	0.02	15.26	2.15	2.26	5.00
05/05/22	2:06:00 PM	2.51	1.85	2.52	7.72	0.03	7.97	0.02	15.30	2.15	2.26	5.00
05/05/22	2:07:00 PM	2.51	1.86	2.53	7.72	0.03	8.05	0.02	15.38	2.13	2.26	5.01
05/05/22	2:08:00 PM	2.52	1.85	2.54	7.72	0.03	8.15	0.02	15.48	2.57	2.26	5.04
05/05/22	2:09:00 PM	2.77	1.81	2.83	7.69	0.03	9.94	0.02	17.49	2.49	2.26	5.57
05/05/22	2:10:00 PM	2.75	1.85	2.75	7.69	0.03	9.73	0.02	17.22	2.27	2.26	5.47
05/05/22	2:11:00 PM	2.74	1.84	2.75	7.69	0.03	9.75	0.02	17.25	2.14	2.26	5.47
05/05/22	2:12:00 PM	2.74	1.82	2.74	7.72	0.03	9.72	0.02	17.10	2.19	2.26	5.46
05/05/22	2:13:00 PM	2.75	1.83	2.77	7.68	0.03	9.75	0.02	17.36	2.08	2.26	5.50

Woodville DWS May 5, 2022 Test # 42 - Well 1 & 2 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/05/22	2:04:00 PM	2.51	1.87	2.51	7.72	0.03	8.03	0.02	15.33	2.29	2.26	4.99
05/05/22	2:05:00 PM	2.50	1.84	2.51	7.73	0.03	7.97	0.02	15.26	2.15	2.26	5.00
05/05/22	2:06:00 PM	2.51	1.85	2.52	7.72	0.03	7.97	0.02	15.30	2.15	2.26	5.00
05/05/22	2:07:00 PM	2.51	1.86	2.53	7.72	0.03	8.05	0.02	15.38	2.13	2.26	5.01
05/05/22	2:08:00 PM	2.52	1.85	2.54	7.72	0.03	8.15	0.02	15.48	2.57	2.26	5.04
05/05/22	2:09:00 PM	2.77	1.81	2.83	7.69	0.03	9.94	0.02	17.49	2.49	2.26	5.57
05/05/22	2:10:00 PM	2.75	1.85	2.75	7.69	0.03	9.73	0.02	17.22	2.27	2.26	5.47
05/05/22	2:11:00 PM	2.74	1.84	2.75	7.69	0.03	9.75	0.02	17.25	2.14	2.26	5.47
05/05/22	2:12:00 PM	2.74	1.82	2.74	7.72	0.03	9.72	0.02	17.10	2.19	2.26	5.46
05/05/22	2:13:00 PM	2.75	1.83	2.77	7.68	0.03	9.75	0.02	17.36	2.08	2.26	5.50
05/05/22	2:14:00 PM	2.74	1.84	2.75	7.70	0.03	9.68	0.02	17.17	2.00	2.25	5.48
05/05/22	2:15:00 PM	2.74	1.87	2.74	7.70	0.03	9.75	0.02	17.17	2.07	2.25	5.46
05/05/22	2:16:00 PM	2.74	1.83	2.76	7.67	0.03	9.75	0.02	17.25	2.07	2.25	5.48
05/05/22	2:17:00 PM	2.75	1.87	2.75	7.69	0.03	9.65	0.02	17.17	2.14	2.25	5.47
05/05/22	2:18:00 PM	2.75	1.82	2.75	7.68	0.03	9.73	0.02	17.29	2.24	2.25	5.47
05/05/22	2:19:00 PM	2.75	1.81	2.75	7.69	0.03	9.63	0.02	17.17	2.09	2.26	5.46
05/05/22	2:20:00 PM	2.73	1.79	2.73	7.68	0.03	9.70	0.02	17.01	2.57	2.25	5.43
05/05/22	2:21:00 PM	2.74	1.86	2.74	7.68	0.03	9.68	0.02	17.17	2.30	2.26	5.45
05/05/22	2:22:00 PM	2.74	1.83	2.74	7.68	0.03	9.65	0.02	17.10	2.09	2.25	5.45
05/05/22	2:23:00 PM	2.74	1.83	2.74	7.68	0.03	9.77	0.02	17.27	1.92	2.25	5.46
05/05/22	2:24:00 PM	2.75	1.80	2.75	7.67	0.03	9.75	0.02	17.29	2.16	2.25	5.49
05/05/22	2:25:00 PM	2.74	1.83	2.74	7.68	0.03	9.70	0.02	17.20	2.79	2.25	5.47
05/05/22	2:26:00 PM	2.74	1.78	2.75	7.66	0.03	9.66	0.02	17.25	1.91	2.25	5.47
05/05/22	2:27:00 PM	2.74	1.76	2.74	7.67	0.03	9.80	0.02	17.32	2.31	2.25	5.47
05/05/22	2:28:00 PM	2.74	1.82	2.75	7.69	0.03	9.85	0.02	17.36	2.27	2.25	5.48
05/05/22	2:29:00 PM	2.74	1.78	2.76	7.66	0.03	9.70	0.02	17.32	2.00	2.25	5.47
05/05/22	2:30:00 PM	2.75	1.85	2.75	7.68	0.03	9.73	0.02	17.25	2.14	2.25	5.47
05/05/22	2:31:00 PM	2.75	1.82	2.76	7.65	0.03	9.77	0.02	17.32	2.19	2.26	5.48
05/05/22	2:32:00 PM	2.74	1.83	2.74	7.69	0.03	9.73	0.02	17.24	2.30	2.26	5.45
05/05/22	2:33:00 PM	2.74	1.81	2.75	7.68	0.03	9.78	0.02	17.36	2.32	2.26	5.48
05/05/22	2:34:00 PM	2.75	1.80	2.76	7.66	0.03	9.87	0.02	17.36	2.25	2.26	5.48
05/05/22	2:35:00 PM	2.73	1.86	2.73	7.68	0.03	9.68	0.02	17.15	2.49	2.26	5.42
05/05/22	2:36:00 PM	2.75	1.81	2.75	7.67	0.03	9.84	0.02	17.36	2.67	2.26	5.48
05/05/22	2:37:00 PM	2.74	1.84	2.74	7.68	0.03	9.97	0.02	17.44	2.40	2.25	5.47
05/05/22	2:38:00 PM	2.75	1.79	2.75	7.68	0.03	9.82	0.02	17.37	2.24	2.26	5.48
05/05/22	2:39:00 PM	2.74	1.81	2.74	7.66	0.03	9.73	0.02	17.36	2.07	2.25	5.47
05/05/22	2:40:00 PM	2.75	1.79	2.75	7.67	0.03	9.80	0.02	17.32	2.25	2.26	5.46
05/05/22	2:41:00 PM	2.74	1.80	2.73	7.68	0.03	9.77	0.02	17.27	2.09	2.25	5.45
05/05/22	2:42:00 PM	2.74	1.82	2.73	7.68	0.03	9.80	0.02	17.22	1.91	2.25	5.44
05/05/22	2:43:00 PM	2.75	1.80	2.76	7.69	0.03	9.89	0.02	17.44	2.20	2.25	5.49
05/05/22	2:44:00 PM	2.74	1.79	2.74	7.67	0.03	9.89	0.02	17.32	1.97	2.25	5.46
05/05/22	2:45:00 PM	2.74	1.79	2.76	7.69	0.03	9.82	0.02	17.37	2.45	2.25	5.47
05/05/22	2:46:00 PM	2.74	1.82	2.73	7.67	0.03	9.82	0.02	17.22	2.51	2.25	5.45
05/05/22	2:47:00 PM	2.74	1.82	2.74	7.68	0.03	9.82	0.02	17.30	2.40	2.25	5.46
05/05/22	2:48:00 PM	2.74	1.82	2.74	7.67	0.03	9.92	0.02	17.36	2.15	2.25	5.46
05/05/22	2:49:00 PM	2.75	1.81	2.75	7.68	0.03	9.84	0.02	17.36	2.32	2.25	5.47
05/05/22	2:50:00 PM	2.74	1.80	2.75	7.67	0.03	9.75	0.02	17.44	2.21	2.25	5.46
05/05/22	2:51:00 PM	2.74	1.86	2.74	7.68	0.03	9.99	0.02	17.53	2.20	2.25	5.47
05/05/22	2:52:00 PM	2.75	1.81	2.75	7.68	0.03	9.85	0.02	17.32	2.57	2.25	5.47
05/05/22	2:53:00 PM	2.75	1.80	2.76	7.65	0.03	9.82	0.02	17.48	2.37	2.25	5.49
05/05/22	2:54:00 PM	2.74	1.76	2.74	7.67	0.03	9.91	0.02	17.37	2.14	2.25	5.47
05/05/22	2:55:00 PM	2.75	1.78	2.77	7.67	0.03	9.82	0.02	17.46	2.03	2.25	5.50
05/05/22	2:56:00 PM	2.75	1.77	2.74	7.68	0.03	9.85	0.02	17.34	2.51	2.25	5.46
05/05/22	2:57:00 PM	2.74	1.81	2.74	7.67	0.03	9.96	0.02	17.41	2.57	2.25	5.46
05/05/22	2:58:00 PM	2.75	1.82	2.74	7.67	0.03	9.96	0.02	17.46	1.99	2.25	5.47
05/05/22	2:59:00 PM	2.74	1.83	2.75	7.67	0.03	9.89	0.02	17.41	2.16	2.25	5.46
05/05/22	3:00:00 PM	2.74	1.78	2.75	7.66	0.03	9.89	0.02	17.41	2.51	2.25	5.46
05/05/22	3:01:00 PM	2.74	1.81	2.74	7.67	0.03	9.82	0.02	17.29	1.69	2.25	5.45
05/05/22	3:02:00 PM	2.74	1.80	2.75	7.68	0.03	9.91	0.02	17.42	2.24	2.25	5.47
05/05/22	3:03:00 PM	2.74	1.84	2.75	7.69	0.03	9.91	0.02	17.41	2.05	2.25	5.47
05/05/22	3:04:00 PM	2.74	1.77	2.75	7.66	0.03	9.89	0.02	17.44	2.32	2.25	5.47
05/05/22	3:05:00 PM	2.75	1.79	2.75	7.68	0.03	10.09	0.02	17.65	2.15	2.25	5.48
05/05/22	3:06:00 PM	2.75	1.80	2.75	7.66	0.03	9.97	0.02	17.56	2.03	2.25	5.48
05/05/22	3:07:00 PM	2.76	1.81	2.77	7.67	0.03	10.15	0.02	17.72	2.24	2.25	5.51
05/05/22	3:08:00 PM	2.74	1.78	2.74	7.68	0.03	9.92	0.02	17.37	1.91	2.25	5.45
05/05/22	3:09:00 PM	2.74	1.81	2.75	7.67	0.03	9.96	0.02	17.44	2.15	2.25	5.46
05/05/22	3:10:00 PM	0.00	1.43	0.00	7.74	0.03	0.00	0.02	0.14	2.25	2.25	0.21
05/05/22	3:11:00 PM	0.00	1.46	5.34	7.37	0.03	0.00	0.03	119.75	2.65	2.25	5.27
05/05/22	3:12:00 PM	0.00	1.41	5.33	7.31	0.03	0.00	0.06	125.80	5.00	2.25	5.32
05/05/22	3:13:00 PM	0.00	1.39	5.29	7.29	0.03	0.00	0.03	123.62	3.13	2.25	5.26
05/05/22	1:07:00 PM	2.56	1.77	2.47	7.63	0.03	7.60	0.04	15.05	2.06	2.27	5.01

Woodville DWS May 9, 2022 Test # 43 - Well 1 & 2 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/09/22	7:58:00 AM	4.77	2.36	0.00	8.52	0.10	0.00	0.05	89.44	5.00	2.35	4.75
05/09/22	7:59:00 AM	5.13	2.27	0.00	8.44	0.20	7.04	0.30	14.64	5.00	2.35	5.23
05/09/22	8:00:00 AM	2.81	2.30	1.32	8.25	0.54	7.74	0.07	14.47	3.20	2.35	4.01
05/09/22	8:01:00 AM	2.69	2.23	2.66	8.15	0.21	9.00	0.10	16.15	2.40	2.35	5.33
05/09/22	8:02:00 AM	3.04	2.13	3.01	8.06	0.04	11.64	0.05	18.90	1.90	2.36	6.02
05/09/22	8:03:00 AM	3.03	2.19	3.00	8.04	0.04	11.72	0.04	18.93	2.15	2.36	5.99
05/09/22	8:04:00 AM	3.00	2.07	3.02	8.01	0.04	11.67	0.03	19.11	2.04	2.36	6.00
05/09/22	8:05:00 AM	3.00	2.05	3.01	7.97	0.04	11.59	0.03	18.97	2.11	2.36	5.99
05/09/22	8:06:00 AM	2.99	2.07	3.02	7.94	0.03	11.55	0.03	18.97	1.92	2.36	5.99
05/09/22	8:07:00 AM	3.00	2.04	3.00	7.94	0.03	11.59	0.03	18.93	2.04	2.36	5.97
05/09/22	8:08:00 AM	2.98	2.01	2.99	7.90	0.03	11.64	0.03	18.88	1.79	2.36	5.95
05/09/22	8:09:00 AM	2.98	2.02	2.99	7.90	0.03	11.59	0.03	18.81	2.16	2.36	5.94
05/09/22	8:10:00 AM	2.99	1.97	2.99	7.87	0.03	11.38	0.03	18.68	2.29	2.35	5.94
05/09/22	8:11:00 AM	2.99	2.01	2.99	7.87	0.03	11.47	0.03	18.73	2.45	2.35	5.94
05/09/22	8:12:00 AM	2.98	1.92	2.98	7.84	0.03	11.30	0.03	18.54	2.79	2.35	5.94
05/09/22	8:13:00 AM	2.98	1.96	2.99	7.85	0.03	11.40	0.03	18.59	2.60	2.35	5.95
05/09/22	8:14:00 AM	2.99	1.95	3.00	7.83	0.03	11.16	0.03	18.54	2.55	2.35	5.97
05/09/22	8:15:00 AM	2.98	1.92	2.98	7.84	0.03	11.38	0.03	18.49	2.40	2.35	5.94
05/09/22	8:16:00 AM	2.99	1.91	3.01	7.83	0.03	11.42	0.03	18.80	2.51	2.35	5.97
05/09/22	8:17:00 AM	2.98	1.94	2.99	7.83	0.03	11.24	0.03	18.52	2.57	2.35	5.94
05/09/22	8:18:00 AM	2.97	1.94	2.96	7.82	0.03	11.09	0.03	18.30	2.50	2.35	5.90
05/09/22	8:19:00 AM	2.98	1.91	2.98	7.81	0.03	11.19	0.03	18.57	2.46	2.35	5.94
05/09/22	8:20:00 AM	2.98	1.87	2.99	7.79	0.03	11.26	0.03	18.57	2.51	2.35	5.95
05/09/22	8:21:00 AM	2.97	1.87	2.96	7.78	0.03	11.23	0.03	18.35	2.52	2.35	5.91
05/09/22	8:22:00 AM	2.97	1.88	2.97	7.77	0.03	11.28	0.03	18.51	2.51	2.35	5.92
05/09/22	8:23:00 AM	2.97	1.85	2.98	7.78	0.03	11.26	0.03	18.51	2.60	2.35	5.92
05/09/22	8:24:00 AM	2.97	1.89	2.97	7.76	0.03	11.31	0.03	18.51	2.57	2.35	5.92
05/09/22	8:25:00 AM	2.97	1.82	2.96	7.76	0.03	11.19	0.03	18.42	2.39	2.35	5.91
05/09/22	8:26:00 AM	2.97	1.87	2.96	7.76	0.03	11.19	0.03	18.39	2.57	2.34	5.90
05/09/22	8:27:00 AM	2.97	1.89	2.96	7.76	0.03	11.30	0.03	18.49	2.61	2.35	5.91
05/09/22	8:28:00 AM	2.97	1.86	2.96	7.74	0.03	11.19	0.03	18.40	2.42	2.35	5.90
05/09/22	8:29:00 AM	2.97	1.82	2.97	7.73	0.03	11.19	0.03	18.47	2.22	2.35	5.92
05/09/22	8:30:00 AM	2.98	1.85	2.98	7.75	0.03	11.33	0.03	18.61	2.56	2.35	5.93
05/09/22	8:31:00 AM	2.98	1.86	2.98	7.74	0.03	11.47	0.03	18.69	2.50	2.34	5.94
05/09/22	8:32:00 AM	2.97	1.83	2.93	7.74	0.03	11.14	0.03	18.32	2.79	2.35	5.88
05/09/22	8:33:00 AM	2.98	1.82	2.96	7.72	0.03	11.21	0.03	18.40	2.87	2.35	5.90
05/09/22	8:34:00 AM	2.97	1.87	2.95	7.74	0.03	11.24	0.03	18.45	2.67	2.34	5.89
05/09/22	8:35:00 AM	2.97	1.79	2.94	7.71	0.03	11.09	0.03	18.33	2.52	2.35	5.89
05/09/22	8:36:00 AM	2.98	1.88	2.95	7.73	0.03	11.30	0.03	18.54	2.44	2.35	5.91
05/09/22	8:37:00 AM	2.97	1.78	2.96	7.71	0.03	11.30	0.03	18.56	2.56	2.35	5.91
05/09/22	8:38:00 AM	2.98	1.78	2.96	7.69	0.03	11.30	0.03	18.66	2.22	2.35	5.92
05/09/22	8:39:00 AM	2.98	1.83	2.96	7.72	0.03	11.23	0.03	18.61	2.51	2.35	5.91
05/09/22	8:40:00 AM	2.97	1.80	2.95	7.69	0.03	11.30	0.03	18.54	2.69	2.35	5.89
05/09/22	8:41:00 AM	2.97	1.79	2.94	7.70	0.03	11.26	0.03	18.45	2.35	2.35	5.88
05/09/22	8:42:00 AM	2.96	1.77	2.94	7.69	0.03	11.33	0.03	18.52	2.36	2.35	5.89
05/09/22	8:43:00 AM	2.97	1.76	2.94	7.71	0.03	11.18	0.03	18.35	2.50	2.35	5.89
05/09/22	8:44:00 AM	2.95	1.80	2.91	7.69	0.03	11.04	0.03	18.18	2.57	2.35	5.83
05/09/22	8:45:00 AM	2.97	1.80	2.94	7.70	0.03	11.07	0.03	18.35	2.50	2.35	5.88
05/09/22	8:46:00 AM	2.96	1.80	2.92	7.67	0.03	11.18	0.03	18.33	2.76	2.35	5.85
05/09/22	8:47:00 AM	2.97	1.77	2.94	7.69	0.03	11.26	0.03	18.54	2.52	2.35	5.87
05/09/22	8:48:00 AM	2.97	1.82	2.95	7.70	0.03	11.30	0.03	18.63	2.51	2.35	5.89
05/09/22	8:49:00 AM	2.96	1.83	2.93	7.68	0.03	11.18	0.03	18.39	2.61	2.35	5.86
05/09/22	8:50:00 AM	2.92	1.79	2.97	7.68	0.03	11.36	0.03	18.61	2.35	2.35	5.88
05/09/22	8:51:00 AM	2.93	1.77	2.95	7.67	0.03	11.19	0.03	18.40	2.02	2.35	5.86
05/09/22	8:52:00 AM	2.91	1.79	2.94	7.68	0.03	11.23	0.03	18.33	2.35	2.35	5.82
05/09/22	8:53:00 AM	2.92	1.79	2.94	7.69	0.03	11.14	0.03	18.33	2.51	2.35	5.84
05/09/22	8:54:00 AM	2.93	1.81	2.97	7.69	0.03	11.19	0.03	18.52	2.19	2.35	5.87
05/09/22	8:55:00 AM	2.93	1.75	2.96	7.69	0.03	11.19	0.03	18.42	2.32	2.35	5.86
05/09/22	8:56:00 AM	2.91	1.76	2.93	7.65	0.03	11.00	0.03	18.21	2.56	2.35	5.82
05/09/22	8:57:00 AM	2.92	1.73	2.94	7.68	0.03	11.16	0.03	18.39	2.81	2.36	5.83
05/09/22	8:58:00 AM	2.93	1.76	2.97	7.66	0.03	11.21	0.03	18.52	2.72	2.36	5.87
05/09/22	8:59:00 AM	2.95	1.78	2.95	7.66	0.03	11.31	0.03	18.57	2.62	2.36	5.87
05/09/22	9:00:00 AM	2.95	1.73	2.95	7.66	0.03	11.18	0.03	18.42	2.69	2.36	5.86
05/09/22	9:01:00 AM	2.95	1.75	2.95	7.66	0.03	11.19	0.03	18.54	2.62	2.36	5.89
05/09/22	9:02:00 AM	2.95	1.78	2.93	7.65	0.03	11.11	0.03	18.39	2.85	2.36	5.85
05/09/22	9:03:00 AM	2.95	1.79	2.93	7.67	0.03	11.09	0.03	18.30	2.52	2.36	5.84
05/09/22	9:04:00 AM	2.96	1.74	2.95	7.67	0.03	11.35	0.03	18.59	2.16	2.36	5.88
05/09/22	9:05:00 AM	2.95	1.76	2.95	7.65	0.03	11.12	0.03	18.45	2.52	2.36	5.88
05/09/22	9:06:00 AM	3.17	1.70	3.23	7.61	0.03	12.53	0.03	20.33	2.55	2.36	6.36
05/09/22	9:07:00 AM	3.25	1.71	3.25	7.61	0.03	13.08	0.03	21.05	2.63	2.36	6.46
05/09/22	9:08:00 AM	3.25	1.68	3.26	7.59	0.03	13.18	0.03	21.18	2.80	2.36	6.48

Woodville DWS May 9, 2022 Test # 44 - Well 1 & 2 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/09/22	9:02:00 AM	2.95	1.78	2.93	7.65	0.03	11.11	0.03	18.39	2.85	2.36	5.85
05/09/22	9:03:00 AM	2.95	1.79	2.93	7.67	0.03	11.09	0.03	18.30	2.52	2.36	5.84
05/09/22	9:04:00 AM	2.96	1.74	2.95	7.67	0.03	11.35	0.03	18.59	2.16	2.36	5.88
05/09/22	9:05:00 AM	2.95	1.76	2.95	7.65	0.03	11.12	0.03	18.45	2.52	2.36	5.88
05/09/22	9:06:00 AM	3.17	1.70	3.23	7.61	0.03	12.53	0.03	20.33	2.55	2.36	6.36
05/09/22	9:07:00 AM	3.25	1.71	3.25	7.61	0.03	13.08	0.03	21.05	2.63	2.36	6.46
05/09/22	9:08:00 AM	3.25	1.68	3.26	7.59	0.03	13.18	0.03	21.18	2.80	2.36	6.48
05/09/22	9:09:00 AM	3.26	1.74	3.27	7.60	0.03	13.30	0.03	21.32	2.86	2.36	6.50
05/09/22	9:10:00 AM	3.26	1.66	3.29	7.59	0.03	13.34	0.03	21.36	2.79	2.36	6.52
05/09/22	9:11:00 AM	3.25	1.75	3.26	7.60	0.03	13.17	0.03	21.29	2.75	2.35	6.48
05/09/22	9:12:00 AM	3.25	1.68	3.28	7.57	0.03	13.24	0.03	21.29	2.75	2.35	6.51
05/09/22	9:13:00 AM	3.27	1.68	3.28	7.58	0.03	13.22	0.03	21.39	2.79	2.36	6.52
05/09/22	9:14:00 AM	3.25	1.65	3.27	7.57	0.03	13.20	0.03	21.39	2.67	2.35	6.51
05/09/22	9:15:00 AM	3.25	1.64	3.26	7.57	0.03	13.34	0.03	21.29	2.52	2.35	6.49
05/09/22	9:16:00 AM	3.26	1.72	3.28	7.59	0.03	13.32	0.03	21.42	2.65	2.36	6.51
05/09/22	9:17:00 AM	3.25	1.66	3.27	7.56	0.03	13.30	0.03	21.34	2.59	2.35	6.49
05/09/22	9:18:00 AM	3.26	1.69	3.29	7.56	0.03	13.37	0.03	21.39	2.85	2.35	6.52
05/09/22	9:19:00 AM	3.25	1.65	3.27	7.56	0.03	13.18	0.03	21.34	2.80	2.35	6.50
05/09/22	9:20:00 AM	3.26	1.61	3.27	7.53	0.03	13.36	0.03	21.41	2.59	2.35	6.51
05/09/22	9:21:00 AM	3.26	1.71	3.29	7.56	0.03	13.36	0.03	21.48	2.80	2.35	6.53
05/09/22	9:22:00 AM	3.26	1.66	3.27	7.56	0.03	13.18	0.03	21.30	2.76	2.35	6.51
05/09/22	9:23:00 AM	3.26	1.68	3.28	7.55	0.03	13.41	0.03	21.46	2.61	2.35	6.50
05/09/22	9:24:00 AM	3.26	1.66	3.28	7.54	0.03	13.65	0.03	21.46	2.95	2.35	6.52
05/09/22	9:25:00 AM	3.25	1.66	3.28	7.53	0.03	13.27	0.03	21.41	2.57	2.35	6.50
05/09/22	9:26:00 AM	3.26	1.67	3.29	7.57	0.03	13.32	0.03	21.53	2.86	2.34	6.53
05/09/22	9:27:00 AM	3.26	1.64	3.28	7.53	0.03	13.36	0.03	21.39	2.80	2.34	6.51
05/09/22	9:28:00 AM	3.26	1.68	3.28	7.53	0.03	13.34	0.03	21.49	2.57	2.34	6.52
05/09/22	9:29:00 AM	3.26	1.67	3.28	7.55	0.03	13.27	0.03	21.36	2.57	2.34	6.51
05/09/22	9:30:00 AM	3.26	1.62	3.28	7.52	0.03	13.42	0.03	21.51	2.86	2.35	6.52
05/09/22	9:31:00 AM	3.27	1.64	3.29	7.54	0.03	13.42	0.03	21.49	2.89	2.35	6.53
05/09/22	9:32:00 AM	3.26	1.66	3.29	7.53	0.03	13.42	0.03	21.48	2.79	2.34	6.52
05/09/22	9:33:00 AM	3.25	1.63	3.27	7.54	0.03	13.42	0.03	21.42	2.89	2.34	6.51
05/09/22	9:34:00 AM	3.26	1.63	3.29	7.53	0.03	13.39	0.03	21.51	2.70	2.35	6.53
05/09/22	9:35:00 AM	3.27	1.61	3.29	7.54	0.03	13.41	0.03	21.56	2.74	2.35	6.53
05/09/22	9:36:00 AM	3.26	1.65	3.29	7.53	0.03	13.41	0.03	21.54	2.45	2.35	6.52
05/09/22	9:37:00 AM	3.26	1.62	3.28	7.53	0.03	13.60	0.03	21.60	2.70	2.34	6.52
05/09/22	9:38:00 AM	3.27	1.60	3.30	7.50	0.03	13.56	0.03	21.65	2.60	2.35	6.54
05/09/22	9:39:00 AM	3.26	1.65	3.28	7.52	0.03	13.42	0.03	21.51	2.44	2.35	6.51
05/09/22	9:40:00 AM	3.26	1.64	3.29	7.52	0.03	13.32	0.03	21.60	3.04	2.35	6.54
05/09/22	9:41:00 AM	3.26	1.62	3.28	7.53	0.03	13.41	0.03	21.58	2.57	2.35	6.52
05/09/22	9:42:00 AM	3.27	1.68	3.30	7.53	0.03	13.49	0.03	21.65	2.95	2.35	6.54
05/09/22	9:43:00 AM	3.27	1.63	3.30	7.51	0.03	13.56	0.03	21.66	2.67	2.35	6.56
05/09/22	9:44:00 AM	3.28	1.65	3.31	7.51	0.03	13.51	0.03	21.73	2.65	2.35	6.55
05/09/22	9:45:00 AM	3.27	1.63	3.31	7.50	0.03	13.54	0.03	21.70	2.61	2.35	6.56
05/09/22	9:46:00 AM	3.28	1.59	3.32	7.49	0.03	13.72	0.03	21.87	3.04	2.35	6.57
05/09/22	9:47:00 AM	3.27	1.63	3.29	7.50	0.03	13.53	0.03	21.68	3.16	2.35	6.54
05/09/22	9:48:00 AM	3.27	1.58	3.29	7.52	0.03	13.56	0.03	21.68	2.86	2.35	6.54
05/09/22	9:49:00 AM	3.28	1.61	3.32	7.50	0.03	13.53	0.03	21.85	2.75	2.35	6.57
05/09/22	9:50:00 AM	3.28	1.60	3.30	7.51	0.03	13.51	0.03	21.75	2.60	2.34	6.56
05/09/22	9:51:00 AM	3.25	1.60	3.27	7.49	0.03	13.60	0.03	21.53	2.86	2.35	6.51
05/09/22	9:52:00 AM	3.27	1.62	3.29	7.49	0.03	13.54	0.03	21.60	2.74	2.35	6.54
05/09/22	9:53:00 AM	3.27	1.60	3.29	7.49	0.03	13.61	0.03	21.72	2.80	2.35	6.55
05/09/22	9:54:00 AM	3.27	1.61	3.30	7.52	0.03	13.53	0.03	21.66	2.81	2.35	6.54
05/09/22	9:55:00 AM	3.27	1.65	3.30	7.53	0.03	13.49	0.03	21.78	2.75	2.35	6.55
05/09/22	9:56:00 AM	3.26	1.58	3.30	7.49	0.03	13.48	0.03	21.75	2.42	2.35	6.55
05/09/22	9:57:00 AM	3.27	1.57	3.32	7.50	0.03	13.58	0.03	21.75	2.56	2.35	6.56
05/09/22	9:58:00 AM	3.28	1.58	3.31	7.49	0.03	13.65	0.03	21.82	2.30	2.35	6.56
05/09/22	9:59:00 AM	3.26	1.62	3.28	7.51	0.03	13.53	0.03	21.60	2.57	2.35	6.51
05/09/22	10:00:00 AM	3.27	1.62	3.30	7.50	0.03	13.61	0.03	21.72	2.36	2.35	6.54
05/09/22	10:01:00 AM	3.27	1.57	3.30	7.49	0.03	13.63	0.03	21.82	2.44	2.35	6.55
05/09/22	10:02:00 AM	3.27	1.58	3.30	7.47	0.03	13.48	0.03	21.66	2.64	2.35	6.53
05/09/22	10:03:00 AM	3.27	1.63	3.30	7.49	0.03	13.65	0.03	21.70	2.57	2.34	6.54
05/09/22	10:04:00 AM	3.27	1.61	3.30	7.50	0.03	13.53	0.03	21.66	2.80	2.35	6.54
05/09/22	10:05:00 AM	3.27	1.60	3.29	7.47	0.03	13.65	0.03	21.72	2.92	2.35	6.54
05/09/22	10:06:00 AM	3.27	1.57	3.30	7.47	0.03	13.56	0.03	21.68	2.81	2.34	6.54
05/09/22	10:07:00 AM	3.27	1.57	3.30	7.47	0.03	13.54	0.03	21.61	2.60	2.34	6.53
05/09/22	10:08:00 AM	3.27	1.57	3.30	7.46	0.03	13.65	0.03	21.80	2.72	2.34	6.55
05/09/22	10:09:00 AM	3.27	1.64	3.28	7.48	0.03	13.61	0.03	21.75	2.80	2.34	6.53
05/09/22	10:10:00 AM	3.27	1.56	3.31	7.47	0.03	13.60	0.03	21.80	3.11	2.34	6.56
05/09/22	10:11:00 AM	3.35	1.55	3.39	7.45	0.03	14.52	0.03	22.68	2.72	2.34	6.73
05/09/22	10:12:00 AM	3.38	1.55	3.39	7.47	0.03	14.57	0.03	22.68	2.55	2.34	6.75

Woodville DWS May 9, 2022 Test # 45 - Well 1 & 2 - Train #1 & #2

Date	Time	Well #1 Flow	Well #1 Level	Well #2 Flow	Well #2 Level	Train #1 Filter Turbidity	Train #1 Headloss	Train #2 Filter Turbidity	Train #2 Headloss	Pre Chlorine	Post Chlorine	Treated Water Flow
05/09/22	10:08:00 AM	3.27	1.57	3.30	7.46	0.03	13.65	0.03	21.80	2.72	2.34	6.55
05/09/22	10:09:00 AM	3.27	1.64	3.28	7.48	0.03	13.61	0.03	21.75	2.80	2.34	6.53
05/09/22	10:10:00 AM	3.27	1.56	3.31	7.47	0.03	13.60	0.03	21.80	3.11	2.34	6.56
05/09/22	10:11:00 AM	3.35	1.55	3.39	7.45	0.03	14.52	0.03	22.68	2.72	2.34	6.73
05/09/22	10:12:00 AM	3.38	1.55	3.39	7.47	0.03	14.57	0.03	22.68	2.55	2.34	6.75
05/09/22	10:13:00 AM	3.40	1.57	3.40	7.44	0.03	14.52	0.03	22.78	3.09	2.34	6.77
05/09/22	10:14:00 AM	3.41	1.56	3.40	7.44	0.03	14.56	0.03	22.83	2.81	2.34	6.79
05/09/22	10:15:00 AM	3.40	1.55	3.40	7.45	0.03	14.57	0.03	22.85	2.76	2.32	6.78
05/09/22	10:16:00 AM	3.40	1.56	3.40	7.42	0.03	14.52	0.03	22.80	2.92	2.32	6.78
05/09/22	10:17:00 AM	3.40	1.51	3.40	7.44	0.03	14.47	0.03	22.75	2.96	2.32	6.78
05/09/22	10:18:00 AM	3.40	1.51	3.40	7.44	0.03	14.57	0.03	22.80	2.86	2.34	6.77
05/09/22	10:19:00 AM	3.40	1.54	3.41	7.43	0.03	14.64	0.03	22.87	2.70	2.34	6.79
05/09/22	10:20:00 AM	3.40	1.55	3.40	7.44	0.03	14.57	0.03	22.88	2.80	2.32	6.78
05/09/22	10:21:00 AM	3.40	1.51	3.40	7.44	0.03	14.54	0.03	22.80	2.44	2.32	6.77
05/09/22	10:22:00 AM	3.40	1.59	3.39	7.44	0.03	14.69	0.03	22.83	2.92	2.32	6.77
05/09/22	10:23:00 AM	3.40	1.55	3.38	7.44	0.03	14.45	0.03	22.64	2.46	2.32	6.75
05/09/22	10:24:00 AM	3.41	1.54	3.40	7.43	0.03	14.61	0.03	22.85	3.02	2.32	6.78
05/09/22	10:25:00 AM	3.41	1.54	3.41	7.41	0.03	14.66	0.03	22.93	2.91	2.32	6.79
05/09/22	10:26:00 AM	3.41	1.51	3.40	7.42	0.03	14.61	0.03	22.87	2.67	2.32	6.78
05/09/22	10:27:00 AM	3.40	1.51	3.39	7.44	0.03	14.75	0.03	22.87	2.86	2.32	6.76
05/09/22	10:28:00 AM	3.41	1.52	3.40	7.41	0.03	14.44	0.03	22.66	3.05	2.32	6.77
05/09/22	10:29:00 AM	3.41	1.52	3.40	7.40	0.03	14.56	0.03	22.87	2.92	2.32	6.79
05/09/22	10:30:00 AM	3.41	1.49	3.42	7.41	0.03	14.64	0.03	22.97	2.65	2.32	6.81
05/09/22	10:31:00 AM	3.41	1.53	3.40	7.40	0.03	14.52	0.03	22.83	2.46	2.32	6.79
05/09/22	10:32:00 AM	3.40	1.50	3.39	7.40	0.03	14.32	0.03	22.57	2.67	2.32	6.76
05/09/22	10:33:00 AM	3.41	1.53	3.41	7.40	0.03	14.64	0.03	22.95	2.75	2.32	6.79
05/09/22	10:34:00 AM	3.41	1.50	3.41	7.39	0.03	14.73	0.03	23.04	3.00	2.32	6.79
05/09/22	10:35:00 AM	3.41	1.57	3.40	7.41	0.03	14.75	0.03	22.95	2.46	2.32	6.78
05/09/22	10:36:00 AM	3.42	1.46	3.41	7.38	0.03	14.63	0.03	23.04	2.75	2.32	6.81
05/09/22	10:37:00 AM	3.41	1.51	3.41	7.40	0.03	14.78	0.03	23.07	2.56	2.32	6.79
05/09/22	10:38:00 AM	3.41	1.47	3.40	7.39	0.03	14.83	0.03	23.00	2.70	2.32	6.79
05/09/22	10:39:00 AM	3.42	1.48	3.42	7.38	0.03	14.78	0.03	23.19	2.76	2.32	6.82
05/09/22	10:40:00 AM	3.40	1.47	3.39	7.41	0.03	14.59	0.03	22.80	2.86	2.32	6.77
05/09/22	10:41:00 AM	3.41	1.51	3.42	7.38	0.03	14.81	0.03	23.19	3.01	2.32	6.81
05/09/22	10:42:00 AM	3.41	1.49	3.41	7.39	0.03	14.69	0.03	23.04	2.51	2.32	6.80
05/09/22	10:43:00 AM	3.41	1.53	3.40	7.40	0.03	14.69	0.03	22.83	2.91	2.32	6.79
05/09/22	10:44:00 AM	3.40	1.53	3.40	7.39	0.03	14.75	0.03	22.73	2.56	2.32	6.77
05/09/22	10:45:00 AM	3.41	1.51	3.41	7.39	0.03	14.80	0.03	23.00	2.46	2.32	6.80
05/09/22	10:46:00 AM	3.40	1.51	3.39	7.38	0.03	14.61	0.03	22.90	2.89	2.34	6.78
05/09/22	10:47:00 AM	3.42	1.47	3.42	7.37	0.03	14.63	0.03	23.11	3.07	2.34	6.81
05/09/22	10:48:00 AM	3.41	1.46	3.41	7.37	0.03	14.80	0.03	23.11	2.92	2.34	6.79
05/09/22	10:49:00 AM	3.41	1.47	3.41	7.40	0.03	14.88	0.03	23.14	2.84	2.32	6.79
05/09/22	10:50:00 AM	3.41	1.47	3.42	7.38	0.03	14.83	0.03	23.26	2.72	2.34	6.82
05/09/22	10:51:00 AM	3.41	1.47	3.41	7.38	0.03	14.73	0.03	23.00	2.72	2.34	6.79
05/09/22	10:52:00 AM	3.41	1.48	3.42	7.35	0.03	14.87	0.03	23.14	2.89	2.34	6.81
05/09/22	10:53:00 AM	3.41	1.50	3.40	7.39	0.03	14.88	0.03	23.05	2.49	2.34	6.79
05/09/22	10:54:00 AM	3.41	1.49	3.40	7.37	0.03	14.71	0.03	23.09	2.76	2.34	6.79
05/09/22	10:55:00 AM	3.41	1.46	3.40	7.37	0.03	14.92	0.03	23.14	2.90	2.34	6.78
05/09/22	10:56:00 AM	3.43	1.51	3.44	7.37	0.03	14.88	0.03	23.50	3.00	2.34	6.86
05/09/22	10:57:00 AM	3.42	1.48	3.41	7.36	0.03	14.75	0.03	23.09	2.95	2.34	6.80
05/09/22	10:58:00 AM	3.42	1.45	3.41	7.36	0.03	14.93	0.03	23.23	2.79	2.34	6.81
05/09/22	10:59:00 AM	3.41	1.47	3.42	7.37	0.03	14.93	0.03	23.19	2.95	2.34	6.81
05/09/22	11:00:00 AM	3.42	1.45	3.41	7.36	0.03	14.95	0.03	23.21	2.72	2.34	6.80
05/09/22	11:01:00 AM	3.42	1.52	3.42	7.36	0.03	14.87	0.03	23.19	2.81	2.34	6.81
05/09/22	11:02:00 AM	3.42	1.51	3.41	7.40	0.03	14.88	0.03	23.16	3.35	2.34	6.80
05/09/22	11:03:00 AM	3.42	1.48	3.41	7.38	0.03	14.85	0.03	23.19	2.81	2.34	6.82
05/09/22	11:04:00 AM	3.42	1.43	3.42	7.36	0.03	14.95	0.03	23.28	2.95	2.34	6.80
05/09/22	11:05:00 AM	3.41	1.45	3.41	7.35	0.03	14.90	0.03	23.23	2.67	2.34	6.79
05/09/22	11:06:00 AM	3.42	1.43	3.42	7.35	0.03	14.99	0.03	23.38	2.76	2.34	6.82
05/09/22	11:07:00 AM	3.42	1.46	3.42	7.36	0.03	14.93	0.03	23.26	2.66	2.34	6.81
05/09/22	11:08:00 AM	3.42	1.44	3.42	7.34	0.03	14.92	0.03	23.24	2.55	2.34	6.81
05/09/22	11:09:00 AM	3.42	1.48	3.41	7.36	0.03	14.85	0.03	23.23	2.83	2.34	6.81
05/09/22	11:10:00 AM	3.42	1.51	3.42	7.38	0.03	14.90	0.03	23.21	2.90	2.32	6.81
05/09/22	11:11:00 AM	3.42	1.45	3.42	7.34	0.03	14.92	0.03	23.31	2.74	2.32	6.82
05/09/22	11:12:00 AM	3.43	1.50	3.42	7.36	0.03	14.93	0.03	23.28	2.55	2.32	6.82
05/09/22	11:13:00 AM	3.04	1.55	2.64	7.43	0.03	0.00	0.03	115.27	2.92	2.32	5.51
05/09/22	11:14:00 AM	2.67	1.59	2.23	7.50	0.03	0.00	0.03	107.58	2.76	2.32	4.88
05/09/22	11:15:00 AM	0.00	1.09	5.37	7.08	0.03	0.00	0.03	109.23	3.25	2.32	5.32
05/09/22	11:16:00 AM	0.00	1.09	5.28	7.08	0.03	0.00	0.07	110.72	3.19	2.32	5.24
05/09/22	11:17:00 AM	0.00	1.10	5.32	7.07	0.03	0.00	0.03	111.55	3.35	2.32	5.28
05/09/22	10:12:00 AM	3.38	1.55	3.39	7.47	0.03	14.57	0.03	22.68	2.55	2.34	6.75