

# Kinmount Drinking Water System

---

Waterworks # 260075231  
System Category – Small Municipal Residential

## Annual Water Report

Prepared For: The City of Kawartha Lakes

Reporting Period of January 1<sup>st</sup> – December 31<sup>st</sup>, 2023

Issued: February 21, 2024

Revision: 0

Operating Authorities:



**OCWA**



This report has been prepared to satisfy the annual reporting requirements in  
O. Reg. 170/03 Section 11 and Schedule 22

## Table of Contents

Annual Water Report .....	1
Report Availability .....	1
Compliance Report Card .....	1
System Process Description .....	1
Raw Source .....	1
Treatment .....	1
Treatment Chemicals used during the reporting year: .....	2
Summary of Non-Compliance.....	2
Adverse Water Quality Incidents.....	2
Non-Compliance .....	2
Non-Compliance Identified in a Ministry Inspection: .....	2
Flows .....	2
Raw Water Flows.....	2
Total Monthly Flows (m <sup>3</sup> /d) .....	3
Monthly Rate Flows (L/s) .....	3
Treated Water Flows .....	3
Monthly Rated Flows .....	4
Annual Total Flow Comparison.....	4
Regulatory Sample Results Summary .....	5
Microbiological Testing .....	5
Operational Testing .....	5
Inorganic Parameters .....	5
Schedule 15 Sampling:.....	6
Organic Parameters.....	6
Additional Legislated Samples.....	9
Major Maintenance Summary .....	9
WTRS Data Submission Confirmation.....	A

## Report Availability

This system does not serve more than 10,000 residences. The annual reports will be available to residents at the City of Kawartha Lakes Public Works Administration Office and on the City’s website at: [www.kawarthalakes.ca](http://www.kawarthalakes.ca). Notification that reports are available free of charge will be made on the City of Kawartha Lakes website. The City of Kawartha Lakes Public Works Administration Office is located at 322 Kent Street West in Lindsay, Ontario.

## Compliance Report Card

**Drinking Water System Number:** 260075231

**Drinking Water System Name:** Kinmount DWS

**Drinking Water System Owner:** City of Kawartha Lakes

**Drinking Water System Category:** Small Municipal Residential

**Period Being Reported:** January 1, 2023 - December 31, 2023

	# of Events	Date	Details
<b>Health &amp; Safety</b>			
Number of Incidents	0		
<b>Drinking Water</b>			
MECP Inspections	1	October 12, 2023	2023-24 Announced-Focused Drinking Water Inspection – Final Inspection Rating of 100%.
AWQI's	0		
Number of Non-Compliances	0		
Number of Boil Water Advisories	0		

## System Process Description

### Raw Source

The Kinmount Water Treatment Plant is supplied with surface water from the Burnt River.

### Treatment

The treatment system is a dual train conventional filtration package plant consisting of the following:

- In-line static mixer
- Coagulant feed system with SternPac addition upstream of static mixer
- Two stage variable speed flocculators located in flocculation tanks
- Coagulant aid feed system with polymer added to flocculation tanks

- Two upflow clarifier units equipped with tube settlers
- Two dual media rapid gravity filters
- Sodium hypochlorite feed system for primary disinfection
- Dual celled chlorine contact tanks located beneath the plant
- Two highlift pump chambers housing four highlift pumps
- Sodium hypochlorite feed system for post chlorination
- Online analyzers to monitor both free treated chlorine and filter effluent turbidity
- Wastewater treatment system that consists of two backwash pumps and a settling tank that receives backwash wastewater and clarifier sludge
- SCADA computer control system
- Standby power generator

Treatment Chemicals used during the reporting year:

Chemical Name	Use	Supplier
Sodium Hypochlorite	Disinfection	Jutzi Water Technology
Polyalumunium Chloride	Flocculation	FloChem
Polymer	Flocculation	Basf
Sodium hydroxide	pH adjustment	Not required in 2023

## Summary of Non-Compliance

### Adverse Water Quality Incidents

There was no adverse water quality incidents during the reporting period.

### Non-Compliance

There were no non-compliance issues reported during the reporting period.

### Non-Compliance Identified in a Ministry Inspection:

There were no non-compliance identified in a Ministry Inspection for 2023/2024 inspection report.

## Flows


The Kinmount Drinking Water System is operating on average under half the rated capacity.

### Raw Water Flows

The Raw Water takings are regulated by the Permit to Take Water (PTTW). 2023 Raw Flow Data was submitted to the Ministry electronically under permit #2447-AWDJEA. The confirmation for the data that was submitted is attached in Appendix A.


Total Monthly Flows (m<sup>3</sup>/d)

Max Allowable PTTW- Raw



Monthly Rated Flows (L/s)

Max Allowable Rate – PTTW- Raw




**Treated Water Flows**

The Treated Water flows are regulated under the Municipal Drinking Water Licence (MDWL) 141-121.


Monthly Rated Flows

Rated Capacity - MDWL



Annual Total Flow Comparison

Total Annual m³



## Regulatory Sample Results Summary

### Microbiological Testing

	No. of Samples Collected	Range of E. Coli Results	Range of E. Coli Results	Range of Total Coliform Results	Range of Total Coliform Results	Range of HPC Results	Range of HPC Results
		Min	Max	Min	Max	Min	Max
<b>Raw</b>	26	2	60	42	360		
<b>Distribution</b>	53	0	0	0	0	0	1

### Operational Testing

Parameter	Number of Samples Collected	Range of Results Minimum	Range of Results Maximum
<b>Turbidity Filter 1 (NTU)</b>	8760	0.03	1.99
<b>Turbidity Filter 2 (NTU)</b>	8760	0.02	2.00
<b>Chlorine</b>	8760	0.00	2.65
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A	N/A

**Note:** Record the unit of measure if it is **not** milligrams per litre.

**Note:** For continuous monitors 8760 is used as the number of samples. Spikes recorded by on-line instrumentation were a result of air bubbles and various maintenance/calibration activities. All spikes are reviewed for compliance with O. Reg. 170/03.

### Inorganic Parameters

These parameters are tested as a requirement under O. Reg. 170/03. Sodium, Fluoride and the metals are required to be tested every 5 years while Nitrate and Nitrite are tested quarterly. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.

- MAC = Maximum Allowable Concentration as per O. Reg. 169/03
- MDL = Method Detection Limit

Treated Water Parameter	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances MAC	Exceedances ½ MAC
Antimony: Sb (ug/L) - TW	2020/01/06	<MDL 0.09	6.0	No	No
Arsenic: As (ug/L) - TW	2020/01/06	<MDL 0.2	10.0	No	No
Barium: Ba (ug/L) - TW	2020/01/06	18.5	1000.0	No	No
Boron: B (ug/L) - TW	2020/01/06	5.0	5000.0	No	No
Cadmium: Cd (ug/L) - TW	2020/01/06	<MDL 0.003	5.0	No	No
Chromium: Cr (ug/L) - TW	2020/01/06	0.28	50.0	No	No

Treated Water Parameter	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedances MAC	Exceedances ½ MAC
Mercury: Hg (ug/L) - TW	2020/01/06	<MDL 0.01	1.0	No	No
Selenium: Se (ug/L) - TW	2020/01/06	<MDL 0.04	50.0	No	No
Uranium: U (ug/L) - TW	2020/01/06	0.029	20.0	No	No
<b>Additional Inorganics</b>					
Fluoride (mg/L) - TW	2020/01/06	<MDL 0.06	1.5	No	No
Nitrite (mg/L) - TW	2023/01/03	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2023/04/03	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2023/07/04	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW	2023/10/03	<MDL 0.003	1.0	No	No
Nitrate (mg/L) - TW	2023/01/03	0.064	10.0	No	No
Nitrate (mg/L) - TW	2023/04/03	0.123	10.0	No	No
Nitrate (mg/L) - TW	2023/07/04	0.047	10.0	No	No
Nitrate (mg/L) - TW	2023/10/03	0.030	10.0	No	No
Sodium: Na (mg/L) - TW	2020/01/06	9.01	20*	No	No

\*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified mg/L when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

#### Schedule 15 Sampling:

The Schedule 15 Sampling is required under O. Reg. 170/03. This system is under reduced sampling. No plumbing samples were collected.

Distribution System	Number of Sampling Points	Number of Samples	Range of Results Minimum	Range of Results Maximum	MAC (ug/L)	Number of Exceedances
Alkalinity (mg/L)	2	2	25	35	N/A	N/A
pH	2	2	6.86	7.05	N/A	N/A
Lead (ug/l)	2	2	0.31	0.48	10	No

#### **Organic Parameters**

These parameters are tested every 5 years as a requirement under O. Reg.170/03. In the event any of the parameters exceed half of the maximum allowable concentration the parameter is required to be sampled quarterly.



## Kinmount Drinking Water System – 2023 Annual Water Reports

Treated Water Parameter	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedance MAC	Exceedance ½ MAC
Alachlor (ug/L) - TW	2020/01/06	<MDL 0.02	5.00	No	No
Atrazine + N-dealkylated metabolites (ug/L) - TW	2020/01/06	<MDL 0.01	5.0	No	No
Azinphos-methyl (ug/L) - TW	2020/01/06	<MDL 0.05	20.0	No	No
Benzene (ug/L) - TW	2020/01/06	<MDL 0.32	1.0	No	No
Benzo(a)pyrene (ug/L) - TW	2020/01/06	<MDL 0.004	0.01	No	No
Bromoxynil (ug/L) - TW	2020/01/06	<MDL 0.33	5.0	No	No
Carbaryl (ug/L) - TW	2020/01/06	<MDL 0.05	90.0	No	No
Carbofuran (ug/L) - TW	2020/01/06	<MDL 0.01	90.0	No	No
Carbon Tetrachloride (ug/L) - TW	2020/01/06	<MDL 0.17	2.0	No	No
Chlorpyrifos (ug/L) - TW	2020/01/06	<MDL 0.02	90.0	No	No
Diazinon (ug/L) - TW	2020/01/06	<MDL 0.02	20.0	No	No
Dicamba (ug/L) - TW	2020/01/06	<MDL 0.2	120.0	No	No
1,2-Dichlorobenzene (ug/L) - TW	2020/01/06	<MDL 0.41	200.0	No	No
1,4-Dichlorobenzene (ug/L) - TW	2020/01/06	<MDL 0.36	5.0	No	No
1,2-Dichloroethane (ug/L) - TW	2020/01/06	<MDL 0.35	5.0	No	No
1,1-Dichloroethylene (ug/L) - TW	2020/01/06	<MDL 0.33	14.0	No	No
Dichloromethane (Methylene Chloride) (ug/L) – TW	2020/01/06	<MDL 0.35	50.0	No	No
2,4-Dichlorophenol (ug/L) - TW	2020/01/06	<MDL 0.15	900.0	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) – TW	2020/01/06	<MDL 0.19	100.0	No	No
Diclofop-methyl (ug/L) - TW	2020/01/06	<MDL 0.4	9.0	No	No
Dimethoate (ug/L) - TW	2020/01/06	<MDL 0.06	20.0	No	No
Diquat (ug/L) - TW	2020/01/06	<MDL 1.0	70.0	No	No
Diuron (ug/L) - TW	2020/01/06	<MDL 0.03	150.0	No	No
Glyphosate (ug/L) - TW	2020/01/06	<MDL 1.0	280.0	No	No
Malathion (ug/L) - TW	2020/01/06	<MDL 0.02	190.0	No	No
Metolachlor (ug/L) - TW	2020/01/06	<MDL 0.01	50.0	No	No
Metribuzin (ug/L) - TW	2020/01/06	<MDL 0.02	80.0	No	No
Monochlorobenzene (Chlorobenzene) (ug/L) – TW	2020/01/06	<MDL 0.3	80.0	No	No
Paraquat (ug/L) - TW	2020/01/06	<MDL 1.0	10.0	No	No
PCB (ug/L) - TW	2020/01/06	<MDL 0.04	3.0	No	No
Pentachlorophenol (ug/L) - TW	2020/01/06	<MDL 0.15	60.0	No	No
Phorate (ug/L) - TW	2020/01/06	<MDL 0.01	2.0	No	No
Picloram (ug/L) - TW	2020/01/06	<MDL 1.0	190.0	No	No
Prometryne (ug/L) - TW	2020/01/06	<MDL 0.03	1.0	No	No
Simazine (ug/L) - TW	2020/01/06	<MDL 0.01	10.0	No	No
Terbufos (ug/L) - TW	2020/01/06	<MDL 0.01	1.0	No	No
Tetrachloroethylene (ug/L) - TW	2020/01/06	<MDL 0.35	10.0	No	No
2,3,4,6-Tetrachlorophenol (ug/L) -	2020/01/06	<MDL 0.2	100.0	No	No

Treated Water Parameter	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Exceedance MAC	Exceedance ½ MAC
TW					
Triallate (ug/L) - TW	2020/01/06	<MDL 0.01	230.0	No	No
Trichloroethylene (ug/L) - TW	2020/01/06	<MDL 0.44	5.0	No	No
2,4,6-Trichlorophenol (ug/L) - TW	2020/01/06	<MDL 0.25	5.0	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L)	2020/01/06	<MDL 0.12	100.0	No	No
Trifluralin (ug/L) - TW	2020/01/06	<MDL 0.02	45.0	No	No
Vinyl Chloride (ug/L) - TW	2020/01/06	<MDL 0.17	1.0	No	No
<b>Distribution Water</b>					
Trihalomethane: Total (ug/L) Annual Average - DW	2023	73.50	100	No	Yes
HAA Total (ug/L) Annual Average - DW	2023	61.73	80	No	Yes

MAC = Maximum Allowable Concentration as per O. Reg. 169/03

MDL = Method Detection Limit

### Additional Legislated Samples

Municipal Drinking Water Licence	Date Collected	Suspended Solids (mg/L)	Free Chlorine Residual (mg/L)
Settling Tank Discharge Point	January	<2	0.04
	February	17	0.02
	March	5	0.01
	April	8	0.01
	May	<2	0.01
	June	3	0.02
	July	<2	0.03
	August	<2	0.01
	September	<2	0.00
	October	2	0.03
	November	<2	0.04
	December	6	0.03
	Annual Average	4	

**Note:** The Suspended Solids 12 month running average limit is 25 mg/L.

Municipal Drinking Water Licence	Collected Weekly June – Oct	Total Microcystin Raw Results Range (ug/L)	Total Microcystin Treated Water Results Range (ug/L)	Treated Water Total Microcystin Limit 1.5 ug/L Exceeded Y/N
Harmful Algal Blooms Monitoring required June to October at a	June	<0.1 – <0.1	<0.1 – <0.1	N

Municipal Drinking Water Licence	Collected Weekly June – Oct	Total Microcystin Raw Results Range (ug/L)	Total Microcystin Treated Water Results Range (ug/L)	Treated Water Total Microcystin Limit 1.5 ug/L Exceeded Y/N
minimum. Samples collected weekly. Raw and Treated water tested for Total Microcystin.				
	July	<0.1 - <0.1	<0.1 – <0.1	N
	August	<0.1 - <0.1	<0.1 – <0.1	N
	September	<0.1 - <0.1	<0.1 – <0.1	N
	October	<0.1 – <0.1	<0.1 – <0.1	N



Method Detection Limit is 0.1ug/L

**Major Maintenance Summary incurred to install, repair or replace required equipment**

WO #	Description
3340302	Repair HLP2
3483617	Troubleshoot Filter #1 Floc Mixer
3525764	Replace CT Chlorine Analyzer
3206831	Replace Chemical Room Heater
3434724	Replace IT Equipment
3479959	Replace motor on exhaust fan

# Appendix A

## WTRS Data Submission Confirmation



Ministry of the Environment,  
Conservation and Parks

[| WT DATA](#) | [| USER PROFILE](#) | [| CONTACT US](#) | [| HELP](#) | [| HOME](#) | [| LOGOUT](#) |

Location: [WTRS](#) / [WT DATA](#) / [Input WT Record](#) WTRS-WT-008

**Water Taking Data submitted successfully.**

**Confirmation:**


Thank you for submitting your water taking data online.

Permit Number: 2447-AWDJEA  
Permit Holder: THE CORPORATION OF THE CITY OF KAWARTHA LAKES.  
Received on: Feb 6, 2024 8:34 AM

This confirmation indicates that your data has been received by the Ministry, but should not be construed as acceptance of this data if it differs from that specified on the Permit Number, assigned to the Permit Holder stated above.

[Print Confirmation](#)   [Return to Main Page](#)

CITY OF KAWARTHA LAKES | 2024/02/06  
version: v4.5.0.21 (build#: 22)  
Last modified: 2018/09/18

 This site maintained by  
the Government of Ontario ©2024 [Queen's Printer for Ontario](#)