## Kawartha Lakes ump In


### **PRESENTATION TO COUNCIL** Water and Wastewater Servicing and Capacity Master Plan Update

**Tuesday December 10, 2024** 



Photo: Lindsay Water **Treatment Plant** 

### Study Background and Objective The City has experienced a significant increase in growth over the recent years, which is driving demands for improvements and upgrades to its water and wastewater infrastructure.



### **TYLin**

-The City is forecasted to grow to 130,000 people and 40,600 jobs by 2051. This is reflected in the City's Growth Management Strategy (GMS), and is based on Provincial guidance (A Place to Grow, 2020).


-Council adopted the Province's housing target for Kawartha Lakes of 6,500 newly constructed housing units by the end of 2031.

The Objective of this Master Plan is to ensure that approved growth can be accommodated without affecting the level-of-service to existing residents and businesses.



## **Environmental Assessment Process**

### **Scope of the Master Plan**





## Notes About Growth and Infrastructure Plans


- current forecasts.
- evolution in the various plans.

### **IVLin**

-The Growth Management Strategy (GMS) process is a parallel study to this Water/Wastewater Master Plan Update -The growth forecasts presented on the next slides reflect the


-These plans (the GMS and the W/WW Master Plan) are updated regularly, so that adjustments can be made as required. -Infrastructure plans tend to be slightly conservative, so that recommended infrastructure can accommodate a degree of





### **IVLin**







	Water		Wastewater
	Treatment		Treatment
t	Capacity, MDD	Water Storage	Capacity, ADF
	[m3/d]	Capacity [m3]	[m3/d]
	22,730	11,650	24,500
	58%	74%	58%
	62,080	29,606	44,235
	7	74	5.6.7
		1 3	
2112	L-twose -		
U	HG1	UN-G-22	
	LIN-G-2	LIN-G-20 LIN-G-19	
	AING2		
HG-3	Investige of the second	St N Wala	
	P O ak St Elgin de	Entry Est	
+G-4	Elgin St of		LIN-FLATO-7
-00		borne St-W	ne Ste
Hay UN-FY	LINHER LINHER		Queen-St
K	LINHAZE LINE DOB Park	ntstw rr Dadita	Net Contraction
L			UN-HOZ HANNER IN
		Melbourne St.E	
-		Laine Linds	
1.			
LIN-GA	·	LIN-LHI CHI CHI LIN-SPA- 09	Lat-12
-	1.1.	Cem nery UN-STAT-08	LIN-BRO-I
C		HO-11 - 1 - 27 - 21	
	din Lin-BRO	unas Lindsay	
		Riverside Chaspart 4	LN-62 6
0		LIN-SPA-05 LIN-H	
-bi	ttle-Britain-Ro		Goldenmile Rd
3		Op.	Stor San
	Kilometers	O B	



### DD=Maximum Day Demand DF=Average Day Flow







### **IVLin**

	Water		Wastewater
	Treatment		Treatment
ent	Capacity, MDD	Water Storage	Capacity, ADF
a]	[m3/d]	Capacity [m3]	[m3/d]
	5,184	4,400	3,055
	69%	48%	85%
	8,792	4,894	5,540















	Water			
	Treatment			
ent		Water Storage		
a]	[m3/d]	Capacity [m3]		
	588	1,160		_
	32%	11%		
7	612	398		
		1 1		
	5 (15)			
	1/ A			
		WD	N-G-4	
			North Martin	
			Critical de la composition de	
	WD	4G-3	Woodciba Para	
	Mantan D		Argyle St. of all an and	
una je	and the same same and and	is division a water		
-King 51	1 P	Card Statements 1 Contraction	No. of Arction	ļ
///		and in the second secon		
		1 0 1		
	1	my of	ARTS O	
	1/ 5000		- 38-	
$\square$			Appendix	
			201 -	
		(mark		
1				
1,000 Meter	s de la	1 5	7 60-	





### Growth Forecasts – Other Communities Reserve Treatment Considerations

	Forecasted Population	Additional MDD Water Servicing	Reserve Treatment Capacity	Treatment Capacity
Water System	Growth	Need [m³/d]	[m³/day]	Available?
Birch Point	0	0	162	Yes
Canadiana Shores	0	0	716	Yes
Janetville	186	209	207	No ( <b>D</b> )
Kings Bay	106	119	174	Yes
Kinmount	329	370	252	No ( <b>D</b> )
Manilla	150	169	71	No ( <b>D</b> )
Manorview	0	0	235	Yes
Mariposa	0	0	5	Yes
Norland	12	14	78	Yes
Omemee	2,686	3,022	369	No ( <b>D</b> )
Pinewood	366	412	316	No ( <b>D</b> )
Pleasant Point	0	0	345	Yes
Sonya	0	0	92	Yes
Southview Estates	0	0	341	Yes
Victoria Place	0	0	33	Yes

	Wastewater System	Forecasted Population Growth	Additional ADF Wastewater Servicing Need [m <sup>3</sup> /d]	Reserve Treatment Capacity [m <sup>3</sup> /day]	Treatment Capacity Available?
	Coboconk	16	7	10	Limited (
	King's Bay	106	48	87	Yes (
Ί	Lin				

Jane appe Kinr appe Mar appe VTP serv deve VTP serv

**Coboconk:** No land available for expansion. Likely not warranted. **King's Bay:** Currently, low flows but high loadings. Detailed servicing assessment is recommended.



Janetville: Water Plant expansion appears warranted

**Kinmount:** Water Plant expansion appears warranted

Manilla: Water Plant expansion appears warranted

**Omemee:** Local neighbourhood WTP; Undertake detailed water servicing review for new developments.

**Pinewood:** Local neighbourhood WTP; Undertake detailed water servicing review for new developments.

## Level of Service Objectives

- maintain the level of service.

### Water Systems

### Water Treatment/Storage:

Ensure that water supply needs can be provided, with planning for upgrades when plant flows reach 80% of Capacity

### **System Pressures**

Operating pressures between 350 and 550 kPa (50 and 80 psi)

### **Fire Flow**

Under fire flow conditions, the pressure should not drop below 140 kPa (20 psi) at any point in the water system

**IVLin** 

-Development leads to increased water demands and wastewater flows, which may result in low pressure or fire flow in certain areas, or exceed the existing treatment plant capacities.

-The objective of this Master Plan Update will be to study the impact of the planned growth, and identify required solutions to

### Wastewater Systems

### Wastewater Treatment:

Ensure that wastewater treatment needs can be provided, with planning for upgrades when plant flows reach 80% of Capacity

### **Design Flows**

The sanitary sewers should not surcharge under **Design Flow Conditions** 

### **System Surcharge (Policy Under Development)**

Under Severe Storm Events, water levels in sanitary sewers shall be below basement levels



## Master Plan Objectives

- businesses
- level-of-service
- upgrades, and supporting growth

**TYLin** 

-The objective of this Master Plan Update will be to study the impact of the planned growth, and identify the following:

1. Risks to the Level-of-Service for existing residents and

2. Facility and system upgrades which need to be implemented to support the forecasted growth, and minimize the risks to the

3. Capital Planning investments to assist the City in financing these



## Servicing Assumptions

- 1. Treatment Upgrades: - The Preferred Alternatives (upgrade existing treatment plant; build a second treatment plant, replace existing plant with a new larger facility) will not be confirmed through this process - This Study *informs* subsequent "Schedule C" Class Environmental Assessments
- 2. Storage and Pumping Stations: - The need for these facility upgrades has been identified
- 3. Internal Development Servicing: – We have identified assumed connection points based on the following: - Availability of existing servicing adjacent to the development – Preliminary Servicing Plans (where available) – Topography and existing streets (where Servicing Plans are not Available) – These assumptions are to be confirmed, and internal systems will be designed by the owners to meet the Master Servicing Plan.

### **IVLin**



## Design Flow/Demand Basis

**Existing Serviced Areas are based on Historical Data** (Plant Flow Records and/or Sewer Flow Monitoring Data) - The hydraulic models have been calibrated

Future Development is considered at the City Design Standard – Average day water demand/wastewater flow: 450 Lpcd; – Extraneous flow: 0.26 L/s/ha – Appropriate peaking factors



## **Consultation Process and Activities**

- 1. Notice of Commencement: – Published June 8, 2023
- 2. Project Website:
- 3. Public Information Centre #1: – Held in Lindsay on October 18, 2023
- 4. Public Information Centre #2:
- 5. First Nations Consultation: – All local First Nations were contacted – Project Team met with Alderville First Nation on February 29, 2024

### **'IYLin**

 Established to facilitate ongoing consultation – Presentation was live-broadcasted, with remote participation – Held in Fenelon Falls on June 19, 2024; in Lindsay on June 20, 2024 – Lindsay presentation was live-broadcasted, with remote participation





### Kawartha Lakes Jump In Technical Studies Supporting Master Plan

- 3. Wastewater Flow Monitoring Report:
  - Fenelon Falls)
- 5. Services Demand Assessment:

**IVI** In

### 1. Background Information and Needs Review: – Internal review of technical information and studies

### 2. Field Investigation Recommendations:

- Identified the need for additional wastewater flow monitoring

– 22 Flow Monitoring Locations (12 in Lindsay; 7 in Bobcaygeon; 3 in

### Supported model development and calibration

### 4. System Capacity and Condition Assessment: – Documents the capacities of existing facilities

## - Establishes the servicing needs of the 2051 community populations

## **Evaluation of Alternatives**

### -The possible alternatives are as follows: 1. Do Nothing:

- 2. Limit Community Growth:

### **IVIII**

– Allow the growth to occur, but do not implement upgrades - The systems will not have sufficient capacity.

- Establish the ultimate population can be supported by infrastructure, and do not allow the communities to grow beyond that population

### - This does not fulfill the growth objectives established through *Places to Grow* and the Growth Management Strategy

### 3. Water Conservation and Inflow Reduction

- If we can reduce water demands and wastewater flows, the existing pipes can accommodate some increases in serviced population.

### - This is always an objective, but rarely a complete solution 4. Expand the Facilities and Services

### - Identify improvements required to Treatment, Pumping and Storage, Pipes - Continue to investigate options to reduce servicing requirements




## Evaluation of Alternatives


<b>Evaluation Criteria</b>	Alternative 1: Do Nothing	Alternative 2: Limit Community Growth	Alternative 3: Water Conservation	Alternative 4: Expand & Enhance Municipal Systems
<b>Technical Merit</b>	This would result in the desired level-of- service not being provided	Does not permit the Township to achieve the Regional growth targets.	This would maximise the use of the existing built capacity, but does not provide for servicing of greenfield development.	Completely addresses the growth envisioned in the Growth Management Strategy through intensification and expansions to urban boundaries.
Natural	No impact, but does not offer improvements to existing conditions.	No impact, but does not offer improvements to existing conditions.	No impact, and offers improvements to existing conditions.	Some impact as a result of construction works including creek crossings. Most construction will occur in road right-of-ways and the use of trenchless technologies will largely mitigate concerns. Offers valuable improvements to existing conditions.
Socio-Economic	Could result in basement flooding associated with surcharged sanitary sewers. Minimum pressure requirements or fire flow availability might not meet the desired level-of-service	This option does not meet the growth and density objectives of the City's growth forecast.	It can be difficult to encourage residents/businesses to conserve to the degree required to ensure success. Cannot guarantee long-term compliance. Greenfield development not serviced.	Modest impacts during construction, most of which will occur in outlying areas. Completely satisfies the City's growth forecast.
Financial	No impact.	Minor financial investment required to address existing capacity constraints.	Modest financial investment required. If not successful, would require additional investment in implementing another solution.	Significant financial investment required
OVERALL	Cannot satisfy City's Servicing Policies.	Cannot satisfy growth forecast.	Cannot satisfy growth forecast.	Optimal balance of benefits and impacts across all evaluation criteria while fully satisfying the City's growth forecasts.




# Lindsay - Water Constraints [Peak Hour]




# Lindsay - Water Constraints [Peak Hour]



Red: High Risk of failing to meet Level-of-service Orange: Moderate Risk Green: Low Risk Verulam Tank a PIGEON LAKE RD 0 0 0 WHEATFIELD RD Lindsay WTP and HLP **BPS: Booster Pumping Station** GOLDENMIL MAY 7 & 35 HLP: High-Lift Pumps WTP: Water Treatment Plant






### **TYLin**


### Kawartha Lakes Lindsay - Water Constraints [Max Day+Fire]

## Lindsay: Recommended Water Projects






## Bobcaygeon - Water Constraints [Peak Hour]




### **TYLin**


# Kawartha Lakes




## Bobcaygeon-Water Constraints [Max Day + Fire]








### Kawartha Lakes Jump In Bobcaygeon: Recommended Water Projects







## Fenelon Falls - Water Constraints [Peak Hour]









# Kawartha Lakes Fenelon Falls - Water Constraints [Max Day+ Fire]



### **IVIII**




## Fenelon Falls: Recommended Water Projects




### **IVLin**

Kawartha Lakes




# Woodville - Water Constraints [Peak Hour]






## Woodville: Recommended Water Projects






## Lindsay- Wastewater Constraints DWF




### **TYLin**

Kawartha Lakes






## Lindsay- Wastewater Constraints WWF






## Lindsay: Recommended Wastewater Projects




### **IVLin**




# Bobcaygeon- Wastewater Constraints DWF




# Bobcaygeon- Wastewater Constraints WWF







### Kawartha Lakes Jump In Bobcaygeon: Recommended Wastewater Projects




### Kawartha Lakes Jump In Fenelon Falls- Wastewater Constraints DWF







## Kawartha Lakes Fenelon Falls- Wastewater Constraints WWF



### **IVLin**





## Fenelon Falls: Recommended Wastewater Projects



### **TYLin**

# Kawartha Lakes






### **IVIII**

## **Omemee-** Wastewater Constraints DWF




# Kawartha Lakes Jump In Jump In Omemee- Wastewater Constraints WWF



### **IVIII**

## Omemee: Recommended Wastewater Projects



### **IVIII**



## Capital Forecast

Water System	Estimated Capital Costs	Forecasted Growth [Res. Units]	<b>Cost/Unit</b>
Lindsay	\$492,000,000	23,695	\$21,000
Bobcaygeon	\$77,000,000	2,406	\$32,000
Fenelon Falls	\$37,000,000	1,746	\$21,000
Woodville	\$7,000,000	718	\$10,000
TOTAL	\$613,000,000	28,565	\$21,000
Wastewater System	Estimated Capital Costs	Forecasted Growth [Res. Units]	Cost/Unit
Lindsay	\$381,000,000	23,695	\$16,000
Lindsay Bobcaygeon	\$381,000,000 \$82,000,000	23,695 2,406	\$16,000 \$34,000
Bobcaygeon	\$82,000,000	2,406	\$34,000



## Next Steps

- 1. Finalise Project File Report
- 2. Notice of Completion – Formal Consultation Activity, notifying Stakeholders that the Class EA process is complete
- 3. 30-Day Project File Review - Stakeholders have the opportunity to review the Project File and
  - ask questions
- Exempt: May proceed to implementation

**IVI** In

# - To Council with a final report for endorsement in 2025-Q1

## 4. Implementation (by Class EA Schedule)

- Schedule B and Schedule C: Must complete more detailed Study



# Kawartha Lakes

## THANK YOU

## **IVIIII**



Photo: Lindsay Water Treatment Plant