

Atlantic Liquid Meters Ontario
METER TICKET

CUSTOMER NAME
CITY OF KAWARTHA LAKES

ADDRESS
12 MOYNES CRT

Register Used
Test Liquid
Registration #
Units
Special Instructions
INITIAL READ
FINAL READ
TRANSMITTER#
SER#
Date Tested
Tester

: ECR
: WATER
:
: CUBIC FEET
:
: 0
: 0
:
: 79630217--
: DEC19/24
:

MODEL
G/T Used

5/8X3/4 SRII

GEARS
-

Bench

1

~W+~W~W*****

Units Min.	DEL	Reg. Read	percentage registration
HIGH	251.2	251.40	100.08%
MID	177.9	178.6	100.39%
INT LOW	115.6	116.80	101.04%
LOW	24.4	23.4	95.90%

Inspector
comments
MASTER METER
500 LITRE FORD METER BOX
VOLUMETRIC PROVER

OVERALL ACCURACY
99.35%

NO DISPLAY ON REGISTER
USED REGISTER FOR TESTING ONLY