

## NOTES:

- 1. ROAD DESIGN MUST COMPLY WITH MTO STANDARDS AND APPROPRIATE CKL CROSS SECTION. REFERENCE THE TAC MANUAL AND CKL ROADS INFRASTRUCTURE GUIDELINES FOR STANDARDS.
- 2. GRANULAR ROAD BASE TO BE COMPACTED TO 100% S.P.D.
- BOULEVARD AREAS TO RECEIVE 150mm TOPSOIL AND NUMBER 1 NURSERY SOD.

## MULTI-USE PATHWAY NOTES

- 1. ASPHALT TO BE PLACED AND SPREAD USING A MECHANICAL PAVER.
- 2. ASPHALT LAYERS (AFTER ROLLING) TO BE COMPACTED TO A MINIMUM 98% S.P.M.D.D.
- 3. IN THE EVENT OF UNSUITABLE SUB-GRADE MATERIAL, BASE IS TO BE OVER-EXCAVATED AND BACKFILLED WITH GRANULAR 'B' COMPACTED TO 985 S.P.M.D.D.
- 4. ALL BACKFILL TO BE COMPACTED IN LIFTS OF 100MM.
- ENSURE POSITIVE DRAINAGE.
- 6. TAMP ALL EDGES TO A FIRM 45 DEGREE BEVEL.
- 7. ALL DIMENSIONS IN MM.

	REVISIONS					
NO.	COMMENTS	BY	DATE	APPROVED BY	DATE APPROVED	
						DR
						┕
						<b>A</b> P

CITY OF KAWARTHA LAKES ENGINEERING AND CORPORATE ASSETS

322 KENT ST. W, LINDSAY ON. K9V 5B7, (705) 324-9411

PRAWN BY: AK CHECKED BY: DATE: 2025/04/24

APPROVED BY: DATE:



20 METRE URBAN LOCAL ROW PATHWAY ON ONE SIDE